

Southern California Edison
2022-WMPs – 2022 Wildfire Mitigation Plan Updates

DATA REQUEST SET O E I S - S C E - 2 2 - 0 0 2

To: Energy Safety
Prepared by: Napa Tayavibul
Job Title: Senior Advisor, Compliance
Received Date: 3/15/2022

Response Date: 3/18/2022

Question 14:

Off-Cycle Vegetation Management Inspections:

- a. On page 398, SCE discusses an off-cycle inspection that occurs 6-months after the planned annual inspection. During this inspection SCE inspects “most of its tree inventory”.
 - i. What criteria are used to identify inventory trees needing an off-cycle/second inspection?
 - ii. What percentage of SCE inventory was inspected during off-cycle in 2021?
 - iii. What percentage of SCE inventory will be inspected during off-cycle in 2022?

Response to Question 14:

- i. All trees in inventory are scheduled to receive an off-cycle inspection. The primary reason why most, but not all, trees receive an off-cycle inspection is because the annual inspections take priority, and in situations where inspections are not keeping pace with schedule, some off-cycle inspections may be cancelled to create capacity to maintain the annual schedule.
- ii. In 2021, 100% of SCE’s inventory was scheduled for an off-cycle inspection. Approximately 75% of SCE’s inventory had an off-cycle inspection performed.
- iii. Though 100% of SCE’s inventory is scheduled for an off-cycle inspection in 2022, based on the above, SCE expects to inspect between 75% and 100% of SCE’s inventory during off-cycle inspections.