
 SOUTHERN CALIFORNIA EDISON® Energy for What's Ahead™	Transmission and Distribution	DOCUMENT NUMBER	QCP-014
	Compliance & Quality	REVISION	0
	Quality Control	EFFECTIVE DATE	03/01/2021
TRANSMISSION DETAIL QC INSPECTION PROCESS FOR TRANSMISSION EQUIPMENT			

TABLE OF CONTENTS

SECTION	PAGE
1.0 PURPOSE	2
2.0 RESPONSIBILITIES	2
3.0 REFERENCES	2
4.0 PREREQUISITES	3
5.0 PRECAUTIONS	3
6.0 PROCEDURE	3
6.1 Workflow / Assignment	3
6.2 Inspection	3
6.3 Acceptance Criteria	4
6.4 Documentation	4
6.5 Checkpoint Review	4
ATTACHMENTS	
None	

 SOUTHERN CALIFORNIA EDISON® Energy for What's Ahead™	Transmission and Distribution	DOCUMENT NUMBER	QCP-014
	Compliance & Quality	REVISION	0
	Quality Control	EFFECTIVE DATE	03/01/2021
TRANSMISSION DETAIL QC INSPECTION PROCESS FOR TRANSMISSION EQUIPMENT			

1.0 PURPOSE

- 1.1 This procedure describes the SCE Quality Control (QC) activities utilized to provide independent oversight of the Transmission Detail Inspection Program (TIMP). Independent SCE QC inspections of poles are performed to assess the inspections performed by SCE Senior Patrol Man, and to provide reasonable assurance that quality in-field inspections are being performed by the SCE Senior Patrol Man.
- 1.2 SCE QC inspections for TIMP are based on sampling techniques defined by Governance and Reporting.
- 1.3 SCE QC inspection results are provided to G&R for reporting purposes. The information provided is intended to drive performance improvement.

2.0 RESPONSIBILITIES

- 2.1 The QC Senior Manager reports to the Compliance and Quality (C&Q) Principal Manager and is responsible for the overall QC Program development, implementation, and continuous improvement.
- 2.2 The QC Operations Manager(s) is responsible for the day-to-day operations of the TIMP QC program and for ensuring only personnel qualified to PQSQCTIMP "Transmission Detailed Inspections" are assigned to perform TIMP inspections. Ensures all provided scope is assigned monthly.
- 2.3 QC Inspectors are responsible for performing independent QC inspections of the SCE Senior Patrol Man work and for assuring the pole being inspected meets the requirements of CPUC GO 95 and Transmission Inspection and Maintenance Program Manual requirements as related to quality.
- 2.4 While performing inspections, QC Inspectors shall adhere to QCDP-004 QC Field Hazard Mitigation desk-top procedure.

3.0 REFERENCES

- 3.1 CPUC General Order 95 – Overhead Electric Line Construction
- 3.2 CPUC General Order 165 – Inspection Requirements for Electric Distribution and Transmission Facilities

	Transmission and Distribution	DOCUMENT NUMBER	QCP-014
	Compliance & Quality	REVISION	0
	Quality Control	EFFECTIVE DATE	03/01/2021
TRANSMISSION DETAIL QC INSPECTION PROCESS FOR TRANSMISSION EQUIPMENT			

- 3.3 SCE Accident Prevention Manual
- 3.4 Transmission Inspection and Maintenance Program (TIMP)
- 3.5 QCP-003 Qualification and Training of QC Personnel
- 3.6 QCDP-004 QC Field Hazard Mitigation

4.0 PREREQUISITES


- 4.1 Verify this document is current by reviewing the “Quality Control Document Revision Index.”
- 4.2 QC personnel performing overhead detailed inspections shall be qualified to Performance Qualification Standard PQSQCTIMP “Transmission Detailed Inspections.”

5.0 PRECAUTIONS

- 5.1 QC personnel performing overhead detailed inspections shall wear appropriate personnel protective equipment and meet the relevant requirements of the SCE Accident Prevention Manual.
- 5.2 QC inspectors will not perform any electrical work on/or in the structure/equipment, especially on energized equipment.

6.0 PROCEDURE

- 6.1 Workflow / Assignment
 - 6.1.1 Independent SCE QC inspections are performed for the work completed by SCE and Contractor inspectors.
 - 6.1.2 Selection of work is provided by G&R monthly.
- 6.2 Inspection
 - 6.2.1 The SCE QC inspector shall review assigned work prior to going to the field to verify no data issues exist that would result in inspection delays
 - 6.2.2 The SCE QC inspector performs inspections of the assigned structure and records the results in Survey 123. Technical issues/concerns may be raised

	Transmission and Distribution	DOCUMENT NUMBER	QCP-014
	Compliance & Quality	REVISION	0
	Quality Control	EFFECTIVE DATE	03/01/2021
TRANSMISSION DETAIL QC INSPECTION PROCESS FOR TRANSMISSION EQUIPMENT			

through management/supervision or to the QC TIMP subject matter expert.

6.2.3 The SCE QC inspector assesses the SCE Senior Patrol Man's work to assure the pole being assessed meets the applicable GO 95 requirements and that no potential GO infractions exist. Any misidentified items (GO infractions) or issues that affect safety/reliability will result in a failed structure for the purposes of assessing the SCE Senior Patrol Man's overall performance.

6.2.4 QC inspection records shall specify the structure inspected, the inspector, the date of the inspection, and any problems (or items requiring corrective action) identified during each inspection. The inspector should clearly annotate the GO infraction or issue that has not been satisfied.

6.3 Acceptance Criteria

6.3.1 Acceptability of product being inspected is obtained from GO95 and TIMP Manual.

6.4 Documentation

6.4.1 The SCE QC inspector documents completed inspection results into the Survey 123 app. Documentation shall include photographs of the structure and any identified nonconforming conditions.

6.5 Checkpoint Review

6.5.1 All nonconforming conditions identified by QC inspectors for each month are reviewed for accuracy during the checkpoint review process. The checkpoint review process provides a learning opportunity and continuous improvement in the inspection process.

6.5.2 Program SME to review inspection results for the month and communicate to Governance and Reporting for reporting process.