

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 3 - S C E - 0 0 5

To: Energy Safety
Prepared by: Kevin Arlic
Job Title: Senior Manager
Received Date: 5/25/2023

Response Date: 5/31/2023

Question 02. a:

Regarding SCE's Asset Inspection Program

a. Provide the inspection checklists used for both SCE's patrols and detailed inspections.

Response to Question 02. a:

Regarding detailed inspections, please refer to the inspection checklist "*Distribution Ground InspectApp Survey Approved 2022-05-20.*"

Regarding patrols, SCE's Annual Grid Patrol program follows GO 165 guidance in which it states: "Patrol inspection" shall be defined as a simple visual inspection, of applicable utility equipment and structures, that is designed to identify obvious structural problems and hazards. Although a checklist is neither required nor completed, further details regarding methods and procedures for the patrol can be referenced within the file: "*Distribution Inspection and Maintenance Program (DIMP).*"