

Southern California Edison
2025-WMPs – 2025-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 4 - S C E - 0 3

To: Energy Safety
Prepared by: Michelle Lambert
Job Title: Sr. Advisor
Received Date: 4/29/2024

Response Date: 5/2/2024

Question 06:
Regarding SCE's LineVue Program

On page 33 of SCE's 2025 WMP Update, SCE states that it is closing the LineVue program given a 0% find rate in 2023 and 2024.

- a. Did SCE have any other findings prior to 2023 using LineVue? If so:
1. Provide a list of such findings, including details on the type of finding (i.e. type of damage found).
 2. For each type of finding provided, describe what other existing inspection programs are able to detect such findings.

Response to Question 06:

a. Did SCE have any other findings prior to 2023 using LineVue? If so:

The 0% find rate for the LineVue inspection program referenced on page 33 of SCE's 2025 WMP Update is for 2022 and 2023 inspection years. The LineVue inspection program is still ongoing in 2024.

The 0% find rate was from a total of 79 inspections performed in 2022 and 70 inspections performed in 2023 for this program.

1. Provide a list of such findings, including details on the type of finding (i.e. type of damage found).

N/A

2. For each type of finding provided, describe what other existing inspection programs are able to detect such findings.

N/A