

Southern California Edison
2026-WMPs – 2026-WMPs

DATA REQUEST SET M G R A - S C E - 0 0 3

To: MGRA
Prepared by: Trang L Woo
Job Title: Engineer 3
Received Date: 5/23/2025

Response Date: 5/29/2025

Question MGRA 3-2:

Please provide an excel spreadsheet table that provides for 2019, 2020, 2021, 2022, 2023, and 2024:

- a. Number of outages attributable to infrastructure on fully “bare wire” conductor circuit segments in the HFRA.
- b. Number of outages attributable to infrastructure on fully covered conductor circuit segments in the HFRA.

Response to Question MGRA 3-2:

Number of Outages (HFRA)		
Year	Fully Covered Conductor	Not Covered Conductor ¹
2019	0	10,545
2020	0	5,707
2021	77	4,116
2022	120	2,701
2023	193	1,803
2024	312	1,248

***Includes both momentary and sustained outages**

¹ The figures in this column include outages attributable to infrastructure on circuit segments that are not fully Covered Conductor, including but are not limited to circuit segments with bare wire such as aerial cable.