

Southern California Edison
2026-WMPs – 2026-WMPs

DATA REQUEST SET M G R A - S C E - 0 0 4

To: MGRA
Prepared by: Elim Li
Job Title: Data Science, Senior Specialist
Received Date: 6/2/2025

Response Date: 6/5/2025

Question MGRA-4-13:

MGRA-4-13 Does SCE take PEDS into account in its probability of ignition analysis?

Response to Question MGRA-4-13:

SCE objects to this Question as vague and ambiguous. Subject to these objections, SCE responds as follows:

While outages on Fast Curve-enabled circuits are included in the subset of outages used to study the overhead conductor probability of failure and ignition, the sub-models do not directly consider the presence or impact of PEDS into their predictions.