

*Southern California Edison*  
*2026-WMPs – 2026-WMPs*

**DATA REQUEST SET M G R A - S C E - 0 0 5**

**To: MGRA**

**Prepared by: Jonathan Brownstein**

**Job Title: Engineering Manager**

**Received Date: 6/2/2025**

**Response Date: 6/5/2025**

---

**Question MGRA-5-2:**

The SCE response to MGRA-SCE-003-Q.1 indicated reportable ignitions on covered conductor in the HFRA. Please provide non-confidential summaries of root cause analysis reports for all covered conductor-related ignitions in the HFRA in 2024.

**Response to Question MGRA-5-2:**

SCE objects to this Question as vague and ambiguous. SCE interprets this Question to seek information relating to the three items listed under the “Number of reportable ignitions for fully covered conductor HFRA Circuits” for year-end 2024 listed in the attachment to SCE’s response to MGRA-SCE-003, Question 1. Subject to these objections, SCE responds as follows:

Please see the attached Excel file titled “MGRA\_SCE\_005\_Q2.xlsx.” Please note that upon further review, the ignition listed in row 3 of the attached spreadsheet was on a portion of the circuit containing bare wire, though greater than 95% of structures on the circuit contained covered conductor.