



David LeBlond  
Principal Manager, Regulatory Affairs-Wildfire & Public Safety  
[david.leblond@sce.com](mailto:david.leblond@sce.com)

Docket: 2026-2028 Electrical Corporation Wildfire Mitigation Plans  
Docket# 2026-2028-Base-WMPs  
Revision 3  
Volume 1 of 1

January 22, 2026

Tony Marino  
Deputy Director  
Office of Energy Infrastructure Safety  
715 P Street, 20th Floor  
Sacramento, CA 95814

**SUBJECT: SCE's Substantive Errata for the 2026-2028 Wildfire Mitigation Plan (WMP)**

Dear Deputy Director Marino:

Following SCE's second revised 2026-2028 WMP and non-substantive errata filing to the Office of Energy Infrastructure Safety (OEIS), OEIS identified non-substantive errors that remain for SCE to correct. The Notice on Errata to SCE also allows additional non-substantive errors to be submitted at the same time. SCE's corrections are set forth in the table and redlines on the following pages.

SCE's 2026-2028 WMP and associated materials are available at <https://www.sce.com/wmp/>

Sincerely,  
//s//

David LeBlond  
Principal Manager, Regulatory Affairs-Wildfire & Public Safety  
[david.leblond@sce.com](mailto:david.leblond@sce.com)

## Table of Errata

The table below lists requested corrections to the September 15, 2025 submission of SCE's 2026-2028 Base WMP R2.

Section	Page Number(s)	Description of Correction
Table of Contents	Starting on page i	SCE has updated the table of contents page number references to accurately reflect the correct WMP Sections, subsections, and page numbers throughout the WMP.
Section 4.2 Catastrophic Wildfire History	Page 31	SCE has updated Table 4-2: Catastrophic Wildfires to show the correct ignition date for the Round fire.
Section 9.2.1.5 Scheduling & Section 9.2.2.5 Scheduling	Pages 339 and 342	SCE has updated its 2026-2028 Base WMP to include the clarifications made in its response to Data Request 18, Questions 1 and 2.
Section 9.12 Work Orders	Page 375	SCE has adjusted Table 9-7 and Table 9-8 so that past due vegetation management work order totals for each table are the same.
Section 13.3 Discontinued Activities	Page 502	SCE has revised Section 13.3 of its 2026-2028 Base WMP to remove the SH-10 and SA-10 activities consistent with its response to Data Request 18, Question 3.

## Table Of Contents

1	Executive Summary.....	1
1.1	Primary WMP Goal.....	2
1.2	Plan Objectives .....	2
1.3	Framework for the development of the Base WMP.....	2
1.4	Summary of SCE's 2026-2028 WMP .....	3
1.4.1	Grid Design and System Hardening .....	3
1.4.2	Asset Inspections and Remediations .....	4
1.4.3	Vegetation Management .....	4
1.4.4	Situational Awareness and Forecasting .....	4
1.4.5	Emergency Preparedness, Collaboration, and Community Outreach .....	4
1.4.6	Public Safety Power Shutoff (PSPS) .....	5
1.4.7	Risk Methodology and Assessment.....	5
1.5	Conclusion .....	5
2	Responsible Persons .....	6
3	Overview of BaseWMP.....	8
3.1	Primary Goal .....	8
3.2	Plan Objectives .....	8
3.3	Utility Mitigation Activity Tracking IDs .....	11
3.4	Prioritized List of Wildfire Risks and Risk Drivers.....	12
3.5	Performance Metrics.....	18
3.6	Projected Expenditures.....	22
3.7	Climate Change .....	22
4	Overview of the Service Territory .....	26
4.1	Service Territory .....	26
4.2	Catastrophic Wildfire History .....	30
4.3	Frequently Deenergized Circuits.....	36
5	Risk Methodologyand Assessment .....	39
5.1	Methodology .....	39
5.1.1	Overview.....	39
5.2	Risk Analysis Framework.....	40
5.2.1	Risk and Risk Component Identification .....	42

5.2.2	Risk and Risk Components Calculation.....	6970
5.2.3	Key Assumptions and Limitations.....	10270
5.3	Risk Scenarios.....	1089
5.3.1	Design Basis Scenarios .....	10910
5.3.2	Extreme-Event/High Uncertainty Scenarios .....	1167
5.4	Summary of Risk Models .....	14920
5.5	Risk Analysis Results and Presentation .....	12930
5.5.1	Top Risk Areas within the HFRA.....	12930
5.5.2	Top Risk-Contributing Circuits/Segments/Spans .....	1356
5.6	Quality Assurance and Quality Control .....	1389
5.6.1	Independent Review.....	1389
5.6.2	Model Controls, Design, and Review.....	1414
5.7	Risk Assessment Improvement Plan.....	1436
6	Wildfire Mitigation Strategy.....	14952
6.1	Risk Evaluation.....	14952
6.1.1	Approach.....	14952
6.1.2	Risk-Informed Prioritization.....	1525
6.1.3	Activity Selection Process.....	15760
6.2	Wildfire Mitigation Strategy .....	1914
6.2.1	Anticipated Risk Reduction .....	1914
6.2.2	Interim Activities.....	2069
7	Public Safety Power Shutoff .....	20811
7.1	Planned Initiative Actions to Reduce the Impacts of PSPS Events .....	20811
7.2	Frequently De-Energized Circuits .....	2114
7.3	Lessons Learned Since 2023-2025 WMP .....	2114
8	Grid Design, Operations, and Maintenance .....	2147
8.1	Targets .....	2147
8.1.1	Qualitative Targets .....	2147
8.1.2	Quantitative Targets .....	2158
8.2	Grid Design and System Hardening .....	21922
8.2.1	Covered Conductor Installation.....	2225
8.2.2	Undergrounding of Electric Lines and/or Equipment .....	22831

8.2.3	Distribution Pole Replacements and Reinforcements.....	23841
8.2.4	Transmission Pole/Tower Replacements and Reinforcements .....	2401
8.2.5	Traditional Overhead Hardening .....	2444
8.2.6	Emerging Grid Hardening Technology Installations and Pilots.....	2469
8.2.7	Microgrids.....	25861
8.2.8	Installation of System Automation Equipment .....	25962
8.2.9	Line Removal (in the HFTD).....	2636
8.2.10	Other Grid Topology Improvements to Minimize Risk of Ignitions.....	2658
8.2.11	Other Grid Topology to Mitigate or Reduce PSPS Events .....	2658
8.2.12	Other Technologies and Systems Not Listed Above.....	2658
8.2.13	Status Updates on Additional Technologies Being Piloted .....	26871
8.3	Asset Inspections .....	2703
8.3.1	Distribution High Fire Risk-Informed (HFRI) Inspections - Ground and Aerial (IN-1.1) .....	272
	5	
8.3.2	Transmission High Fire Risk-Informed (HFRI) Inspections - Ground and Aerial (IN-1.2) .....	278
	81	
8.3.3	Distribution Infrared Scanning (IN-3) .....	2803
8.3.4	Transmission Infrared (IR) and Corona Scanning (IN-4).....	2836
8.3.5	Generation HFRI Inspections (IN-5).....	2858
8.3.6	(Discontinued) Transmission Conductor and Splice Assessment.....	28790
8.4	Equipment Maintenance and Repair .....	28790
8.5	Quality Assurance and Quality Control .....	3044
8.5.1	Overview, Objectives, and Targets.....	3044
8.5.2	QA and QC Procedures .....	3047
8.5.3	Sampling Plan .....	3047
8.5.4	Pass Rate Calculation .....	3047
8.5.5	Other Metrics .....	3058
8.5.6	Documentation of Findings.....	3058
8.5.7	Changes to QA and QC Since Last WMP and Planned Improvements.....	3069
8.6	Work Orders .....	30710
8.7	Grid Operations and Procedures .....	3136

8.7.1	Equipment Settings to Reduce Wildfire Risk.....	31	36
8.7.2	Grid Response Procedures and Notifications .....	32	03

8.7.3	Personnel Work Procedures and Training in Conditions of Elevated Fire Risk .....	3225
8.8	Workforce Planning .....	3258
9	Vegetation Management and Inspections .....	32831
9.1	Targets .....	32831
9.1.1	Qualitative Targets.....	32831
9.1.2	Quantitative Targets .....	32932
9.2	Vegetation Management Inspections .....	3326
9.2.1	Inspections for Vegetation Clearances from Distribution Lines (VM-7) .....	3337
9.2.2	Inspections for Vegetation Clearances from Transmission Lines (VM-8) .....	33641
9.2.3	Hazard Tree Management Program (VM-1) .....	33843
9.2.4	Dead and Dying Tree Removal (VM-4).....	3416
9.3	Pruning and Removal .....	3438
9.3.1	Overview.....	3438
9.3.2	Procedures .....	3438
9.3.3	Scheduling.....	3449
9.3.4	Updates .....	3449
9.4	Pole Clearing .....	3449
9.4.1	Overview.....	3449
9.4.2	Procedures .....	34550
9.4.3	Scheduling.....	34550
9.4.4	Updates .....	34550
9.5	Wood and Slash Management .....	34651
9.5.1	Overview.....	34651
9.5.2	Procedures .....	34651
9.5.3	Scheduling.....	34651
9.5.4	Updates .....	34651
9.6	Defensible Space .....	34752
9.6.1	Overview.....	34752
9.6.2	Procedures .....	34752
9.6.3	Scheduling.....	34752
9.6.4	Updates .....	34853

9.7	Integrated Vegetation Management .....	34853
9.7.1	Overview.....	34853
9.7.2	Procedures.....	34853
9.7.3	Scheduling.....	34854
9.7.4	Updates .....	34954
9.8	Partnerships .....	3505
9.8.1	State Fire Agency Partnership (Cal Fire) – Operation Santa Ana .....	3527
9.8.2	Educational Institution Partnership (Cal Poly Wildland Urban Interface) .....	3538
9.8.3	Educational Institution Partnership (San Bernardino Community College District)9.8.4	3549
9.8.4	USFS Region 5.....	35560
9.8.5	International Wildfire Risk Mitigation Consortium (IWRMC) .....	3651
9.9	Activities Based on Weather Conditions .....	35762
9.9.1	Overview.....	35762
9.9.2	Procedures.....	35762
9.9.3	Scheduling.....	35762
9.9.4	Updates .....	35863
9.10	Post-Fire Service Restoration .....	35863
9.10.1	Overview.....	35863
9.10.2	Procedures.....	35863
9.10.3	Scheduling.....	35863
9.10.4	Updates .....	35964
9.11	Quality Assurance and Quality Control .....	35964
9.11.1	Overview, Objectives, and Targets.....	35964
9.11.2	QA/QC Procedures .....	3638
9.11.3	Sample Sizes .....	3638
9.11.4	Pass Rate Calculation .....	3649
9.11.5	Other Metrics.....	3649
9.11.6	Documentation of Findings .....	36570
9.11.7	Changes to QA/QC Since Last WMP and Planned Improvements .....	36570
9.12	Work Orders .....	36671
9.12.1	Priority Assignment .....	36671

9.12.2	Backlog Elimination .....	3672
9.12.3	Trends .....	3673
9.13	Workforce Planning.....	3746
9.13.1	Recruitment .....	3738
9.13.2	Training and Retention .....	3749
10	Situational Awareness and Forecasting.....	37580
10.1	Targets .....	37580
10.1.1	Qualitative Targets .....	37580
10.1.2	Quantitative Targets .....	37681
10.2	Environmental Monitoring Systems .....	37984
10.2.1	Existing Systems, Technologies, and Procedures.....	37984
10.2.2	Evaluation and Selection of New Systems.....	38792
10.2.3	Planned Improvements.....	38792
10.2.4	Evaluating Activities .....	38893
10.3	Grid Monitoring Systems .....	38893
10.3.1	Existing Systems, Technologies, and Procedures .....	38893
10.3.2	Evaluation and Selection of New Systems.....	4005
10.3.3	Planned Improvements .....	4016
10.3.4	Evaluating Activities .....	4027
10.4	Ignition Detection Systems.....	4027
10.4.1	Existing Ignition Detection Sensors and Systems.....	4038
10.4.2	Evaluation and Selection of New Detection Systems .....	40712
10.4.3	Planned Integration of New Ignition Detection Technologies .....	40813
10.4.4	Evaluating Activities .....	40914
10.5	Weather Forecasting.....	40914
10.5.1	Existing Modeling Approach .....	4105
10.5.2	Known Limitations of Existing Approach .....	41722
10.5.3	Planned Improvements .....	41924
10.5.4	Evaluating Activities .....	4216
10.5.5	Weather Station Maintenance and Calibration .....	4246
10.6	Fire Potential Index .....	4227

10.6.1	Existing Calculation Approach and Use.....	42 <del>38</del>
10.6.2	Known Limitations of Existing Approach.....	42 <del>631</del>
10.6.3	Planned Improvements.....	42 <del>631</del>
11	Emergency Preparedness, Collaboration, and Community Outreach .....	42 <del>732</del>
11.1	Targets .....	42 <del>732</del>
11.1.1	Qualitative Targets .....	42 <del>732</del>
11.2	Emergency Preparedness and Recovery Plan .....	43 <del>05</del>
11.2.1	Overview of Wildfire and PSPS Emergency Preparedness and Service Restoration .....	43 <del>1</del>
		6
11.2.2	Planning and Allocation of Resources .....	43 <del>843</del>
11.3	External Collaboration and Coordination.....	44 <del>05</del>
11.3.1	Communication Strategy with Public Safety Partners .....	44 <del>05</del>
11.3.2	Collaboration on Local and Regional Wildfire Mitigation Planning .....	44 <del>50</del>
11.3.3	Collaboration with Tribal Governments.....	44 <del>954</del>
11.4	Public Communication, Outreach, and Education Awareness .....	45 <del>16</del>
11.4.1	Protocols for Emergency Communications .....	45 <del>27</del>
11.4.2	Messaging .....	45 <del>61</del>
11.4.3	Outreach and Education Awareness Activities .....	45 <del>762</del>
11.4.4	Engagement with Access and Functional Needs Populations .....	46 <del>27</del>
11.4.5	Engagement with Tribal Nations .....	46 <del>570</del>
11.4.6	Current Gaps and Limitations .....	46 <del>671</del>
11.5	Customer Support in Wildfire and PSPS Emergencies .....	46 <del>72</del>
11.5.1	Critical Care Backup Battery Program (CCBB) (PSPS-2) .....	46 <del>974</del>
11.5.2	Portable Power Station Rebate Program and Portable Generator Rebate Program (PSPS-3) .....	47 <del>0</del>
		5
11.5.3	Disability Disaster and Access Resources (DDAR) Program .....	47 <del>05</del>
11.5.4	In-Event Battery Loan Pilot.....	47 <del>05</del>
11.5.5	Customer-Side Generator .....	47 <del>05</del>
11.5.6	PSPS 211 Service .....	47 <del>16</del>
11.5.7	Customer Contact Center .....	47 <del>16</del>
12	Enterprise Systems .....	47 <del>27</del>

12.1	Targets .....	47	27
12.1.1	Qualitative Targets.....	47	27

12.2	Summary of Enterprise Systems .....	47	49
13	Lessons Learned .....	47	984
13.1	Description and Summary of Lessons Learned .....	47	984
13.2	Working Group Meetings .....	49	49
13.3	Discontinued Activities.....	49	7502
	Appendix A: Definitions .....	49	9504
	Definition of Terms .....	49	9504
	Definitions of Initiatives by Category .....	52	05
	Definitions of Activities by Initiative .....	52	732
	Appendix B: Supporting Documentation for Risk Methodology and Assessment.....	53	16
	Model Inventory .....	53	16
	Summary Documentation .....	53	38
	R1: Overall Utility Risk.....	53	641
	R2: Wildfire Risk.....	53	843
	R3: Outage Program Risk.....	54	05
	IRC1: Wildfire Likelihood .....	54	27
	IRC2: Ignition Likelihood .....	54	27
	IRC3: Wildfire Consequence .....	54	49
	IRC4: PSPS Risk .....	54	651
	IRC5: PSPS Likelihood .....	54	853
	IRC6: PSPS Consequence.....	55	05
	IRC7: PEDS Outage Risk .....	55	27
	IRC8: PEDS Outage Likelihood .....	55	49
	IRC9: PEDS Outage Consequence .....	55	61
	FRC1: Equipment Caused Ignition Likelihood .....	55	863
	FRC2: Contact from Vegetation Likelihood of Ignition .....	56	05
	FRC3: Contact from Object Likelihood of Ignition .....	56	27
	FRC4: Burn Likelihood.....	56	49
	FRC5: Wildfire Hazard Intensity .....	56	49
	FRC6: Wildfire Exposure Potential.....	56	49
	FRC7: Wildfire Vulnerability.....	56	49
	FRC8: PSPS Exposure Potential .....	56	671

FRC9: PSPS Vulnerability .....	56671
FRC10: PEDS Outage Exposure Potential .....	56873
FRC11: PEDS Outage Vulnerability .....	56873
Appendix C: Additional Maps .....	5705
Appendix D: Areas for Continued Improvement .....	5746
Risk Methodology and Assessment.....	5746
SCE-25U-01. Calculating Risk Scores Using Maximum Consequence Values.....	5746
SCE-23B-04. Incorporation of Extreme Weather Scenarios into Planning Models.....	57681
Wildfire Mitigation Strategy Development.....	57782
SCE-25U-02. Cross-Utility Collaboration on Best Practices for Inclusion of Climate Change Forecasts in Consequence Modeling, Inclusion of Community Vulnerability in Consequence Modeling, and Utility Vegetation Management for Wildfire Safety.....	57782
Grid Design, Operations, and Maintenance.....	57984
SCE-25U-03. Continuation of Grid Hardening Joint Studies.....	57984
SCE-25U-04. Consideration of Prior Actuals in Grid Hardening Targets .....	5846
SCE-25U-05. Transmission Conductor Splice Assessment .....	5838
SCE-25U-06. Transmission High Fire Risk-Informed Inspections .....	58590
Vegetation Management and Inspections .....	5905
SCE-23B-16. Implementation of SCE's Consolidated Inspection Strategy, Use of Its Tree Risk Index, and its Satellite-Based Inspection Pilot .....	5905
SCE-23B-17. Continuation of Effectiveness of Enhanced Clearances Joint Study5938	
Community Outreach and Engagement.....	599604
SCE-23B-21. Community Outreach 3- and 10-Year Objectives – Verification Methods 599604	
Public Safety Power Shutoffs.....	6046
SCE-23B-22. Consideration of PSPS Damage in Consequence Modeling .....	6046
Appendix E: Referenced Regulations, Codes, and Standards.....	6027
Appendix F .....	61823
F1 – Continuation of Section 4.3 Frequently Deenergized Circuits .....	61823
F2 – Continuation of Section 11 .....	63642
Table 11-5: Collaboration in Local and Regional Wildfire Mitigation Planning.....	63642
Figure SCE 11-01c: SCE's PSPS Operational Flow Diagram.....	64652
F3 – ACI SCE-25U-03 Grid Hardening .....	64753

Joint IOU Grid Hardening Working Group Report:.....	64854
F4 – ACI SCE-23B-17 Enhanced Clearances.....	68591
Investor-Owned Utility Effectiveness of Enhanced Clearances .....	68692
List of Tables .....	68793
List of Figures .....	68793
List of Appendices .....	68893
Executive Summary.....	68995
Introduction.....	6906
Data and Methods .....	6917
Comments on the Third-Party Memo Regarding the Effectiveness of Enhanced Clearance.....	70814
Conclusions and Recommendations based on Enhanced Clearance Study .....	7106
Discussion on Combined Mitigations and Implementations .....	7128

---

**Table SCE 5-02a: Circuit Miles Per IWMS Risk Tranche .....****SCE List of Tables**

Table SCE 2-01: Responsible Persons .....	6
Table SCE 3-01: Plan Objectives .....	8
Table SCE 5-01: Risk Quantification Factors .....	41
Table SCE 5-02: Summary of IWMS Risk Categories .....	59
Table SCE 5-02a: Circuit Miles Per IWMS Risk Tranche .....	61
Table SCE 5-03: MARS Conversion Table.....	967
Table SCE 5-04: Risk Models Containing Separate Modules .....	1425
Table SCE 5-05: Version Control .....	1436
Table SCE 6-01: Mitigation Effectiveness .....	16972
Table SCE 6-02: Mitigation Effectiveness Sources.....	1723
Table SCE 6-03: Preferred Mitigation Portfolio per Risk Tranche .....	1769
Table SCE 6-04: Activity Portfolios .....	1781
Table SCE 6-05: Efficacy of Activity Portfolios .....	17982
Table SCE 6-06: Project Timelines for Select Wildfire Mitigations .....	1836
Table SCE 8-01: Equipment Maintenance and Repair Strategy .....	2903
Table SCE 8-02: List of Possible Findings, Priority Level and Timeframe for Remediation .....	2969
Table SCE 8-03: Equipment Maintenance and Repair Failure Rate.....	298301
Table SCE 8-04: Equipment Maintenance and Repair Ignition Rate.....	299302
Table SCE 8-05: Types of Findings Within The Backlog – Distribution .....	3103
Table SCE 8-06: Types of Findings Within The Backlog – Transmission .....	3103
Table SCE 8-07: Ignition Risk Potential - Past Due Asset Notifications Categorized by Age .....	3125
Table SCE 8-08: Ignition Risk Potential - Number of Past Due Asset Notifications Categorized by Age for Priority Levels .....	3125
Table SCE 8-09: Personnel Qualifications and Training for Asset Inspections, Grid Hardening and Risk Event Inspections.....	3269
Table SCE 9-01: Distribution Circuit Mile Inspections in HFRA and State Responsibility Area (SRA) .....	3638
Table SCE 10-01: Summary of WRF Model Physics Configurations.....	4127
Table SCE 11-01: SCE's Emergency Management Phases .....	4327
Table SCE 11-02: PSPS Tracker Survey Key Findings and Mitigation Measures for Customers With AFN .....	4649

**OEIS List of Tables**

Table 3-1: List of Risks and Risk Drivers to Prioritize.....	12
Table 3-2: SCE Self-Identified Performance Metrics.....	19
Table 3-3: SCE Summary of Projected WMP Expenditures .....	22
Table 4-1: SCE High-Level Service Territory Components .....	27
Table 4-2: Catastrophic Wildfires .....	31
Table 4-3: Frequently Deenergized Circuits.....	37
Table 5-1: SCE Risk Modeling Assumptions and Limitations.....	1034
Table 5-2: SCE Summary of Design Basis Scenarios .....	1142
Table 5-3: SCE Summary of Extreme-Event Scenarios.....	1178
Table 5-4: SCE Summary of Risk Models .....	1201
Table 5-5: SCE Summary of Top-Risk Circuits .....	1367
Table 5-6: SCE Risk Assessment Improvement Plan.....	1458
Table 6-1: List of Prioritized Areas in SCE's Service Territory Based on Overall Utility Risk.....	1547

Table 6-2: SCE Stakeholder Roles and Responsibilities in the Decision-Making Process.....	18790
Table 6-3: SCE Risk Impact of Activities .....	1958
Table 6-4: SCE Summary of Risk Reduction for Top-Risk Circuits.....	2044
Table 8-1: SCE Grid Design, Operation, and Maintenance Targets by year .....	2169
Table 8-2: Asset Inspection Frequency, Method, and Criteria .....	2714
Table 8-3: Grid Design, Asset Inspections, and Maintenance QA and QC Program Objectives .....	3044
Table 8-4: Grid Design, Asset Inspections, and Maintenance QA and QC Activity Targets .....	3036
Table 8-5: Number of Past Due Asset Work Orders Categorized by Age .....	3114
Table 8-6: Number of Past Due Asset Work Orders Categorized by Age for Priority Levels .....	3125
Table 8-7: Top Ten Impacted Circuits from Changes to PEDS in the Past Three Years (2022-2024) .....	3169
Table 9-1: SCE Vegetation Management Targets by Year (Non-inspection Targets) .....	3303
Table 9-2: SCE Vegetation Inspections and Pole Clearing Targets by Year .....	3345
Table 9-3: Vegetation Management Inspection Frequency, Method, and Criteria.....	3326
Table 9-4: Partnerships in Vegetation Management.....	3505
Table 9-5: Vegetation Management QA and QC Program Objectives .....	3605
Table 9-6: Vegetation Management QA and QC Program Targets.....	3627
Table 9-7: Number of Past Due Vegetation Management Work Orders Categorized by Age and HFTD Tier .....	3705
Table 9-8: Number of Past Due Vegetation Management Work Orders Categorized by Age and Priority Levels .....	3705
Table 9-9: Vegetation Management Qualifications and Training .....	3727
Table 10-1: Situational Awareness Targets by Year .....	37782
Table 10-2: Environmental Monitoring Systems .....	3805
Table 10-3: Grid Operation Monitoring Systems .....	3894
Table 10-4: Fire Detection Systems Currently Deployed.....	4049
Table 10-5: Fire Potential Features .....	42530
Table 11-1: Emergency Preparedness and Tribal/Stakeholder Outreach Targets by Year .....	42833
Table 11-2: Key Gaps and Limitations in Integrating Wildfire- and PSPS-Specific Strategies into Emergency Plan.....	43843
Table 11-3: High-Level Communication Protocols, Procedures, and Systems With Public Safety Partners.....	4438
Table 11-4: Key Gaps and Limitations in Communication Coordination with Public Safety Partners .....	4449
Table 11-5: Collaboration in Local and Regional Wildfire Mitigation Planning .....	44752
Table 11-6: Key Gaps and Limitations in Collaborating on Local and Regional Wildfire Mitigation Planning .....	44853
Table 11-7: Collaboration with Tribal Agencies .....	4505
Table 11-8: Key Gaps and Limitations in Collaborating with Tribal Agencies .....	4516
Table 11-9: Protocols for Emergency Communication to Stakeholder Groups.....	4549
Table 11-10: List of Target Communities.....	4605
Table 11-11: Key Gaps and Limitations in Public Emergency Communication Strategy.....	46671
Table 12-1: SCE Enterprise Systems Targets .....	4738
Table 13-1: SCE Lessons Learned .....	4816
Table 13-2: SCE Lessons Learned From Discontinued Activities .....	498503

## SCE List of Figures

Figure SCE 3-01: Graph of WMP Expenditures .....	22
Figure SCE 3-02: Illustration of Average Annual Hectares Burned, 2050 .....	24
Figure SCE 4-01: SCE Service Territory and Customer Meter Density Map .....	28
Figure SCE 4-02: SCE Service Territory and Electrical Infrastructure Map .....	29
Figure SCE 4-03: SCE Frequently De-Energized Circuits .....	38
Figure SCE 5-01: Illustrative Risk Bowtie Consistent with CPUC Risk Informed Decision-Making Framework (RDF) .....	46
Figure SCE 5-02: Risk Bowtie Depicting SCE's MARS Framework Consistent with CPUC RDF .....	48
Figure SCE 5-03: SCE'S IWMS Risk Framework .....	49
Figure SCE 5-04: Division of SCE's HFRA into Equally Sized Polygons .....	51
Figure SCE 5-05: Example of Identified Population Egress-Constrained Locations in SCE HFRA .....	52
Figure SCE 5-06: Identify Areas with a High Historical Fire Frequency in SCE HFRA .....	53
Figure SCE 5-07: Example Overlay of High Historical Frequency of Fires with Egress-Constrained Area in SCE HFRA .....	53
Figure SCE 5-08: Steps to Calculate the "Burn in Buffer" .....	54
Figure SCE 5-09: Areas with Significant Wildfire Consequence Potential in SCE HFRA .....	55
Figure SCE 5-10: High Wind Locations in SCE HFRA .....	56
Figure SCE 5-11: Example of a CEFC with Topographical Overview (Left) and Example of Vegetation in Canyon (Right) .....	57
Figure SCE 5-12: Fire Size at 8 Hours Relative to Final Fire Size, 2018-2024 .....	58
Figure SCE 5-13: Map of SCE IWMS Categories in HFRA .....	60
Figure SCE 5-14: Example of 100% Match of Risk Model and SME Review .....	623
Figure SCE 5-15: Photo of Location Confirms SRA Designation .....	623
Figure SCE 5-16: Example of a Deviation Between Risk Model and SME Review .....	634
Figure SCE 5-17: Photo of Location Confirms Need to Convert Designation from SRA to HCA .....	645
Figure SCE 5-18: SCE Fire Behavior Matrix (FBM) .....	689
Figure SCE 5-19: Probability of Ignition Calculation .....	712
Figure SCE 5-20: Schematic for Individual SCE POI Subcomponent Models .....	723
Figure SCE 5-21: Schematic for SCE Probability of Ignition Model .....	734
Figure SCE 5-22: Schematic of POI Subcomponent Model Calculation .....	745
Figure SCE 5-23: Schematic of POI Subcomponent Testing, Training, and Validation .....	745
Figure SCE 5-24: Schematic of POI Validation Confusion Matrix .....	756
Figure SCE 5-25: Schematic of POI ROC Curve .....	767
Figure SCE 5-26: Example of Ignition Points (Black Dots) in Proximity to Utility Assets (Gray Lines) .....	7980
Figure SCE 5-27: Schematic of SCE Wildfire Consequence Modeling (8 Hours, Unsuppressed) .....	801
Figure SCE 5-28: Spatial Extent of SCE FireSight 8 Model .....	823
Figure SCE 5-29: Fire Climate Zones and Ignition Point Locations .....	845
Figure SCE 5-30: Fire Behavior Matrix .....	856
Figure SCE 5-31: Ratio of Fire Weather Days to Total Weather Days for Select Fire Climate Zones .....	867
Figure SCE 5-32: CPUC 2019 PSPS Event – SCE Wildfire Analysis Report .....	889
Figure SCE 5-33: Full Distribution of Natural Unit Consequences (Acres Burned) for a Simulation Truncated Period of 8 Hours .....	890
Figure SCE 5-34: Full Distribution of Natural Unit Consequences (Acres Burned) for a Simulation Truncated Period of 24 Hours .....	890

Figure SCE 5-35: FireSight 8 Fuel Layer Domain (Right) Compared to WRRM 7.6 (Left) .....	942
Figure SCE 5-36: Comparison of Uber H3 Hexagons with Prior Hexagon Lattice .....	923
Figure SCE 5-37: Illustrative Example of WUI Fuel Transformation .....	934
Figure SCE 5-38: (D) Building Loss Factor in SCE's Service Territory .....	945
Figure SCE 5-39: SCE Safety Consequences Calculation .....	945
Figure SCE 5-40: SCE Reliability Consequences Calculation .....	956
Figure SCE 5-41: SCE Financial Consequences Calculation .....	956
Figure SCE 5-42: Illustrative Example of MARS Conversion Steps for Financial Consequences .....	967
Figure SCE 5-43: AFN Multiplier Calculation .....	978
Figure SCE 5-44: NRCI Multiplier Calculation .....	978
Figure SCE 5-45: Wildfire Vulnerability Calculation .....	978
Figure SCE 5-46: PSPS Safety Index Calculation .....	989
Figure SCE 5-47: PSPS Reliability Consequences Calculation .....	989
Figure SCE 5-48: PSPS Financial Consequences Calculation .....	99100
Figure SCE 5-49: Overall Utility Risk Calculation .....	1001
Figure SCE 5-50: Wildfire Risk Calculation .....	1001
Figure SCE 5-51: Outage Program Risk Calculation.....	1001
Figure SCE 5-52: PSPS Risk Calculation .....	1001
Figure SCE 5-53: PEDS Risk Calculation .....	1001
Figure SCE 5-54: Map of Top-Risk Areas within SCE HFRA .....	1342
Figure SCE 5-55: Map of Top-Risk Areas within the SCE HFRA and SCE Proposed Updates to the HFTD.....	1345
Figure SCE 6-01: IWMS Mitigation Selection and Deployment Process .....	1514
Figure SCE 6-02: Wildfire Mitigation Activity Selection Process .....	1614
Figure SCE 6-03: Evaluation of Wildfire and Outage Program Risk (excerpt from full version in Figure SCE 6-02	1625
Figure SCE 6-04: Identifying Mitigations (excerpt from full version in Figure SCE 6-02).....	1647
Figure SCE 6-05: Evaluating Activities (excerpt from full version in Figure SCE 6-02) .....	1669
Figure SCE 6-06: Decision-Making Factors Considered.....	1670
Figure SCE 6-07: Illustrative Example of Risk Profile Changes due to Mitigation "A" Deployment. ....	197200
Figure SCE 6-08: Weighting Factor Calculation for Activity Effectiveness – Overall Risk.....	197200
Figure SCE 6-09: Activity Effectiveness – Overall Risk Calculations .....	198201
Figure SCE 6-10: Weighting factor calculation for Activity Effectiveness – Wildfire Risk, Probability of ignition.....	198201
Figure SCE 6-11: Weighting factor calculation for Activity Effectiveness – Wildfire Risk, Wildfire Consequence.....	198201
Figure SCE 6-12: Activity Effectiveness – Wildfire Risk Calculation .....	198201
Figure SCE 6-13: Weighting factor calculation for Activity Effectiveness – Outage Program Risk, PEDS.....	198201
Figure SCE 6-14: Weighting factor calculation for Activity Effectiveness – Outage Program Risk, PSPS Consequence.....	198201
Figure SCE 6-15: Activity Effectiveness – Outage Program Risk Calculation.....	198201
Figure SCE 6-16: Risk Spend Efficiency – Overall Risk Calculation .....	199202
Figure SCE 6-17: Risk Spend Efficiency – Wildfire Risk Calculation .....	199202
Figure SCE 6-18: Risk Spend Efficiency – Outage Program Risk Calculation.....	199202
Figure SCE 6-19: Percent of HFTD Covered Calculation.....	199202

Figure SCE 6-20: Expected Percent Risk Reduction Calculation .....	199202
Figure SCE 6-21 Risk After Calculation .....	19902
Figure SCE 8-01: Cross Section of Covered Conductor (left) and Composite and Fire-Resistant Wrapped Poles (right) .....	2236
Figure SCE 8-02: Types of Vibration Dampers: Stockbridge Damper (left) and Spiral Damper (right) .....	2269
Figure SCE 8-03: Re-Route Example in Malibu Area .....	22932
Figure SCE 8-04a: Cover Installed Over Cable Tray System from PG&E's GLDS Pilot in Woodside .....	2325
Figure SCE 8-04b: Cross-Section View of AGDB (above) and GLDS (below) .....	2336
Figure SCE 8-05: A Line Spacer Installed on a Long Span to Mitigate Wire-to-Wire Contact (Left), Close Up Line Spacer View (Right) .....	2425
Figure SCE 8-06: Long Span Initiative Remediation Decision Tree .....	2436
Figure SCE 8-07: Image of a Ground Fault Neutralizer .....	2469
Figure SCE 8-08: Isolation (Iso) Bank Transformer (12kV to 12kV) .....	2503
Figure SCE 8-9: Images of Isolation Transformers used for Grounding Conversion .....	2514
Figure SCE 8-10: Sectionalizing Devices Limit De-energization to Smaller Segments .....	2603
Figure SCE 8-11: Remote Grid System Diagram .....	2636
Figure SCE 8-12: Cracked Hendrix Insulator (Drone Capture) .....	2736
Figure SCE 8-13: Drone (left) and SCE Helicopter (right) .....	2736
Figure SCE 8-14: Damaged Pole Carrying 120V .....	2736
Figure SCE 8-15: Rotten / Hollow Guy Stub Pole .....	2747
Figure SCE 8-16: Animal Nest Found on Transmission Switchgear (Drone Capture) .....	2781
Figure SCE 8-17: Distribution Infrared (IR) Inspection of a 12kV Circuit .....	2814
Figure SCE 8-18: Control-Haiwee-Inyokern 115kV line .....	2836
Figure SCE 8-19: SCE Helicopters .....	2847
Figure SCE 9-01: Volume of Open Work Orders .....	36974
Figure SCE 9-02: Volume of Past Due Work Orders .....	3705
Figure SCE 10-01: Live Fuel Moisture Content Calculation .....	3849
Figure SCE 10-01: PSPS LFO & Patrolling Process .....	38691
Figure SCE 10-02: DoprD Alarm Verification Process .....	3938
Figure SCE 10-03.2: The Scheme Measures the Primary Current of a CT by Measuring the Secondary of the CT and Then Multiplying by the CTR .....	3949
Figure SCE 10-03: MADEC Flowchart .....	397402
Figure SCE 10-04: Transformer EDD Flowchart .....	397402
Figure SCE 10-05: Fire Potential Index Equation .....	4249
Figure SCE 11-01a: SCE's Emerging Situation Process .....	4338
Figure SCE 11-01b: SCE's Wildfire Operational Flow Diagram .....	4338
Figure SCE 11-01c: SCE's PSPS Operational Flow Diagram .....	4349
Figure SCE-RN-SCE-26-09: SCE Vegetation Management Remote Sensing Journey .....	340

## OEIS List of Figures

Figure 5-1: SCE Composition of Overall Utility Risk Using OEIS Prescribed Risk Comps .....	45
Figure 5-2: Example of a Calculation Schematic .....	701
Figure 6-1: SCE Projected Overall HFRA Risk .....	1925
Figure 8-1a: Distribution Detailed Inspections and Remediations Workflow .....	2758
Figure 8-2: Transmission Detailed Inspections Workflow .....	27982
Figure 8-3: Distribution Infrared Inspections Workflow .....	2814
Figure 8-4: Transmission Infrared And Corona Scan Inspections Workflow .....	2847
Figure 8-5: Generation Inspections Workflow .....	2869

Table 4-2: Catastrophic Wildfires

Ignition Date <sup>17</sup>	Fire Name	Official Cause <sup>18</sup>	Fire Size (acres)	No. of Fatalities	No. of Structures Destroyed and Damaged	Financial Loss (US\$) <sup>19</sup>	Lesson(s) Learned
10/20/2007	RANCH	USFS opined that the fire was caused by SCE equipment	>58,000	0	9 Structures Damaged or Destroyed	Data not available	See Section 4.2 narrative
11/14/2008	SAYRE	USFS opined that the fire was caused by SCE equipment	11,262	0	604 Structures Destroyed / 147 Structures Damaged	Data not available	See Section 4.2 narrative
2/6/2015	ROUND	CAL FIRE opined that the fire was caused by SCE equipment	7,000	0	43 Structures Destroyed / 5 Structures Damaged	Data not available	See Section 4.2 narrative
8/18/2016	REY	USFS opined that the fire was caused by SCE equipment	32,606	0	5 Structures Destroyed	Data not available	See Section 4.2 narrative
12/4/2017	THOMAS/ KOENIGSTEIN	CAL FIRE & VCFD opined that the fires were caused by SCE equipment	281,893	2	1,060 Structures Destroyed / 274 Structures Damaged	Data not available	See Section 4.2 narrative

17 Wildfire history data is derived from various sources including SCE incident reports and related communications, CAL FIRE (<https://www.fire.ca.gov/stats-events/>), and U.S Forest Service (<https://nap.nwrg.gov/NAP/>).

18 Wildfire history data is derived from various sources including SCE incident reports and related communications, CAL FIRE (<https://www.fire.ca.gov/stats-events/>), and U.S Forest Service (<https://nap.nwrg.gov/NAP/>).

19 In some instances, an agency may provide data related to one component of financial loss such as costs associated with suppression efforts; however, SCE is not aware of an authoritative government source that provides all-inclusive data regarding financial loss.

<b>Ignition Date<sup>17</sup></b>	<b>Fire Name</b>	<b>Official Cause<sup>18</sup></b>	<b>Fire Size (acres)</b>	<b>No. of Fatalities</b>	<b>No. of Structures Destroyed and Damaged</b>	<b>Financial Loss (US\$)<sup>19</sup></b>	<b>Lesson(s) Learned</b>
12/5/2017	CREEK	USFS opined that fire was caused by LADWP equipment	15,619	0	123 Structures Destroyed / 81 Structures Damaged	Data not available	See Section <a href="#">4.2</a> narrative
12/5/2017	RYE	CAL FIRE opined that the fire was caused by SCE equipment	6,049	0	6 Structures Destroyed / 3 Structures Damaged	Data not available	See Section <a href="#">4.2</a> narrative
11/8/2018	WOOLSEY	CAL FIRE opined that the fire was caused by SCE equipment and an unidentified communication line	96,949	3	1,643 Structures Destroyed / 364 Structures Damaged	Data not available	See Section <a href="#">4.2</a> narrative
10/10/2019	SADDLE RIDGE	Los Angeles City Fire Dept opined that the cause of the fire is undetermined	8,799	1	24 Structures Destroyed / 91 Structures Damaged	Data not available	See Section <a href="#">4.2</a> narrative
9/6/2020	BOBCAT	USFS opined that the fire was caused by SCE equipment	115,997	0	169 Structures Destroyed / 47 Structures Damaged	Data not available	See Section <a href="#">4.2</a> narrative
10/26/2020	SILVERADO	CAL FIRE and OCFA opined that the fire was caused by SCE and T-Mobile equipment	12,466	0	5 Structures Destroyed / 11 Structures Damaged	Data not available	See Section <a href="#">4.2</a> narrative

Ignition Date <sup>17</sup>	Fire Name	Official Cause <sup>18</sup>	Fire Size (acres)	No. of Fatalities	No. of Structures Destroyed and Damaged	Financial Loss (US\$) <sup>19</sup>	Lesson(s) Learned
9/5/2022	FAIRVIEW	CAL FIRE opined that the fire was caused by SCE equipment	28,307	2	36 Structures Destroyed / 8 Structures Damaged	Data not available	See Section <a href="#">4.2</a> narrative
1/7/2025	EATON	No official cause. Under investigation	14,021	17	9,413 Structures Destroyed / 1,074 Structures Damaged	Data not available	See Section <a href="#">4.2</a> narrative

SCE uses the GRCD to determine clearances from distribution lines which are based on standards set forth in GO 95 Rule 35 (Case 13 and Case 14), GO 95 Rule 37, PRC 4293, PRC 4292 Title 14 CCR Sections 1250-1258, and SCE's internal procedures UVM-03 and UVM-09. SCE strives to obtain expanded clearances of 12 feet or greater for distribution lines in HFRA. At a minimum, SCE's Inspections for Vegetation Clearances from Distribution Lines maintains at least the required four feet clearance for distribution lines within HFRA. Vegetation Inspections assess whether the vegetation meets these clearance requirements and prescribe corrective actions if necessary.

Certain tree species, due to their characteristics, have the potential to cause "grow-in" or "blow-in" incidents that could lead to an outage or an ignition. SCE manages high-risk species of vegetation and implements clearances, where possible, to reduce the probability of vegetation contacting electric facilities by providing species-specific categorization to its workforce to make appropriate work prescriptions.

Fast-growing species are typically pruned to maintain compliance for annual cycles. If the tree is not expected to maintain the compliance clearance distance (which is SCE's internal clearance target), for one year, a removal is typically pursued.

As an example, palms drive a significant number of off-cycle trims and emergency work required to prevent circuit interruptions and other safety risks. While the overall inventory of palms is low, historically palms have accounted for a significant portion of the Tree Caused Circuit Interruptions (TCCIs). To further mitigate public and worker safety risks associated with trimming palm trees, palms near lines are typically targeted for removal. Similarly, bamboo is one of the fastest growing plant species and SCE's preferred method is to remove it when possible.

### 9.2.1.4 Fall-in Mitigation

*In this section, the electrical corporation must describe how it identifies fall-in risks, such as hazard trees, during the inspection (e.g., Level 1, Level 2, etc.). As applicable, the electrical corporation must describe how it differently prescribes removal of high-risk species of vegetation.*

Fall-in mitigation is primarily addressed through SCE's Hazard Tree and Dead and Dying Tree Programs. Please refer to Sections [9.2.3.4](#) and [9.2.4.4](#).

### 9.2.1.5 Scheduling

*In this section, the electrical corporation must describe how the inspection activity (program) is scheduled. This must include the frequency (e.g., annual, quarterly, three-year cycle) and/or triggers (e.g., severe weather events, risk model outputs) of the inspection activity (program). It must also identify how the frequency and/or trigger might differ by HFTD tier or other risk designation.*

*If the inspection activity (program) is based on a fixed frequency (e.g., annual, three-year cycle), the electrical corporation must explain how it uses risk prioritization in the scheduling of the inspection activity (program) to target high-risk areas. If the electrical corporation does not use risk prioritization in the scheduling of the inspection activity (program), it must explain why.*

Inspections for vegetation clearances from distribution lines are scheduled and conducted on an annual basis. The timing and scheduling of inspections may be adjusted in Areas of Concern (AOC) based on weather data, risk models, and environmental conditions. AOC are areas that pose increased fuel-driven and wind-driven fire risk. AOCs are identified based on several factors, including fire history, current and near-term fuel and weather conditions, vegetation type and amount, and impact to communities and SCE infrastructure. To mitigate the potential risk in AOC, SCE may adjust its vegetation inspection schedules to address risk in AOC.<sup>155</sup>

SCE targets annual vegetation inspections for all HFRA distribution circuit miles. Completion of this scope may be constrained by environmental conditions (e.g., snow, high winds, sensitive environmental regions) and risk prioritization efforts (such as emergent inspections), which may influence inspection timing and scheduling but does not typically prevent inspections from occurring. While the timing of inspection work may not always adhere to the original planned schedule, it is ultimately completed. In accordance with SCE's internal guidelines, VM schedulers monitor delays and follow up as necessary to verify that inspections are completed. In addition, circuit mileage totals are dynamic and may shift due to HFRA boundary changes, GIS and data refinements, and asset-related adjustments such as conductor span length variations due to asset removal or installation.

### 9.2.1.6 Updates

*In this section, the electrical corporation must discuss changes/updates to the inspection activity (program) since its last WMP submission, including known future plans (beyond the current year) and new/novel strategies the electrical corporation may implement in the next five years (e.g., references to and strategies from pilot projects and research). The electrical corporation must include lessons learned as applicable.*

In 2024, SCE continued its implementation of a consolidated inspection strategy to improve contractor management, optimize work scheduling, support the transition from grid-based to circuit-based inspections, and enable increased use of remote sensing. This involves requiring Pre-Inspection contractors to perform inspection across all three vegetation management programs: Routine Line Clearing,<sup>156</sup> Hazard Tree Management Program, and Dead and Dying Tree Removal. As part of the consolidated inspection strategy, SCE started the transition from a grid-based inspection strategy (Vegetation Management grids are SCE-defined geographic boundaries that define a work area) to a more linear circuit-based inspection strategy. Shifting to a circuit-based inspection approach allows for alignment with other company initiatives, such as remote sensing to enable near real-time data capture.

In this 2026-2028 WMP, SCE is combining two prior WMP activities – expanded clearances for distribution lines (VM-7) and remote sensing distribution inspections (VM-9) – into a single WMP activity called “Inspections for Vegetation Clearance from Distribution Lines” (new VM-7). It is beneficial to combine the remote sensing and ground inspections because SCE plans to augment VM-7 by increasing the use of remote sensing technologies in its inspections. This shift will facilitate the transition from ground-based inspections to more remote sensing methodologies, thus providing valuable data for predictive models.

In 2025 and beyond, SCE plans to introduce the use of CanopySense, a suite of technology tools to aid in performing vegetation management inspection activities around distribution and transmission assets. CanopySense is a cloud-based platform that utilizes LiDAR or imagery (e.g., satellite, orthoimagery) to determine vegetation encroachment to SCE's circuit lines.

SCE's CanopySense project has completed two proofs of concept, Crown Segmentation

156 AOCs do not provide a comprehensive list of every area that could potentially have a major wildfire as this is not conceivable. AOCs concentrate on the more obvious locations where major wildfires could occur.

155 SCE refers to the inspections for vegetation clearances from distribution lines (VM-7) and transmission lines (VM-8) as Routine Line Clearing (RLC). Both programs are collectively termed Routine Line Clearing.

#### 9.2.2.4 Fall-in Mitigation

*In this section, the electrical corporation must describe how it identifies fall-in risks, such as hazard trees, during the inspection (e.g., Level 1, Level 2, etc.). As applicable, the electrical corporation must describe how it differently prescribes removal of high-risk species of vegetation.*

Fall-in mitigation is primarily addressed through SCE's Hazard Tree and Dead and Dying Tree Programs. Please refer to sections [9.2.3.4](#) and [9.2.4.4](#).

#### 9.2.2.5 Scheduling

*In this section, the electrical corporation must describe how the inspection activity (program) is scheduled. This must include the frequency (e.g., annual, quarterly, three-year cycle) and/or triggers (e.g., severe weather events, risk model outputs) of the inspection activity (program). It must also identify how the frequency and/or trigger might differ by HFTD tier or other risk designation.*

*If the inspection activity (program) is based on a fixed frequency (e.g., annual, three-year cycle), the electrical corporation must explain how it uses risk prioritization in the scheduling of the inspection activity (program) to target high-risk areas. If the electrical corporation does not use risk prioritization in the scheduling of the inspection activity (program), it must explain why.*

SCE uses the same procedures for scheduling inspections for vegetation clearances from transmission lines<sup>157</sup> and distribution lines. See section [9.2.1.5](#) for details.

SCE targets annual vegetation inspections for all transmission HFRA circuit miles. Completion of this scope may be constrained by environmental **conditions** (e.g., snow, high winds, sensitive environmental regions) and risk prioritization efforts (such as emergent inspections), which may influence inspection timing and scheduling but does not typically prevent inspections from occurring. While the timing of inspection work may not always adhere to the original planned schedule, it is ultimately completed. In accordance with SCE's internal guidelines, VM schedulers monitor delays and follow up as necessary to verify that inspections are completed. In addition, circuit mileage totals are dynamic and may shift due to HFRA boundary changes, GIS and data refinements, and asset-related adjustments such as conductor span length variations due to asset removal or installation.

#### 9.2.2.6 Updates

*In this section, the electrical corporation must discuss changes/updates to the inspection activity (program) since its last WMP submission, including known future plans (beyond the current year) and new/novel strategies the electrical corporation may implement in the next five years (e.g., references to and strategies from pilot projects and research). The electrical corporation must include lessons learned as applicable.*

In this 2026-2028 WMP, SCE is combining two prior WMP activities – expanded clearances for transmission lines (VM-8) and remote sensing transmission inspections (VM-10) – into a single WMP activity called “Inspections for Vegetation Clearance from Transmission Lines” (new VM-8). It is beneficial to combine the remote sensing and ground inspections because SCE plans to augment VM-8 by increasing the use of remote sensing technologies in its inspections.

As mentioned above in [9.2.1.6](#), in 2025 and beyond, SCE plans to introduce use of CanopySense for vegetation management inspection activities around transmission lines.

Figure SCE 9-02: Volume of Past Due Work Orders<sup>170</sup>



Table 9-7: Number of Past Due Vegetation Management Work Orders Categorized by Age and HFTD Tier<sup>171</sup>

HFTD Area	0-30 Days	31-90 Days	91-180 Days	181+ Days	Total
Non-HFTD	6,029 5,103	118 100	58 55	25 22	6,230 5,280
HFTD Tier 2	5,414 4,654	59 56	133	102	5,708 4,945
HFTD Tier 3	4,636 3,753	41	85 83	35 34	4,797 3,911
Total	16,079 13,510	218 197	276 271	162 158	16,735 14,136

Table 9-8: Number of Past Due Vegetation Management Work Orders Categorized by Age and Priority Levels Timeline Category<sup>172,173</sup>

Priority Level	0-30 Days	31-90 Days	91-180 Days	181+ Days	Total
Priority 1 (24 hours)	0	0	0	0	0
Priority 1 (72 hours)	0	0	0	0	0
Priority 2 - Less than RCD (<30 days)	1,727	55	22	2	1,806
Priority 2 - Between RCD and TCD (<90 days)	11,751	117	108	67	12,045
Priority 2 - Hazard Tree Management and Dead and Dying Tree (<180 days)	30	25	141	89	285
Strain or Abrasion on Secondary Lines <sup>174</sup>	N/A	N/A	N/A	N/A	N/A

170 As of 3/7/2025.

171 As of 3/7/2025. Excludes work points with clearance equal to or greater than GRCD.

172 The electrical corporation must use the priority levels it defines in section 9.12.1

173 As of 3/7/25. As explained in SCE's response to Data Request Set OEIS-P-WMP\_2025-SCE-018, Question 1, SCE clarifies this data excludes work points with clearance equal to or greater than GRCD.

174 Strain or Abrasion on Secondary Lines is not a formal category SCE tracks as part of its vegetation management inspections.

### 13.3 Discontinued Activities

*The electrical corporation must provide all activities from previous WMP submissions that it is no longer implementing (“Discontinued Activities”),<sup>212</sup> the rationale for discontinuation, the applicable lessons learned, and a list of the new or existing activities that mitigate risk in place of the discontinued activity (“Replacement Activities”), including cross-references to the page numbers within the WMP where each replacement activity is discussed.*

*Table 13-2 provides the required format for this information.*

SCE plans to replace transmission splice inspections with X-Ray (IN-9.b) with proactive splice shunting (SH-20) for the 2026 Base WMP. Many activities included in the 2023 Base WMP have been completed and reached a steady state, such as software development and implementation, system hardening, or planned remediations.

Activities in the 2023 Base WMP concluding prior to 2026 include:

- DG-1 WiSDM / Ezy Data
- IN-9.a Transmission Spans with LineVue
- SA-1 Weather Station Installs
- ~~SA-10 HD Cameras~~
- SA-8 Fire Spread Modeling
- ~~SH-10 Tree Attachment Remediation~~
- SH-15 Vertical Switches
- SH-4 Branch Line
- SH-6 Circuit Breaker Relay Hardware for Fast Curve
- SH-8 Transmission Open Phase Detection
- VM-10 LiDAR Vegetation Inspections – Transmission
- VM-3 Expanded Clearances for Generation Legacy Facilities
  - VM-9 LiDAR Vegetation Inspections – Distribution

Discontinued activities are summarized in Table 13-2.

---

<sup>212</sup> Discontinued activities do not include activities that the electrical corporation has completed. An activity that has been completed is not a discontinued activity.