

Southern California Edison
R.18-10-007 – SB 901

DATA REQUEST SET C A L P A - S C E - 0 0 2

To: CalPA
Prepared by: Cameron McPherson
Job Title: Sr. Project Mgr.
Received Date: 2/15/2019

Response Date: 2/22/2019

Question 2: Question 2

How do SCE's procedures differ in situations where there is a high rating on the Fire Potential Index, but a red flag warning is not issued, compared to Red Flag Warning procedures?

Response to Question 2:

During situations where there is an elevated Fire Potential Index without the issuance of a Red Flag Warning (RFW) by the National Weather Service, SCE's procedures provide discretion to implement the Operating Restrictions described in SCE's System Operating Bulletin (SOB) 322 for overhead subtransmission and distribution lines or line sections. Operating Restrictions guide the operational status of reclosers (e.g. recloser blocking and fast-curve settings enablement) and testing/patrolling of subtransmission and distribution lines/line sections that traverse high fire areas following a relay operation. When a RFW is issued by the National Weather Service, the aforementioned Operating Restrictions are put into place and the additional RFW procedures noted on page 35 of the WMP will also be implemented.

