

Southern California Edison
R.18-10-007 – SB 901

DATA REQUEST SET M G R A - S C E - 0 0 1

To: MGRA
Prepared by: Peter Lee
Job Title: Senior Business Analyst
Received Date: 3/3/2019

Response Date: 3/6/2019

Question 13: What tree species are regarded to be “at risk” or “reliability” trees in the utility service area? If this is a long list, restrict to the top ten most likely to be associated with outages.

Response to Question 13:

“At risk” or “reliability” trees are based on the tree’s hazard characteristics rather than simply a tree species.

The following tree species have been linked to the largest number of outages associated with SCE utility equipment over the past 3 years:

1. Palm Tree
2. Eucalyptus
3. Pine
4. Oak
5. Cedar
6. Ash
7. Sycamore
8. Elm
9. Cypress
10. Ficus