



Laura Genao
Managing Director
State Regulatory Affairs
Laura.Genao@sce.com

August 17, 2020

Leslie Palmer, Director
Safety Enforcement Division
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102

SUBJECT: SCE PSPS Post Event Report-July 31 to August 4, 2020

Dear Director Palmer,

Southern California Edison (SCE) respectfully submits the attached report in compliance with PSPS Post Event Reporting requirements regarding its Public Safety Power Shutoff (PSPS) event that began July 31, 2020. This report has been verified by an Officer of SCE in accordance with Rule 1.11 of the Commission's Rules of Practice and Procedure.

Sincerely,

/s/ Laura Genao

Laura Genao,
Managing Director, Regulatory Affairs

cc: ESRB_ComplianceFilings@cpuc.ca.gov

**Southern California Edison
Public Safety Power Shutoff Protocol (PSPS)
Post-Event Reporting in Compliance with Resolution
ESRB-8 and PSPS OIR Phase 1 & 2 Requirements
July 31 to August 4, 2020**

**Submitted to:
California Public Utilities Commission
Director of the Safety and Enforcement Division
August 18, 2020**

Executive Summary

On July 31, 2020, Southern California Edison (SCE) remotely activated¹ an Incident Management Team (IMT) to manage a weather event where forecasted high wind and low relative humidity levels were anticipated to require the use of SCE's Public Safety Power Shutoff (PSPS) protocol, potentially impacting up to approximately 500 customers. The Tejon circuit was in scope with a period of concern from August 2nd to August 3rd. The Toll circuit was in scope with a period of concern from August 4th to August 6th but was removed from PSPS consideration on August 3rd due to improving weather conditions and no customers were de-energized on this circuit. Ultimately, SCE pro-actively de-energized seventeen customer meters on the Tejon circuit in Antelope Valley at 2:15 pm on August 2. Power was restored to 14 of the customer meters on Monday, August 3 at approximately 5:17 pm and the remaining 3 customer meters (which all served one large customer) on Tuesday, August 4 at approximately 10:30 am.

This report is submitted to demonstrate SCE's compliance with the directives of Resolution ESRB-8 and the California Public Utilities Commission (CPUC or Commission) Order to Institute Rulemaking (OIR) Phase 1 (D. 19-05-042) and Phase 2 (D.20-05-051) requirements associated with PSPS events. Specifically, this report explains SCE's decision to call, sustain, and curtail a de-energization event and provides an event summary and responses to post-event reporting questions as required by the Commission.

SCE appreciates that PSPS de-energizations pose significant challenges and hardships for its customers and the Public Safety Partners that provide vital services to our communities. SCE's decision to activate an IMT for potential use of the PSPS protocol is based on careful consideration of multiple factors including impacts to Public Safety Partners and the communities we serve. The advance notifications of a potential PSPS event are intended to serve as an alert to our Public Safety Partners and customers of the potential need to de-energize a part of our system to protect public safety from the risk of a wildfire. As such, a notification of a potential de-energization is not a guarantee that an actual de-energization will take place. Rather, it is a warning that a de-energization event could take place so that customers and Public Safety Partners have the information they need to be prepared and respond to the events as they develop on the ground. To that end, SCE also provides notices of an actual de-energization when the decision to de-energize the system has become necessary and definitive. Because SCE takes seriously its responsibilities to its customers, stakeholders, and Public Safety Partners and understands the impacts of de-energization events, SCE only resorts to PSPS de-energization after consultation with Public Safety Partners and when SCE believes that there are no other reasonable alternatives to mitigate identified risks to public safety.

SCE remains committed to continuously improving its processes and welcomes input from its customers, Public Safety Partners, community representatives, and local governments

¹ SCE utilized remote IMT activation due to the impacts of COVID-19

on ways we can work together to enhance existing processes, improve communication and coordination amongst impacted entities, and minimize the impact of PSPS events on external stakeholders.

SCE took the following actions to manage its response during the PSPS event:

1. Activated a Dedicated PSPS IMT to coordinate response operations associated with the potential use of PSPS to maintain public safety. The IMT was activated and operated remotely due to the COVID-19 pandemic.
2. Notified Public Safety Partners, critical infrastructure providers, the CPUC, the California Department of Forestry and Fire Protection (CalFire), the California Governor's Office of Emergency Services (CalOES), and affected SCE customers.
3. Initiated operating restrictions on impacted circuits in affected counties.
4. Performed field patrols of impacted circuits in preparation for the potential use of PSPS.
5. Deployed a Community Crew Vehicle (CCV) to the impacted community in Antelope Valley in consultation with the Kern County Office of Emergency Management.
6. Performed live field observations of monitored circuits as required during the period of concern to validate need for the use of PSPS for actual de-energization.

Event Summary July 31 to August 4, 2020²

On Friday, July 31, Weather Services first notified SCE's Business Resiliency Duty Manager (BRDM) of a weather system that was forecasted to ultimately bring gusty winds, hot temperatures and dry conditions to portions of Los Angeles, Kern and Riverside counties, resulting in an elevated fire weather threat in these areas. Specifically, with respect to the Tejon circuit the period of concern was forecasted to begin on Sunday, August 2nd. Assessments of fuel conditions in sections suggested that the surrounding vegetation was at near record dry levels for this time of year, and thus supportive of significant fire activity. There was a total of two circuits forecasted to breach PSPS criteria over the four-day activation.

On Friday, July 31, SCE activated its Dedicated Incident Management Team and initiated two-day alert and warning notifications to first responder agencies, public safety partners, local government, and customers on the Tejon circuit. SCE provided daily alert and warning update notifications to maintain situational awareness and to provide updated information regarding the ongoing potential PSPS event. SCE also provided e-mail notification to the Independent Living Center of Kern County, Community Action Partnership of Kern County (211 Kern), the Information and Referral Federation of LA County (211 LA County), American Red Cross Central, and the Mt. Pinos and Kern River Valley Fire Safe Councils.

On the morning of Sunday, August 2nd, the Toll Circuit in Riverside County was first forecasted to reach PSPS criteria with a period of concern starting on Tuesday, August 4th. SCE initiated two-day

² The following event summary serves to provide an overview of the event. Additional details regarding specific PSPS requirements are addressed in further detail after this narrative

alert and warning notifications for this circuit on Sunday morning; however, this circuit was subsequently removed from the monitored circuit list on Monday, August 3rd, due to improving weather conditions and all clear notifications were sent that day.

On Sunday August 2nd, at approximately 1:30 pm and ahead of the originally forecasted period of concern, SCE began observing actual wind speeds on the Tejon circuit approaching wind speed values that would warrant de-energization for a portion of the circuit. Due to these factors, the conditions noted above, and the potential for catastrophic fire ignition, the IC determined, after thorough consideration of the use of sectionalization, that a pro-active de-energization was likely on a small portion of the Tejon circuit located in a CPUC-designated Tier II HFRA area to maintain public safety and to avoid the risk of an ignition that could lead to a significant fire. As such, notices of a possible imminent (1-4 hours) de-energization³ were sent to 17 customers at approximately 1:48 pm. At approximately 2:15pm, SCE de-energized this portion of the Tejon Circuit impacting 17 customers. The PSPS notification team provided all required notifications to the CPUC, county and state emergency management agencies, Public Safety Partners and customers when de-energization occurred. At 11:01PM and 12:44AM, respectively, SCE began observing actual wind speed values that would warrant de-energization near other portions of the Tejon circuit, and SCE sent notifications of a possible imminent (1-4 hours) de-energization to 102 (11:01PM) and 154 (12:44AM) additional customers. Ultimately, conditions in the field improved and no additional customers, beyond the 17 noted above, were de-energized.

On Monday, August 3, increased fire danger conditions were forecast to subside between the hours of 9AM and 3PM. SCE's Incident Commander provided direction to begin restoration patrols to attempt to re-energize the 17 customer meters prior to the start of the next period of concern. SCE sent notifications to these 17 customers at 9:15 am, stating that it would begin the power restoration process. At approximately 12:40 pm, the Incident Commander made the determination to delay re-energization patrols and the restoration of power because wind speeds began to increase prior to the next forecasted period of concern. Additionally, the IMT was informed that SCE crews identified and made repairs to damage to a pole tap, and that this damage was likely wind-related and likely occurred at some point during the prior period of concern, confirming wind speeds previously reached concerning levels. At approximately 5:16 pm, 14 of the 17 customer meters on the Tejon circuit were re-energized based on meteorologist confirmation of improved observed and forecast weather conditions. SCE crews continued restoration patrols to re-energize the remaining customer (representing three meters); however, conditions in this area of the circuit persisted and the Incident Commander extended the period of concern until 12 am on Tuesday, August 4 given the volatility of the shifting winds. The remaining business customer with three meters remained de-energized.

SCE postponed re-energization patrols for the portion of the circuit feeding the remaining de-energized customer until daylight hours on the morning of Tuesday, August 4, due to difficulty in safely accessing the area and viewing the circuit during the overnight hours. At approximately 8:49AM, restoration patrols were initiated and an imminent re-energization

³ Messaging text can be found in Attachment C-Customer Messaging

notification was sent to the one customer who had remained de-energized. At approximately 10:30 am, this customer was re-energized. Messaging concluding the event was sent to all customers at 11:26 am.

SCE conducted daily county coordination calls with Kern and Los Angeles County representatives and daily Statewide Executive Briefing calls with CalOES, the CPUC and CalFIRE to advise of the ongoing PSPS activities and to solicit input regarding potential public safety concerns from impacted stakeholders. Riverside County was invited to the county coordination call on Sunday, August 2nd when the Toll circuit was on the monitored circuit list. On these calls, SCE consulted with county emergency management officials to determine the appropriate customer care mitigations and dispatched a Community Crew Vehicle to the impacted area to provide customers with grid resiliency kits that include a small-solar device charger, PSPS information, personal protection equipment, water, snacks, ice vouchers, etc. SCE communicated this information with its customers on sce.com and via geo-targeted messaging on Facebook and Twitter using multiple languages. SCE also ensured all customer-facing representatives had the most up-to-date information on customer care mitigations to share with customers. There were two media inquiries during this event, one from the Los Angeles Times and one from Desert Sun.

SCE provided customers and the public with information on the potential PSPS event via regular updates on sce.com (specifically, <https://www.sce.com/safety/wildfire/psps>). This site provides detailed information on SCE's PSPS program and features an interactive map with near real-time status for potentially impacted circuits, period of concern, estimated restoration time and status of customer care mitigations. The SCE website was active throughout the event and was able to support all traffic seeking to access the site. This information is translated in Spanish, Chinese, Korean, Vietnamese and Tagalog.

The following responses address how SCE complied with all applicable PSPS regulatory requirements, including ESRB-8 and the Phase 1 (D. 19-05-042) and Phase 2 (D. 20-05-051) decisions, during this event.

1. The time, place and duration of the power shutoff event

This event started on Friday, July 31st, and continued through Tuesday, August 4th, and impacted portions of Los Angeles, Kern and Riverside counties. The Toll circuit in Riverside county was not de-energized this event.

2. The local communities’ representatives contacted prior to de-energization, the date on which they were contacted, and whether the areas affected by the de-energization are classified as Zone 1, Tier 2, or Tier 3 as per the definition in General Order 95, Rule 21.2⁴

County	Public Safety Partner	Date	Tier
Los Angeles	County and state public safety and first responder agencies and local governments	7/31/2020	Tier II
Kern	County and state public safety and first responder agencies and local governments	7/31/2020	Tier II
Riverside	County and state public safety and first responder agencies and local governments	8/2/2020	Tier II

3. If unable to provide customers with notice at least 2 hours prior to the de-energization event, provide an explanation in its report.

SCE provided all potentially affected customers with notice at least 2 hours prior to the de-energization event as detailed in Attachment B-Customer and Critical Infrastructure Notifications.

4. Summarize the number and nature of complaints received as the result of the de-energization event and include claims that are filed due to de-energization.

As of the submission of this report, no formal complaints were filed with the Commission or SCE Consumer Affairs and no claims have been submitted for this event. Any complaints/claims received after submission of this report will be added to subsequent reports, as they are received and processed.

⁴See Attachment A Public Safety Partner Notifications

With respect to our prior PSPS event, SCE notes that the CPUC received a letter from AT&T regarding the June 28, 2020 SCE PSPS Event,⁵ which detailed AT&T’s concerns with SCE’s notification timelines. The letter indicated that SCE delayed notification, did not provide GIS shape files of the areas affected and did not update its website with information relevant to this event. After receiving the letter, SCE immediately contacted AT&T to discuss its concerns and to explain the sudden onset of increased fire danger conditions that resulted in the abrupt activation and notification. SCE will continue to work closely with AT&T and other critical infrastructure providers to coordinate response to PSPS events and other emergencies.

5. The timeline for power restoration (re-energization), in addition to the steps taken to restore power as required in Resolution ESRB-8.

A PSPS event will last as long as dangerous fire weather conditions exist. If circuits are shut off, those circuits and lines will be inspected to ensure is no damage before power can be safely restored. SCE crews will need to visually inspect the power lines during daylight hours so operations may be limited during overnight hours.

SCE performed post patrols for damage on the Tejon circuit associated with the wind event. Damage was repaired, notification of re-energization was sent to customers, and the circuit was re-energized. Specific details regarding the restoration timeline for this event can be found in the Event Summary above.

The Toll circuit was not de-energized during this event.

6. For any circuits that require more than 24 hours to restore, the utility shall explain why it was unable to restore each circuit within this timeframe in its post event report.

Except for one business customer with three meters, who was subject to an outage for 44 hours, all remaining 14 customers on the Tejon circuit were re-energized within 27 hours. Please see the Event Summary above for a detailed description of why SCE was unable to restore these customers within 24 hours.

7. Identify the address of each community assistance location during the de-energization event, describe the location (in a building, a trailer, etc.), and describe the assistance available at each location, and give the days and hours that it was open.

Type	County	City	Day and Time	Address	Services Provided
CCV - Vehicle	Kern	Lake Hughes	8/2 5pm to 8:30pm 8/3 3pm to 9pm	17520 Elizabeth Lake Rd. Lake Hughes, CA 93532	Grid Resiliency Kits – with Small-solar device charger, PSPS information, personal protection equipment, water, snacks, ice vouchers, etc.

⁵ AT&T’s Response to SCE’s Post-Event Report on the June 25-28 PSPS Event dated July 13, 2020

8. Any wind-related damage(s) to SCE's overhead equipment in the areas where circuits were power is shutoff.

During restoration patrols for wind related damage on the Tejon circuit, a broken tap at the insulator was found on Pole# 4118259E.

9. All factors considered by SCE in its decision to shut off power, including wind speed, temperature, humidity, and vegetation moisture in the vicinity of the de-energized circuits

SCE decision to shut off power is dynamic and made by considering such factors as:

- National Weather Service-issued watches and warnings for high fire risk areas in our territory.
- Ongoing assessments from our in-house meteorologists using high-resolution weather models, data from SCE weather stations and publicly available weather stations.
- The SCE Fire Potential Index (FPI), a tool that utilizes weather data, fuel conditions, and vegetation moisture content to rate the daily fire potential across our region.
- Wind speeds, particularly when they exceed or are expected to exceed National Weather Service Wind Advisory levels (defined as 31 mph sustained wind speed and 46 mph gust wind speed) or exceed the top 1% of historical wind speeds in the area. Wind speeds are particularly important when we consider them in combination with other local conditions, such as dry vegetation, that could present a true hazard for the community. Wind speed thresholds may also be adjusted based on other factors or circuit design.
- Specific concerns received from state and local fire authorities, emergency management personnel and/or law enforcement regarding public safety issues.
- The expected impact of turning off power to essential services such as public safety agencies, water pumps and/or traffic controls.
- Other operational considerations, such as the state of the potentially impacted circuits, flying debris and/or downed wires.
- When possible and safe during extreme fire weather conditions, we can deploy on-the-ground observers in high fire risk areas to monitor live conditions in real time.

Prior to de-energization of the Tejon circuit, SCE Little Oak Canyon was reporting wind speeds at or above 33 mph sustained and 44 mph gust for several observations. Temperature was reported at 87 degrees Fahrenheit and relative humidity was reporting in at 12%. Fire Potential Index values were forecasted at 12.91 during the period of concern.

10. Evaluation of alternatives to de-energization that were considered and mitigation measures used to decrease the risk of utility-caused wildfire in the de-energized area and an explanation of how the utility determined that the benefit of de-energization outweighed the potential public safety risks:

Prior to de-energizing the Tejon circuit, SCE implemented executed operational procedures to minimize or eliminate the potential for a spark to occur. Specifically, SCE implemented fast curve settings protective relays, which are designed to limit the fault energy and more quickly de-energize the line should a fault occur. SCE also implemented operating restrictions and blocked

reclosers on these lines so that if the circuit relayed, it could not automatically reclose. In this situation, the line would have to be patrolled and the potential safety hazard removed before the circuit can be re-energized. However, as the observed weather conditions worsened, these measures were not deemed sufficient to guard against a potential wildfire ignition.

SCE used sectionalizing through an RAR device to separate and isolate the de-energization area, limiting the de-energization to 17 customer meters (as compared to 500 customers that were potentially in scope for the event). This decision was made to help mitigate potential public safety risks by reducing the number of customers who were de-energized as much as safely possible. While avoiding de-energization entirely was not possible, SCE has taken steps to reduce the impacts of the event on the community and considered the impacts of the event within the context of the risk posed by the prevailing weather conditions.

11. A copy of all notifications, the timing of notifications, the methods of notifications and who made the notifications (the utility or local public safety partners).

A copy of all notifications and the timing of notifications can be found in Attachment A - Public Safety Partner Notifications, Attachment B - Critical Infrastructure and Customer Notifications and Attachment C - PSPS Activation Customer Notification Messaging

All PSPS event notifications to key stakeholders, including Public Safety Partners and customers, are delivered via voice, email, and TTY (telecommunication device for the hearing impaired) formats as per the preference of the recipient. Notifications are offered in multiple languages.

All notifications were made by SCE.

12. Number of affected customers broken down by all classifications including residential, medical baseline, commercial/industrial, etc.:

A detailed description of the number of affected customers broken down by all classifications including residential, medical baseline, commercial/industrial, etc. is provided in Attachment B- Customer and Critical Infrastructure Notifications.

13. An explanation of the circumstances that resulted in failure to communicate a potential pro-active de-energization event, if any.

When possible, SCE strives to provide priority notification to Public Safety Partners (including CalOES, the CPUC, and county emergency management officials) three days ahead of the initial forecasted the period of concern. In this event, SCE was unable to provide three-day ahead notifications to Public Safety Partners because the Tejon and Toll circuits were first forecasted to breach PSPS criteria only two days prior to the event, in both cases. [SCE did provide approximately 46-hour notification for the Tejon circuit and 51-hour notification for the Toll circuit as that was the earliest notice could be provided in view of the forecast]. Daily additional alerting and warning update notifications were made to maintain situational awareness and

provide updated information regarding the ongoing potential PSPS event.

Although Los Angeles County and Kern County emergency management officials were contacted, some contacts in Los Angeles and Kern counties were inadvertently left off the initial notification due to a technical issue with the Everbridge Notification System SCE uses for local government and municipal Public Safety Partner notifications. These contacts were manually contacted by Local Public Affairs the next day (as soon as the error was identified) and this technical issue did not occur with future notifications.

14. Each electric investor-owned utility shall enumerate and explain the cause of any false communications in its post event reports by citing the sources of changing data.

SCE only tracks critical care customers for positive or affirmative receipt of notification attempts. Notifications are made daily as these customers remain on potentially impacted circuits. There were four critical care customers on the Tejon circuit and SCE made positive contact with all of them during this event.

SCE notes that its PSPS notices before potential de-energization) only provide a warning to customers of a possible de-energization event. SCE notices are designed to give customers notice that a de-energization could take place and a time frame within which the event is most likely to occur so that customers can take action and prepare. Given the unpredictability of weather on the ground, however, SCE's advance notices do not affirmatively confirm that a circuit *will be* de-energized. In fact, for clarity, SCE does not provide any affirmative notifications until an actual de-energization has taken place.

SCE believes that its notices are correct and factual. However, except with respect to the 17 customer meters that were de-energized, the rest of the customers who received notice of a possible de-energization were not in fact taken off-line. The definition of false positive is subject to interpretation about which notifications should be included. Impending de-energizations could reasonably be interpreted as notifications of imminent de-energization 1-4 hours before outages. SCE believes, however, that the Commission may be interested in all the advance notices of a possible de-energization to such customers. Consequently, in effort to assure transparency and full compliance, SCE will treat them here as potential "false positives" within the meaning of the PSPS guidance. SCE would appreciate any additional Commission clarification or guidance on this issue to assure it is fully compliant.

SCE notes that "false positives" typically refer to decisions made, or actions taken based on erroneous information. Differences between notifications and actual de-energizations, however, do not stem from incorrect data, but rather from actual ground conditions varying from forecast conditions. This variance is inherent because of the constantly changing nature of emergent weather. SCE hopes that the Commission will take this into consideration when clarifying the definition of false positives going forward.

15. A description and evaluation of engagement with local and state public safety partners in providing advanced education and outreach during the de-energization event.

Advanced education and outreach of this Public Safety Power Shutoff event was communicated to all impacted county emergency management officials, CalOES, and the Commission before any forecasted weather was scheduled to impact the SCE service territory. Regular updates were provided throughout the event using the CalOES PSPS Notification Form, daily situational awareness and coordination calls and individual contact with Public Safety Partners in the affected counties.

16. For those customers where positive or affirmative notification was attempted, an accounting of the customers (which tariff and/or access and functional needs population designation), the number of notification attempts made, the timing of attempts, who made the notification attempt (utility or public safety partner) and the number of customers for whom positive notification was achieved.

SCE only tracks critical care customers for positive or affirmative receipt of notification attempts. Notifications are made daily as these customers remain on potentially impacted circuits. There were four critical care customers on the Tejon circuit and SCE made positive contact with all of them during this event.

17. A description of how sectionalizing, i.e., separating loads within a circuit, was considered and implemented and the extent to which it impacted the size and scope of the de-energization event.

There were approximately 500 total customers in scope for potential de-energization on the Tejon circuit during this event. SCE used sectionalizing through an RAR device to separate and isolate the de-energization area, limiting the de-energization to 17 customer meters in the High Fire Risk Area.

18. An explanation of how the utility determined that the benefit of de-energization outweighed potential public safety risks.

In considering the impacts of potential de-energization, SCE consults daily with County Emergency Management Officials to identify potential public safety concerns. In connection with this event, SCE did not receive any requests to forego de-energization through any of these daily calls. To minimize impacts on the community served by the Tejon circuit, SCE took measures to de-energize 17 customer meters out of the nearly 500 customers that were potentially in scope for the event by de-energizing only the portion of the circuit where fire weather conditions were present by leveraging sectionalizing devices to isolate only the customers in the areas of highest risk. While avoiding de-energization entirely was not possible, SCE has taken steps to reduce the impacts of the event on the community and considered the impacts of the event within the context of the risk posed by the prevailing weather conditions.

19. Lessons learned from the de-energization events.

SCE identified the following lessons learned from this event.

- SCE Fire Scientist or a delegate shall consult with Predictive Services at the Southern California Geographical Area Coordination Center (GACC) to discuss forecast weather, fuel and increased fire danger conditions in conjunction with declaring a PSPS event, where appropriate.
- To minimize the number of hours customers were de-energized, SCE attempted to re-energize the Tejon Circuit between periods of concern. As mentioned above, increased wind speeds returned early, and SCE was not able to re-energize prior to the next period of concern. SCE is committed to re-energizing customers whenever possible; however, it is important to weigh this desire against the potential for unexpected changes in weather or damage to the circuit that may prohibit re-energization as quickly as SCE would like after the notifications are sent.

Officer Verification

I am an officer of the applicant corporation herein and am authorized to make this verification on its behalf. I am informed and believe that the matters stated in the foregoing document are true.

I declare under penalty of perjury that the foregoing is true and correct.

Executed this 17 day of August 2020 in Altadena, California

A handwritten signature in blue ink, appearing to read "Marc Ulrich", is written over a horizontal line. The signature is stylized and includes a large loop at the end.

Marc Ulrich

Vice President,

Customer Service Operations

Attachment A

Public Safety Partner Notifications

Everbridge PPS Notification Audit Report 2020-07-31 All Counties Report 1

Notification ID	Message Title	Sent On
508253544977878	Important Information from SCE – Possible Public Safety Power Shutoff in Kern County on 8/4/2020.	Jul 31, 2020 19:28:09 PDT
508253544977884	Important Information from SCE – Possible Public Safety Power Shutoff in Los Angles County on 8/2 .	Jul 31, 2020 19:34:49 PDT
508253544977888	UPDATED: Important Information from SCE – Possible Public Safety Power Shutoff in Kern County on 8/2/2020*	Jul 31, 2020 19:42:42 PDT

*This item was a CORRECTION and not an UPDATE. The subject line included incorrect date from the 19:28 original notice.

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, July 31, 2020 7:28 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff in Kern County on 8/4/2020.
Attachments: SCE+LNO+POC+2020-07-31+UPDATE+Kern+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Kern County. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Southern California Edison LNO Circuit List with Periods of Concern
As of 07/31/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pssp for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	Initial					07/31/2020		08/01/2020		08/02/2020	1800-2100	08/03/2020	0600-0900	438	0	30	12	4	484

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, July 31, 2020 7:35 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff in Los Angeles County on 8/2 .
Attachments: SCE+LNO+POC+2020-07-31+UPDATE+Los+Angeles+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Los Angeles. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Southern California Edison LNO Circuit List with Periods of Concern
As of 07/31/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti
 Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
 Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
 Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pssp for total customer counts by county.
 Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	LOS ANGELES		Three Points City	Initial					07/31/2020		08/01/2020		08/02/2020	1800-2100	08/03/2020	0600-0900	438	0	30	12	4	484

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Friday, July 31, 2020 7:43 PM
To: SCE Liaison Officer
Subject: UPDATED: Important Information from SCE – Possible Public Safety Power Shutoff in Kern County on 8/2/2020
Attachments: SCE+LNO+POC+2020-07-31+UPDATE+Kern+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Kern County. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspсалerts.

Southern California Edison LNO Circuit List with Periods of Concern
As of 07/31/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pssp for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	Initial					07/31/2020		08/01/2020		08/02/2020	1800-2100	08/03/2020	0600-0900	438	0	30	12	4	484

Everbridge PSPS Notification Audit Report 2020-08-01 All Counties Report 1

Notification ID	Message Title	Sent On
508253544978595	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.	Aug 01, 2020 11:04:16 PDT
508253544978673	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Aug 01, 2020 12:21:05 PDT

Allison M Leanos

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Saturday, August 1, 2020 11:04 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.
Attachments: SCE+LNO+POC+2020-08-01+UPDATE+Kern+County+Rpt+1.xlsx
Follow Up Flag: Follow up
Flag Status: Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Kern County. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 08/01/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti
 Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
 Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
 Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pssp for total customer counts by county.
 Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	Update					08/01/2020		08/02/2020	1800-0000	08/03/2020	0000-0600,1800-2100	08/04/2020		438	0	30	12	4	484

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Saturday, August 1, 2020 12:21 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.
Attachments: SCE+LNO+POC+2020-08-01+UPDATE+Los+Angeles+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Los Angeles County. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspсалerts.

Southern California Edison LNO Circuit List with Periods of Concern
As of 08/01/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pssp for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	LOS ANGELES		Three Points City	Update					08/01/2020		08/02/2020	1800-0000	08/03/2020	0000-0600,1800-2100	08/04/2020		438	0	30	12	4	484

Everbridge PPS Notification Audit Report 2020-08-01 All Counties Report 2

Notification ID	Message Title	Sent On
508253544978963	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.	Aug 01, 2020 17:51:02 PDT
508253544978968	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Aug 01, 2020 17:58:18 PDT

Allison M Leanos

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Saturday, August 1, 2020 5:51 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.
Attachments: SCE+LNO+POC+2020-08-01+UPDATE+Kern+County+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Kern County. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Southern California Edison LNO Circuit List with Periods of Concern
As of 08/01/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti
 Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
 Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
 Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pssp for total customer counts by county.
 Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	Update					08/01/2020		08/02/2020	1800-0000	08/03/2020	0000-0600,1800-0000	08/04/2020		438	0	30	12	4	484

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Saturday, August 1, 2020 5:59 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.
Attachments: SCE+LNO+POC+2020-08-01+UPDATE+Los+Angeles+County+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Los Angeles County. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Southern California Edison LNO Circuit List with Periods of Concern
As of 08/01/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti
 Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.
 Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.
 Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pssp for total customer counts by county.
 Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	LOS ANGELES		Three Points City	Update					08/01/2020		08/02/2020	1800-0000	08/03/2020	0000-0600,1800-0000	08/04/2020		438	0	30	12	4	484

Everbridge PPS Notification Audit Report 2020-08-02 All Counties Report 1

Notification ID	Message Title	Sent On
508253544979635	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.	Aug 02, 2020 10:55:59 PDT
508253544979643	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Aug 02, 2020 11:01:20 PDT
508253544979661	Important Information from SCE – Possible Public Safety Power Shutoff in Riverside County on 8/4/2020.	Aug 02, 2020 11:23:07 PDT

Lisa Calderon

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 10:56 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.
Attachments: SCE+LNO+POC+2020-08-02+UPDATE+Kern+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Kern County. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/02/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See scc.com/safety/wildfire/jpps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	No Change					08/02/2020	1800-0000	08/03/2020		0000-0600,1800-0000	08/04/2020			438	0	30	12	4	484

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 11:02 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.
Attachments: SCE+LNO+POC+2020-08-02+UPDATE+Los+Angeles+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Los Angeles County. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/02/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See scc.com/safety/wildfire/jpps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	LOS ANGELES		Three Points City	No Change					08/02/2020	1800-0000	08/03/2020	0000-0600,1800-0000	08/04/2020		08/05/2020		438	0	30	12	4	484

Lisa Calderon

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 11:23 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff in Riverside County on 8/4/2020.
Attachments: SCE+LNO+POC+2020-08-02+UPDATE+Riverside+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Riverside County. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Please refer to the attached file for status and periods of concern for specific circuits in your county.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspсалerts.

Southern California Edison LNO Circuit List with Periods of Concern
As of 08/02/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/jpps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TOLL	RIVERSIDE	Palm Springs		Initial					08/02/2020		08/03/2020		08/04/2020	1500-2100	08/05/2020		26	1	29	0	0	56
TOLL	RIVERSIDE		Whitewater Canyon	Initial					08/02/2020		08/03/2020		08/04/2020	1500-2100	08/05/2020		26	1	29	0	0	56

Everbridge Audit Report 2020-08-02 All Counties

Notification ID	Message Title	Sent On
508253544979806	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County	Aug 02, 2020 14:16:28 PDT
508253544979812	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Aug 02, 2020 14:19:51 PDT

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 2:17 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Tejon**
- **County: Kern County**
- **Unincorporated County Area: South of Twin Lakes**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/pmps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspсалerts.

Lisa Calderon

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 2:20 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Tejon**
- **County: Los Angeles**
- **Unincorporated County Area: Three Points City**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-08-02 All Counties

Notification ID	Message Title	Sent On
508253544979826	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Kern County at 14:15.	Aug 02, 2020 14:29:56 PDT
508253544979831	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 14:15.	Aug 02, 2020 14:33:46 PDT

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 2:30 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Kern County at 14:15.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in Kern County. Impacted circuits and locations are:

- **Circuit: Portion of Tejon Circuit**
- **County: Kern County**
- **Unincorporated County Area: South of Twin Lakes**
- **De-Energized Date: 8/2/2020**
- **De-Energized Time: 14:15**

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 2:34 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 14:15.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in Los Angeles County. Impacted circuits and locations are:

- **Circuit: Portion of Tejon Circuit**
- **County: Los Angeles**
- **Unincorporated County Area: Three Points City**
- **De-Energized Date: 8/2/2020**
- **De-Energized Time: 14:15**

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PPS Notification Audit Report 2020-08-02 All Counties Report 2

Notification ID	Message Title	Sent On
508665861842534	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Aug 02, 2020 19:00:38 PDT
508665861842538	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.	Aug 02, 2020 19:05:23 PDT
508665861842544	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Aug 02, 2020 19:11:42 PDT
508665861842546	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Aug 02, 2020 19:11:54 PDT

Duplicate notification sent to Riverside County

Allison M Leanos

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 7:01 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.
Attachments: SCE+LNO+POC+2020-08-02+UPDATE+Los+Angeles+County+Rpt+2.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/02/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti-

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pmps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	LOS ANGELES		Three Points City	De-Energized – Partial	Portion of the Tejon Circuit has been de-energized due to PSPS	8/2/2020	14:15		08/02/2020	1800-0000	08/03/2020	0000-0600	08/04/2020		08/05/2020		438	0	30	12	4	484

Allison M Leanos

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 7:06 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.
Attachments: SCE+LNO+POC+2020-08-02+UPDATE+Kern+County+Rpt+2.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Kern County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 08/02/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspecti-

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pssp for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	De-Energized – Partial	Portion of the Tejon Circuit has been de-energized due to PSPS	8/2/2020	14:15		08/02/2020	1800-0000	08/03/2020	0000-0600	08/04/2020		08/05/2020		438	0	30	12	4	484

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 7:12 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.
Attachments: SCE+LNO+POC+2020-08-02+UPDATE+Riverside+County+Rpt+2.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/02/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspect-

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pmps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TOLL	RIVERSIDE	Palm Springs		De-Energized – Not PSPS related	Portion of the Toll Circuit has been de-energized due to a fire in the area (not PSPS), currently one customer impacted.	8/2/2020	15:01		08/02/2020		08/03/2020		08/04/2020		08/05/2020	1500-1800	26	1	29	0	0	56
TOLL	RIVERSIDE		Whitewater Canyon	De-Energized – Not PSPS related	Portion of the Toll Circuit has been de-energized due to a fire in the area (not PSPS), currently one customer impacted.	8/2/2020	15:01		08/02/2020		08/03/2020		08/04/2020		08/05/2020	1500-1800	26	1	29	0	0	56

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 7:12 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.
Attachments: SCE+LNO+POC+2020-08-02+UPDATE+Riverside+County+Rpt+2.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 08/02/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspect.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pmps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TOLL	RIVERSIDE	Palm Springs		De-Energized – Not PSPS related	Portion of the Toll Circuit has been de-energized due to a fire in the area (not PSPS), currently one customer impacted.	8/2/2020	15:01		08/02/2020		08/03/2020		08/04/2020		08/05/2020	1500-1800	26	1	29	0	0	56
TOLL	RIVERSIDE		Whitewater Canyon	De-Energized – Not PSPS related	Portion of the Toll Circuit has been de-energized due to a fire in the area (not PSPS), currently one customer impacted.	8/2/2020	15:01		08/02/2020		08/03/2020		08/04/2020		08/05/2020	1500-1800	26	1	29	0	0	56

Everbridge PSPS Audit Report 2020-08-02 Los Angeles County

Notification ID	Message Title	Sent On
508665861842675	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Aug 02, 2020 22:58:23 PDT

Allison M Leanos

From: SCEliaoisonOfficer@sce.com <noreply@everbridge.net>
Sent: Sunday, August 2, 2020 10:59 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

Importance: High

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Tejon**
- **County: Los Angeles County**
- **Unincorporated County Area: Three Points City**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-08-03 All Counties

Notification ID	Message Title	Sent On
508665861842719	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.	Aug 03, 2020 00:38:10 PDT
508665861842720	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Aug 03, 2020 00:39:39 PDT

Allison M Leanos

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 12:38 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Tejon**
- **County: Kern County**
- **Unincorporated County Area: South of Twin Lakes**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/psps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Allison M Leanos

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 12:40 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Tejon**
- **County: Los Angeles County**
- **Unincorporated County Area: Three Points City**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit www.sce.com/PSPS.

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at sce.com/maps.
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at sce.com/PSPS.
- Access SCE's non-PSPS outage information page at sce.com/outages.
- Access information on weather conditions at sce.com/fireweather.
- SCE's post-PSPS reports are available at sce.com/pmps.

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Everbridge PSPS Notification Audit Report 2020-08-03 All Counties

Notification ID	Message Title	Sent On
508253544980690	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Kern County.	Aug 03, 2020 08:59:37 PDT
508253544980694	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.	Aug 03, 2020 09:02:57 PDT

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 9:00 AM
To: SCE Liaison Officer
Subject: Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Kern County.

Importance: High

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: TEJON Circuit**
- **County: Kern County**
- **Unincorporated County Area: South of Twin Lakes**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 9:03 AM
To: SCE Liaison Officer
Subject: Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.

Importance: High

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: TEJON Circuit**
- **County: Los Angeles**
- **Unincorporated County Area: Three Points City**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Everbridge PSPS Notification Audit Report 2020-08-03 All Counties Report 1

Notification ID	Message Title	Sent On
508253544980722	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.	Aug 03, 2020 09:21:11 PDT
508253544980731	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Aug 03, 2020 09:25:24 PDT
508253544980735	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Aug 03, 2020 09:29:19 PDT

Lisa Calderon

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 9:21 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.
Attachments: SCE+LNO+POC+2020-08-03+UPDATE+Kern+County+Rpt+1.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Kern County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/03/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspect

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See scc.com/safety/wildfire/pjps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	Imminent Re-Energize	Portion of the Tejon Circuit has been de-energized due to PSPS. Patrols for potential re-energization have begun. Note however, a new POC begins at 1500 today.	8/2/2020	14:15		08/03/2020	0000-0900,1500-0000	08/04/2020		08/05/2020		08/06/2020		438	0	30	12	4	484

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 9:26 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.
Attachments: SCE+LNO+POC+2020-08-03+UPDATE+Los+Angeles+County+Rpt+1.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/03/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspect

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See scc.com/safety/wildfire/pops for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	LOS ANGELES		Three Points City	Imminent Re-Energize	Portion of the Tejon Circuit has been de-energized due to PSPS. Patrols for potential re-energization have begun. Note however, a new POC begins at 1500 today.	8/2/2020	14:15		08/03/2020	0000-0900,1500-0000	08/04/2020		08/05/2020		08/06/2020		438	0	30	12	4	484

Lisa Calderon

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 9:29 AM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.
Attachments: SCE+LNO+POC+2020-08-03+UPDATE+Riverside+County+Rpt+1.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/03/2020 Circuit List All Counties Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspect.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See scc.com/safety/wildfire/pops for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TOLL	RIVERSIDE	Palm Springs		De-Energized – Not PSPS related	Portion of the Toll Circuit has been de-energized due to a fire in the area (not PSPS), currently one customer impacted. Note, this circuit is no longer being considered for PSPS.	8/2/2020	15:01		08/03/2020		08/04/2020		08/05/2020		08/06/2020		26	1	29	0	0	56
TOLL	RIVERSIDE		Whitewater Canyon	De-Energized – Not PSPS related	Portion of the Toll Circuit has been de-energized due to a fire in the area (not PSPS), currently one customer impacted. Note, this circuit is no longer being considered for PSPS.	8/2/2020	15:01		08/03/2020		08/04/2020		08/05/2020		08/06/2020		26	1	29	0	0	56

Everbridge Notification Audit Report 2020-08-03

Notification ID	Message Title	Sent On
508253544981303	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.	Aug 03, 2020 16:08:20 PDT
508253544981305	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Kern County.	Aug 03, 2020 16:09:38 PDT

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 4:09 PM
To: SCE Liaison Officer
Subject: Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.

Importance: High

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: TEJON Circuit**
- **County: Los Angeles**
- **Unincorporated County Area: Three Points City**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Lisa Calderon

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 4:10 PM
To: SCE Liaison Officer
Subject: Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Kern County.

Importance: High

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: TEJON Circuit**
- **County: Kern County**
- **Unincorporated County Area: South of Twin Lakes**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspalerts.

Everbridge PSPS Notification Audit Report 2020-08-03 Los Angeles County

Notification ID	Message Title	Sent On
508253544981390	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.	Aug 03, 2020 17:34:26 PDT

Lisa Calderon

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 5:35 PM
To: SCE Liaison Officer
Subject: Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.

Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: TEJON Circuit**
- **County: Los Angeles**
- **Unincorporated County Area: Three Points City**
- **Re-Energized Date: 8/3/2020**
- **Re-Energized Time: 17:16**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspсалerts.

Everbridge PPS Notification Audit Report 2020-08-03 All Counties Report 2

Notification ID	Message Title	Sent On
508665861844192	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.	Aug 03, 2020 22:02:19 PDT
508665861844194	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Aug 03, 2020 22:03:42 PDT
508665861844195	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Aug 03, 2020 22:06:27 PDT

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 10:02 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.
Attachments: SCE+LNO+POC+2020-08-03+UPDATE+Kern+County+Rpt+2.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Kern County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/03/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/pmps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	De-Energized – Partial	Portion of the Tejon Circuit has been de-energized due to PSPS.	08/02/2020	14:15		08/03/2020	1500-0000	08/04/2020		08/05/2020		08/06/2020		438	0	30	12	4	484

Allison M Leanos

From: SCEliaoisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 10:04 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.
Attachments: SCE+LNO+POC+2020-08-03+UPDATE+Los+Angeles+County+Rpt+2.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/03/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/psps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	LOS ANGELES		Three Points City	Re-Energized		08/03/2020	17:16		08/03/2020	1500-0000	08/04/2020		08/05/2020		08/06/2020		438	0	30	12	4	484

Allison M Leanos

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Monday, August 3, 2020 10:07 PM
To: SCE Liaison Officer
Subject: Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.
Attachments: SCE+LNO+POC+2020-08-03+UPDATE+Riverside+County+Rpt+2.xlsx
Follow Up Flag: Follow up
Flag Status: Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

Recommended Language to Share with the Public: Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Southern California Edison LNO Circuit List with Periods of Concern
As of 08/03/2020 Circuit List All Counties Report #2

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sce.com/safety/wildfire/psps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TOLL	RIVERSIDE	Palm Springs		All Clear	This circuit is no longer being considered for PSPS. Portion of the Toll Circuit has been de-energized due to a fire in the area (not PSPS), currently one customer impacted. When conditions allow, operations will restore power to customer.				08/03/2020		08/04/2020		08/05/2020		08/06/2020		26	1	29	0	0	56
TOLL	RIVERSIDE		Whitewater Canyon	All Clear	This circuit is no longer being considered for PSPS. Portion of the Toll Circuit has been de-energized due to a fire in the area (not PSPS), currently one customer impacted. When conditions allow, operations will restore power to customer.				08/03/2020		08/04/2020		08/05/2020		08/06/2020		26	1	29	0	0	56

Everbridge PPS Notification Audit Report 2020-08-04 Kern County RE

Notification ID	Message Title	Sent On
509215617656580	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Kern County	Aug 04, 2020 10:39:05 PDT

Joyce Lui

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, August 4, 2020 10:39 AM
To: SCE Liaison Officer
Subject: Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Kern County

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: TEJON Circuit**
- **County: Kern County**
- **Unincorporated County Area: South of Twin Lakes**
- **Re-Energized Date: 08/04/2020**
- **Re-Energized Time: 10:32**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

Recommended Language to Share with the Public: SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspсалerts.

Zack	Scrivner	district2@co.kern.ca.us	1	Aug 04, 2020 10:39:25 PDT	Email Address 1	district2@co.kern.ca.us	No		Sent
Hilda	Solis	hsolis1@bos.lacounty.gov	1	Aug 04, 2020 10:39:32 PDT	Email Address 1	hsolis1@bos.lacounty.gov	No		Sent
Anna	Mouradian	amouradian@bos.lacounty.gov	1	Aug 04, 2020 10:39:35 PDT	Email Address 1	amouradian@bos.lacounty.gov	No		Sent
Katy	Young	kyoung@bos.lacounty.gov	1	Aug 04, 2020 10:39:27 PDT	Email Address 1	kyoung@bos.lacounty.gov	No		Sent
Duty	Officer	kerndutyofficer@kerncountyfire.org	1	Aug 04, 2020 10:39:30 PDT	Email Address 1	kerndutyofficer@kerncountyfire.org	No		Sent
Roel	Amara	ramara@dhs.lacounty.gov	1	Aug 04, 2020 10:39:23 PDT	Email Address 1	ramara@dhs.lacounty.gov	No		Sent
Stella	Fogleman	sfogleman@ph.lacounty.gov	1	Aug 04, 2020 10:39:29 PDT	Email Address 1	sfogleman@ph.lacounty.gov	No		Sent
Vicki	L Stuckely	viatuckely@lasd.org	1	Aug 04, 2020 10:39:34 PDT	Email Address 1	viatuckely@lasd.org	No		Sent
Kelly	Decker	kellyrindecker@aol.com	0		SMS Blkbyr TXT Ph#	18187617713	No		Not Delivered - Duplicate Path
Kelly	Decker	kellyrindecker@aol.com	1	Aug 04, 2020 10:39:35 PDT	Email Address 1	kellyrindecker@aol.com	No		Sent
Kelly	Decker	kellyrindecker@aol.com	2	Aug 04, 2020 10:39:17 PDT	Mobile (Text-SMS)	18187617713	No		Not Delivered - Invalid Number

Everbridge PSPS Notification Audit Report 2020-08-04 All Counties Report 1

Notification ID	Message Title	Sent On
509215617656661	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Los Angeles County	Aug 04, 2020 11:19:30 PDT
509215617656659	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Kern County	Aug 04, 2020 11:16:14 PDT
509215617656706	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Riverside County	Aug 04, 2020 11:45:47 PDT

Joyce Lui

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, August 4, 2020 11:17 AM
To: SCE Liaison Officer
Subject: Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Kern County
Attachments: SCE+LNO+POC+2020-08-04+EVENT+CONCLUDED+Kern+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/04/2020 Circuit List Kern County Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See sca.com/safety/wildfire/pjps for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	KERN		South of Twin Lakes	All Clear					08/04/2020		08/05/2020		08/06/2020		08/07/2020		438	0	30	12	4	484

David	W	Ashman		dmac@dmae.ca.gov	2	Aug 04, 2020 11:16:24 PDT	Mobile (Text-SMS)	15625056443	No		Delivered - To Handset
Robert		Scharf		scenotify@dpw.lacounty.gov	1	Aug 04, 2020 11:16:24 PDT	Email Address 1	scenotify@dpw.lacounty.gov	Yes	Aug 04, 2020 11:37	Confirmed
Diana		Manzano		dmanzano@areadonline.com	1	Aug 04, 2020 11:16:30 PDT	Email Address 1	dmanzano@areadonline.com	Yes	Aug 04, 2020 12:15	Confirmed
Helen	E	Chavez		hchavez@ceooem.lacounty.gov	0		SMS Blkbry TXT Ph#	12134586351	No		Not Delivered - Duplicate Path
Helen	E	Chavez		hchavez@ceooem.lacounty.gov	1	Aug 04, 2020 11:16:41 PDT	Email Address 1	hchavez@ceooem.lacounty.gov	No		Sent
Helen	E	Chavez		hchavez@ceooem.lacounty.gov	2	Aug 04, 2020 11:16:23 PDT	Mobile (Text-SMS)	12134586351	No		Delivered - To Handset

Joyce Lui

From: SCEliaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, August 4, 2020 11:20 AM
To: SCE Liaison Officer
Subject: Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Los Angeles County
Attachments: SCE+LNO+POC+2020-08-04+EVENT+CONCLUDED+LA+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.

- SCELiasonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/04/2020 Circuit List Los Angeles County Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspection.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See scc.com/safety/wildfire/pops for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TEJON	LOS ANGELES		Three Points City	All Clear					08/04/2020		08/05/2020		08/06/2020		08/07/2020		438	0	30	12	4	484

Kerjon		Lee		kelee@dpw.lacounty.gov	1	Aug 04, 2020 11:16:26 PDT	Email Address 1	kelee@dpw.lacounty.gov	No		Sent	
Kerjon		Lee		kelee@dpw.lacounty.gov	2	Aug 04, 2020 11:16:24 PDT	Mobile (Text-SMS)	16264760533	No		Delivered - To Handset	
David	W	Ashman		dmac@dmae.ca.gov	0		SMS BlkbyrY TXT Ph#	15625056443	No		Not Delivered - Duplicate Path	
David	W	Ashman		dmac@dmae.ca.gov	1	Aug 04, 2020 11:16:29 PDT	Email Address 1	dmac@dmae.ca.gov	Yes	Aug 04, 2020 11	Confirmed	
David	W	Ashman		dmac@dmae.ca.gov	2	Aug 04, 2020 11:16:24 PDT	Mobile (Text-SMS)	15625056443	No		Delivered - To Handset	
Robert		Scharf		scenotify@dpw.lacounty.gov	1	Aug 04, 2020 11:16:24 PDT	Email Address 1	scenotify@dpw.lacounty.gov	Yes	Aug 04, 2020 11	Confirmed	
Diana		Manzano		dmanzano@areadonline.com	1	Aug 04, 2020 11:16:30 PDT	Email Address 1	dmanzano@areadonline.com	Yes	Aug 04, 2020 12	Confirmed	
Helen	E	Chavez		hchavez@ceooem.lacounty.gov	0		SMS BlkbyrY TXT Ph#	12134586351	No		Not Delivered - Duplicate Path	
Helen	E	Chavez		hchavez@ceooem.lacounty.gov	1	Aug 04, 2020 11:16:41 PDT	Email Address 1	hchavez@ceooem.lacounty.gov	No		Sent	
Helen	E	Chavez		hchavez@ceooem.lacounty.gov	2	Aug 04, 2020 11:16:23 PDT	Mobile (Text-SMS)	12134586351	No		Delivered - To Handset	

Joyce Lui

From: SCELiaisonOfficer@sce.com <noreply@everbridge.net>
Sent: Tuesday, August 4, 2020 11:46 AM
To: SCE Liaison Officer
Subject: Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Riverside County
Attachments: SCE+LNO+POC+2020-08-04+EVENT+CONCLUDED+Riverside+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a fire, weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

Recommended Language to Share with the Public: The PSPS event in your area has concluded. Customers in this area, however, may experience fire, weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
 - SCE Business Resiliency Team
 - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
 - BusinessResiliencyDutyManager@sce.com. The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
 - SCE Liaison Officer (LNO)
 - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
 - SCELiaisonOfficer@sce.com. The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
 - 800-611-1911 is for outage-specific Customer Service issues.
 - 800-684-8123 is for all other billing and service inquiries.
 - sce.com/PSPS is the site where customers may learn more about PSPS events in their area.
 - Update customer contact information at sce.com/pspsalerts.

Southern California Edison LNO Circuit List with Periods of Concern

As of 08/04/2020 Circuit List Riverside Report #1

Note 1: Restoration activities begin as soon as conditions improve and it is safe for crews to begin inspections.

Note 2: Estimated Restoration Times may be delayed if damage is found or if weather conditions change.

Note 3: 72-hour notification information is for local government and agency planning use only. Customer notifications begin at 48 hours.

Note 4: Approximate customer counts are calculated by circuit, regardless of jurisdiction. If a circuit crosses jurisdictional boundaries, the total customer counts for that circuit are included for each jurisdiction. See scea.com/safety/wildfire/pssp for total customer counts by county.

Note 5: Please refer to Definitions tab for additional information.

Circuit Name	County	Incorporated City/Cities	Unincorporated Communities	Circuit Notification Status	Comments	De-Energ / Re-Energ Date	De-Energ / Re-Energ Time	Est. Restor. Time De-Energ Circuits	Day 1 PoC Date	Day 1 PoC Time	Day 2 PoC Date	Day 2 PoC Time	Day 3 PoC Date	Day 3 PoC Time	Day 4 PoC Date	Day 4 PoC Time	Residential/Unassigned (Entire Circuit)	Essential Use (Entire Circuit)	Major (Entire Circuit)	MBL (Entire Circuit)	Critical Care (Entire Circuit)	Customer Totals (Entire Circuit)
TOLL	RIVERSIDE	Palm Springs		All Clear	This circuit is no longer being considered for PSPS. Portion of the Toll Circuit had been de-energized due to a fire in the area (not PSPS), impacting one customer.				08/04/2020		08/05/2020		08/06/2020		8/7/2020		26	1	29	0	0	56
TOLL	RIVERSIDE		Whitewater Canyon	All Clear	This circuit is no longer being considered for PSPS. Portion of the Toll Circuit had been de-energized due to a fire in the area (not PSPS), impacting one customer.				08/04/2020		08/05/2020		08/06/2020		8/7/2020		26	1	29	0	0	56

Attachment B

Critical Infrastructure and Customer Notifications

07.31.2020 PSPS Activation Customer Communication Notification Tracking Sheet

CIRCUIT STATUS								COMMUNICATIONS						CUSTOMER COUNTS					
Circuits	D_ST_T	Downstreams	Parent Circuit	Counties	Added to Target List	Removed from Target List	HFA Circuit	Initial (72 Hour)	2 Day (48 Hour)	1 Day (24 Hour)	Day Of	Update(s) (required daily unless circuit is de-energized)	All Clear	Residential/ Unassigned	Essential Use	Major	MBL	Critical Care	Customer Totals
TEJON	D			KERN;LOS ANGELES	07/31/2020				7/31/2020 19:36					438	0	30	12	4	484

07.31.2020 PSPS Activation Customer Communication Notification Tracking Sheet

CIRCUIT STATUS							COMMUNICATIONS					CUSTOMER COUNTS							
Circuits	D_ST_T	Downstreams	Parent Circuit	Counties	Added to Target List	Removed from Target List	HFA Circuit	Initial (72 Hour)	2 Day (48 Hour)	1 Day (24 Hour)	Day Of	Update(s) (required daily unless circuit is de-energized)	All Clear	Residential/Unassigned	Essential Use	Major	MBL	Critical Care	Customer Totals
TEJON	D			KERN;LOS ANGELES	07/31/2020				7/31/2020 19:36	8/1/2020 18:13				438	0	30	12	4	484

07.31.2020 PSPS Activation Customer Communication Notification Tracking Sheet

CIRCUIT STATUS								COMMUNICATIONS					CUSTOMER COUNTS							
Circuits	D_ST_T	Downstreams	Parent Circuit	Counties	Added to Target List	Removed from Target List	HFA Circuit	Initial (72 Hour)	2 Day (48 Hour)	1 Day (24 Hour)	Day Of	Update(s) (required daily unless circuit is de-energized)	All Clear	Residential/Unassigned	Essential Use	Major	MBL	Critical Care	Customer Totals	
TEJON	D			KERN;LOS ANGELES	07/31/2020				7/31/2020 19:36	8/1/2020 18:13				438	0	30	12		4	484
TOLL	D			RIVERSIDE	08/02/2020				8/2/2020 11:34					26	1	29	0		0	56

**07.31.2020 PSPS Activation
Customer Communication Notification Tracking Sheet**

COMMUNICATIONS										CUSTOMER COUNTS										PSPS PROTOCOL																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
Circuit ID	Parent Circuit	Customer	Added to Target List	Removed from Target List	SPS Circuit	Initial (24 Hours)	1 Day (24 Hours)	2 Day (48 Hours)	3 Day (72 Hours)	4 Day (96 Hours)	5 Day (120 Hours)	6 Day (144 Hours)	7 Day (168 Hours)	8 Day (192 Hours)	9 Day (216 Hours)	10 Day (240 Hours)	11 Day (264 Hours)	12 Day (288 Hours)	13 Day (312 Hours)	14 Day (336 Hours)	15 Day (360 Hours)	16 Day (384 Hours)	17 Day (408 Hours)	18 Day (432 Hours)	19 Day (456 Hours)	20 Day (480 Hours)	21 Day (504 Hours)	22 Day (528 Hours)	23 Day (552 Hours)	24 Day (576 Hours)	25 Day (600 Hours)	26 Day (624 Hours)	27 Day (648 Hours)	28 Day (672 Hours)	29 Day (696 Hours)	30 Day (720 Hours)	31 Day (744 Hours)	32 Day (768 Hours)	33 Day (792 Hours)	34 Day (816 Hours)	35 Day (840 Hours)	36 Day (864 Hours)	37 Day (888 Hours)	38 Day (912 Hours)	39 Day (936 Hours)	40 Day (960 Hours)	41 Day (984 Hours)	42 Day (1008 Hours)	43 Day (1032 Hours)	44 Day (1056 Hours)	45 Day (1080 Hours)	46 Day (1104 Hours)	47 Day (1128 Hours)	48 Day (1152 Hours)	49 Day (1176 Hours)	50 Day (1200 Hours)	51 Day (1224 Hours)	52 Day (1248 Hours)	53 Day (1272 Hours)	54 Day (1296 Hours)	55 Day (1320 Hours)	56 Day (1344 Hours)	57 Day (1368 Hours)	58 Day (1392 Hours)	59 Day (1416 Hours)	60 Day (1440 Hours)	61 Day (1464 Hours)	62 Day (1488 Hours)	63 Day (1512 Hours)	64 Day (1536 Hours)	65 Day (1560 Hours)	66 Day (1584 Hours)	67 Day (1608 Hours)	68 Day (1632 Hours)	69 Day (1656 Hours)	70 Day (1680 Hours)	71 Day (1704 Hours)	72 Day (1728 Hours)	73 Day (1752 Hours)	74 Day (1776 Hours)	75 Day (1800 Hours)	76 Day (1824 Hours)	77 Day (1848 Hours)	78 Day (1872 Hours)	79 Day (1896 Hours)	80 Day (1920 Hours)	81 Day (1944 Hours)	82 Day (1968 Hours)	83 Day (1992 Hours)	84 Day (2016 Hours)	85 Day (2040 Hours)	86 Day (2064 Hours)	87 Day (2088 Hours)	88 Day (2112 Hours)	89 Day (2136 Hours)	90 Day (2160 Hours)	91 Day (2184 Hours)	92 Day (2208 Hours)	93 Day (2232 Hours)	94 Day (2256 Hours)	95 Day (2280 Hours)	96 Day (2304 Hours)	97 Day (2328 Hours)	98 Day (2352 Hours)	99 Day (2376 Hours)	100 Day (2400 Hours)	101 Day (2424 Hours)	102 Day (2448 Hours)	103 Day (2472 Hours)	104 Day (2496 Hours)	105 Day (2520 Hours)	106 Day (2544 Hours)	107 Day (2568 Hours)	108 Day (2592 Hours)	109 Day (2616 Hours)	110 Day (2640 Hours)	111 Day (2664 Hours)	112 Day (2688 Hours)	113 Day (2712 Hours)	114 Day (2736 Hours)	115 Day (2760 Hours)	116 Day (2784 Hours)	117 Day (2808 Hours)	118 Day (2832 Hours)	119 Day (2856 Hours)	120 Day (2880 Hours)	121 Day (2904 Hours)	122 Day (2928 Hours)	123 Day (2952 Hours)	124 Day (2976 Hours)	125 Day (3000 Hours)	126 Day (3024 Hours)	127 Day (3048 Hours)	128 Day (3072 Hours)	129 Day (3096 Hours)	130 Day (3120 Hours)	131 Day (3144 Hours)	132 Day (3168 Hours)	133 Day (3192 Hours)	134 Day (3216 Hours)	135 Day (3240 Hours)	136 Day (3264 Hours)	137 Day (3288 Hours)	138 Day (3312 Hours)	139 Day (3336 Hours)	140 Day (3360 Hours)	141 Day (3384 Hours)	142 Day (3408 Hours)	143 Day (3432 Hours)	144 Day (3456 Hours)	145 Day (3480 Hours)	146 Day (3504 Hours)	147 Day (3528 Hours)	148 Day (3552 Hours)	149 Day (3576 Hours)	150 Day (3600 Hours)	151 Day (3624 Hours)	152 Day (3648 Hours)	153 Day (3672 Hours)	154 Day (3696 Hours)	155 Day (3720 Hours)	156 Day (3744 Hours)	157 Day (3768 Hours)	158 Day (3792 Hours)	159 Day (3816 Hours)	160 Day (3840 Hours)	161 Day (3864 Hours)	162 Day (3888 Hours)	163 Day (3912 Hours)	164 Day (3936 Hours)	165 Day (3960 Hours)	166 Day (3984 Hours)	167 Day (4008 Hours)	168 Day (4032 Hours)	169 Day (4056 Hours)	170 Day (4080 Hours)	171 Day (4104 Hours)	172 Day (4128 Hours)	173 Day (4152 Hours)	174 Day (4176 Hours)	175 Day (4200 Hours)	176 Day (4224 Hours)	177 Day (4248 Hours)	178 Day (4272 Hours)	179 Day (4296 Hours)	180 Day (4320 Hours)	181 Day (4344 Hours)	182 Day (4368 Hours)	183 Day (4392 Hours)	184 Day (4416 Hours)	185 Day (4440 Hours)	186 Day (4464 Hours)	187 Day (4488 Hours)	188 Day (4512 Hours)	189 Day (4536 Hours)	190 Day (4560 Hours)	191 Day (4584 Hours)	192 Day (4608 Hours)	193 Day (4632 Hours)	194 Day (4656 Hours)	195 Day (4680 Hours)	196 Day (4704 Hours)	197 Day (4728 Hours)	198 Day (4752 Hours)	199 Day (4776 Hours)	200 Day (4800 Hours)	201 Day (4824 Hours)	202 Day (4848 Hours)	203 Day (4872 Hours)	204 Day (4896 Hours)	205 Day (4920 Hours)	206 Day (4944 Hours)	207 Day (4968 Hours)	208 Day (4992 Hours)	209 Day (5016 Hours)	210 Day (5040 Hours)	211 Day (5064 Hours)	212 Day (5088 Hours)	213 Day (5112 Hours)	214 Day (5136 Hours)	215 Day (5160 Hours)	216 Day (5184 Hours)	217 Day (5208 Hours)	218 Day (5232 Hours)	219 Day (5256 Hours)	220 Day (5280 Hours)	221 Day (5304 Hours)	222 Day (5328 Hours)	223 Day (5352 Hours)	224 Day (5376 Hours)	225 Day (5400 Hours)	226 Day (5424 Hours)	227 Day (5448 Hours)	228 Day (5472 Hours)	229 Day (5496 Hours)	230 Day (5520 Hours)	231 Day (5544 Hours)	232 Day (5568 Hours)	233 Day (5592 Hours)	234 Day (5616 Hours)	235 Day (5640 Hours)	236 Day (5664 Hours)	237 Day (5688 Hours)	238 Day (5712 Hours)	239 Day (5736 Hours)	240 Day (5760 Hours)	241 Day (5784 Hours)	242 Day (5808 Hours)	243 Day (5832 Hours)	244 Day (5856 Hours)	245 Day (5880 Hours)	246 Day (5904 Hours)	247 Day (5928 Hours)	248 Day (5952 Hours)	249 Day (5976 Hours)	250 Day (6000 Hours)	251 Day (6024 Hours)	252 Day (6048 Hours)	253 Day (6072 Hours)	254 Day (6096 Hours)	255 Day (6120 Hours)	256 Day (6144 Hours)	257 Day (6168 Hours)	258 Day (6192 Hours)	259 Day (6216 Hours)	260 Day (6240 Hours)	261 Day (6264 Hours)	262 Day (6288 Hours)	263 Day (6312 Hours)	264 Day (6336 Hours)	265 Day (6360 Hours)	266 Day (6384 Hours)	267 Day (6408 Hours)	268 Day (6432 Hours)	269 Day (6456 Hours)	270 Day (6480 Hours)	271 Day (6504 Hours)	272 Day (6528 Hours)	273 Day (6552 Hours)	274 Day (6576 Hours)	275 Day (6600 Hours)	276 Day (6624 Hours)	277 Day (6648 Hours)	278 Day (6672 Hours)	279 Day (6696 Hours)	280 Day (6720 Hours)	281 Day (6744 Hours)	282 Day (6768 Hours)	283 Day (6792 Hours)	284 Day (6816 Hours)	285 Day (6840 Hours)	286 Day (6864 Hours)	287 Day (6888 Hours)	288 Day (6912 Hours)	289 Day (6936 Hours)	290 Day (6960 Hours)	291 Day (6984 Hours)	292 Day (7008 Hours)	293 Day (7032 Hours)	294 Day (7056 Hours)	295 Day (7080 Hours)	296 Day (7104 Hours)	297 Day (7128 Hours)	298 Day (7152 Hours)	299 Day (7176 Hours)	300 Day (7200 Hours)	301 Day (7224 Hours)	302 Day (7248 Hours)	303 Day (7272 Hours)	304 Day (7296 Hours)	305 Day (7320 Hours)	306 Day (7344 Hours)	307 Day (7368 Hours)	308 Day (7392 Hours)	309 Day (7416 Hours)	310 Day (7440 Hours)	311 Day (7464 Hours)	312 Day (7488 Hours)	313 Day (7512 Hours)	314 Day (7536 Hours)	315 Day (7560 Hours)	316 Day (7584 Hours)	317 Day (7608 Hours)	318 Day (7632 Hours)	319 Day (7656 Hours)	320 Day (7680 Hours)	321 Day (7704 Hours)	322 Day (7728 Hours)	323 Day (7752 Hours)	324 Day (7776 Hours)	325 Day (7800 Hours)	326 Day (7824 Hours)	327 Day (7848 Hours)	328 Day (7872 Hours)	329 Day (7896 Hours)	330 Day (7920 Hours)	331 Day (7944 Hours)	332 Day (7968 Hours)	333 Day (7992 Hours)	334 Day (8016 Hours)	335 Day (8040 Hours)	336 Day (8064 Hours)	337 Day (8088 Hours)	338 Day (8112 Hours)	339 Day (8136 Hours)	340 Day (8160 Hours)	341 Day (8184 Hours)	342 Day (8208 Hours)	343 Day (8232 Hours)	344 Day (8256 Hours)	345 Day (8280 Hours)	346 Day (8304 Hours)	347 Day (8328 Hours)	348 Day (8352 Hours)	349 Day (8376 Hours)	350 Day (8400 Hours)	351 Day (8424 Hours)	352 Day (8448 Hours)	353 Day (8472 Hours)	354 Day (8496 Hours)	355 Day (8520 Hours)	356 Day (8544 Hours)	357 Day (8568 Hours)	358 Day (8592 Hours)	359 Day (8616 Hours)	360 Day (8640 Hours)	361 Day (8664 Hours)	362 Day (8688 Hours)	363 Day (8712 Hours)	364 Day (8736 Hours)	365 Day (8760 Hours)	366 Day (8784 Hours)	367 Day (8808 Hours)	368 Day (8832 Hours)	369 Day (8856 Hours)	370 Day (8880 Hours)	371 Day (8904 Hours)	372 Day (8928 Hours)	373 Day (8952 Hours)	374 Day (8976 Hours)	375 Day (9000 Hours)	376 Day (9024 Hours)	377 Day (9048 Hours)	378 Day (9072 Hours)	379 Day (9096 Hours)	380 Day (9120 Hours)	381 Day (9144 Hours)	382 Day (9168 Hours)	383 Day (9192 Hours)	384 Day (9216 Hours)	385 Day (9240 Hours)	386 Day (9264 Hours)	387 Day (9288 Hours)	388 Day (9312 Hours)	389 Day (9336 Hours)	390 Day (9360 Hours)	391 Day (9384 Hours)	392 Day (9408 Hours)	393 Day (9432 Hours)	394 Day (9456 Hours)	395 Day (9480 Hours)	396 Day (9504 Hours)	397 Day (9528 Hours)	398 Day (9552 Hours)	399 Day (9576 Hours)	400 Day (9600 Hours)	401 Day (9624 Hours)	402 Day (9648 Hours)	403 Day (9672 Hours)	404 Day (9696 Hours)	405 Day (9720 Hours)	406 Day (9744 Hours)	407 Day (9768 Hours)	408 Day (9792 Hours)	409 Day (9816 Hours)	410 Day (9840 Hours)	411 Day (9864 Hours)	412 Day (9888 Hours)	413 Day (9912 Hours)	414 Day (9936 Hours)	415 Day (9960 Hours)	416 Day (9984 Hours)	417 Day (10008 Hours)	418 Day (10032 Hours)	419 Day (10056 Hours)	420 Day (10080 Hours)	421 Day (10104 Hours)	422 Day (10128 Hours)	423 Day (10152 Hours)	424 Day (10176 Hours)	425 Day (10200 Hours)	426 Day (10224 Hours)	427 Day (10248 Hours)	428 Day (10272 Hours)	429 Day (10296 Hours)	430 Day (10320 Hours)	431 Day (10344 Hours)	432 Day (10368 Hours)	433 Day (10392 Hours)	434 Day (10416 Hours)	435 Day (10440 Hours)	436 Day (10464 Hours)	437 Day (10488 Hours)	438 Day (10512 Hours)	439 Day (10536 Hours)	440 Day (10560 Hours)	441 Day (10584 Hours)	442 Day (10608 Hours)	443 Day (10632 Hours)	444 Day (10656 Hours)	445 Day (10680 Hours)	446 Day (10704 Hours)	447 Day (10728 Hours)	448 Day (10752 Hours)	449 Day (10776 Hours)	450 Day (10800 Hours)	451 Day (10824 Hours)	452 Day (10848 Hours)	453 Day (10872 Hours)	454 Day (10896 Hours)	455 Day (10920 Hours)	456 Day (10944 Hours)	457 Day (10968 Hours)	458 Day (10992 Hours)	459 Day (11016 Hours)	460 Day (11040 Hours)	461 Day (11064 Hours)	462 Day (11088 Hours)	463 Day (11112 Hours)	464 Day (11136 Hours)	465 Day (11160 Hours)	466 Day (11184 Hours)	467 Day (11208 Hours)	468 Day (11232 Hours)	469 Day (11256 Hours)	470 Day (11280 Hours)	471 Day (11304 Hours)	472 Day (11328 Hours)	473 Day (11352 Hours)	474 Day (11376 Hours)	475 Day (11400 Hours)	476 Day (11424 Hours)	477 Day (11448 Hours)	478 Day (11472 Hours)	479 Day (11496 Hours)	480 Day (11520 Hours)	481 Day (11544 Hours)	482 Day (11568 Hours)	483 Day (11592 Hours)	484 Day (11616 Hours)	485 Day (11640 Hours)	486 Day (11664 Hours)	487 Day (11688 Hours)	488 Day (11712 Hours)	489 Day (11736 Hours)	490 Day (11760 Hours)	491 Day (11784 Hours)	492 Day (11808 Hours)	493 Day (11832 Hours)	494 Day (11856 Hours)	495 Day (11880 Hours)	496 Day (11904 Hours)	497 Day (11928 Hours)	498 Day (11952 Hours)	499 Day (11976 Hours)	500 Day (12000 Hours)	501 Day (12024 Hours)	502 Day (12048 Hours)	503 Day (12072 Hours)	504 Day (12096 Hours)	505 Day (12120 Hours)	506 Day (12144 Hours)	507 Day (12168 Hours)	508 Day (12192 Hours)	509 Day (12216 Hours)	510 Day (12240 Hours)	511 Day (12264 Hours)	512 Day (12288 Hours)	513 Day (12312 Hours)	514 Day (12336 Hours)	515 Day (12360 Hours)	516 Day (12384 Hours)	517 Day (12408 Hours)	518 Day (12432 Hours)	519 Day (12456 Hours)	520 Day (12480 Hours)	521 Day (12504 Hours)	522 Day (12528 Hours)	523 Day (12552 Hours)	524 Day (12576 Hours)	525 Day (12600 Hours)	526 Day (12624 Hours)	527 Day (12648 Hours)	528 Day (12672 Hours)	529 Day (12696 Hours)	530 Day (12720 Hours)	531 Day (12744 Hours)	532 Day (12768 Hours)	533 Day (12792 Hours)	534 Day (12816 Hours)	535 Day (12840 Hours)	536 Day (12864 Hours)	537 Day (12888 Hours)	538 Day (12912 Hours)	539 Day (12936 Hours)	540 Day (12960 Hours)	541 Day (12984 Hours)	542 Day (13008 Hours)	543 Day (13032 Hours)	544 Day (13056 Hours)	545 Day (13080 Hours)	546 Day (13104 Hours)	547 Day (13128 Hours)	548 Day (13152 Hours)	549 Day (13176 Hours)	550 Day (13200 Hours)	551 Day (13224 Hours)	552 Day (13248 Hours)	553 Day (13272 Hours)	554 Day (13296 Hours)	555 Day (13320 Hours)	556 Day (13344 Hours)	557 Day (13368 Hours)	558 Day (13392 Hours)	559 Day (13416 Hours)	560 Day (13440 Hours)	561 Day (13464 Hours)	562 Day (13488 Hours)	563 Day (13512 Hours)	564 Day (13536 Hours)	565 Day (13560 Hours)	566 Day (13584 Hours)	567 Day (13608 Hours)	568 Day (13632 Hours)	569 Day (13656 Hours)	570 Day (13680 Hours)	571 Day (13704 Hours)	572 Day (13728 Hours)	573 Day (13752 Hours)	574 Day (13776 Hours)	575 Day (13800 Hours)	576 Day (13824 Hours)	577 Day (13848 Hours)	578 Day (13872 Hours)	579 Day (13896 Hours)	580 Day (13920 Hours)	581 Day (13944 Hours)	582 Day (13968 Hours)	583 Day (13992 Hours)	584 Day (14016 Hours)	585 Day (14040 Hours)	586 Day (14064 Hours)	587 Day (14088 Hours)	588 Day (14112 Hours)	589 Day (14136 Hours)	590 Day (14160 Hours)	591 Day (14184 Hours)	592 Day (14208 Hours)	593 Day (14232 Hours)	594 Day (14256 Hours)	595 Day (14280 Hours)	596 Day (14304 Hours)	597 Day (14328 Hours)	598 Day (14352 Hours)	599 Day (14376 Hours)	600 Day (14400 Hours)	601 Day (14424 Hours)	602 Day (14448 Hours)	603 Day (14472 Hours)	604 Day (14496 Hours)	605 Day (14520 Hours)	606 Day (14544 Hours)	607 Day (14568 Hours)	608 Day (14592 Hours)	609 Day (14616 Hours)	610 Day (14640 Hours)	611 Day (14664 Hours)	612 Day (14688 Hours)	613 Day (14712 Hours)	614 Day (14736 Hours)	615 Day (14760 Hours)	616 Day (14784 Hours)	617 Day (14808 Hours)	618 Day (14832 Hours)	619 Day (14856 Hours)	620 Day (14880 Hours)	621 Day (14904 Hours)	622 Day (14928 Hours)	623 Day (14952 Hours)	624 Day (14976 Hours)	625 Day (15000 Hours)	626 Day (15024 Hours)	627 Day (15048 Hours)	628 Day (15072 Hours)	629 Day (15096 Hours)	630 Day (15120 Hours)	631 Day (15144 Hours)	632 Day (15168 Hours)	633 Day (15192 Hours)	634 Day (15216 Hours)	635 Day (15240 Hours)	636 Day (15264 Hours)	637 Day (15288 Hours)	638 Day (15312 Hours)	639 Day (15336 Hours)	640 Day (15360 Hours)	641 Day (15384 Hours)	642 Day (15408 Hours)	643 Day (15432 Hours)	644 Day (15456 Hours)	645 Day (15480 Hours)	646 Day (15504 Hours)	647 Day (15528 Hours)	648 Day (15552 Hours)	649 Day (15576 Hours)	650 Day (15600 Hours)	651 Day (15624 Hours)	652 Day (15648 Hours)	653 Day (15672 Hours)	654 Day (15696 Hours)	655 Day (15720 Hours)	656 Day (15744 Hours)	657 Day (15768 Hours)	658 Day (15792 Hours)	659 Day (15816 Hours)	660 Day (15840 Hours)	661 Day (15864 Hours)	662 Day (15888 Hours)	663 Day (15912 Hours)	664 Day (15936 Hours)	665 Day (15960 Hours)	666 Day (15984 Hours)	667 Day (16008 Hours)	668 Day (16032 Hours)	669 Day (16056 Hours)	670 Day (16080 Hours)	671 Day (16104 Hours)	672 Day (16128 Hours)	673 Day (16152 Hours)	674 Day (16176 Hours)	675 Day (16200 Hours)	676 Day (16224 Hours)	677 Day (16248 Hours)	678 Day (16272 Hours)	679 Day (16296 Hours)	680 Day (16320 Hours)	681 Day (16344 Hours)	682 Day (16368 Hours)	683 Day (16392 Hours)	684 Day (16416 Hours)	685 Day (16440 Hours)	686 Day (16464 Hours)	687 Day (16488 Hours)	688 Day (16512 Hours)	689 Day (16536 Hours)	690 Day (16560 Hours)	691 Day (16584 Hours)	692 Day (16608 Hours)	693 Day (16632 Hours)	694 Day (16656 Hours)	695 Day (16680 Hours)	696 Day (16704 Hours)	697 Day (16728 Hours)	698 Day (16752 Hours)	699 Day (16776 Hours)	700 Day (16800 Hours)	701 Day (16824 Hours)	702 Day (16848 Hours)	703 Day (16872 Hours)	704 Day (16896 Hours)	705 Day (16920 Hours)	706 Day (16944 Hours)	707 Day (16968 Hours)	708 Day (16992 Hours)	709 Day (17016 Hours)	710 Day (17040 Hours)	711 Day (17064 Hours)	712 Day (17088 Hours)	713 Day (17112 Hours)	714 Day (17136 Hours)	715 Day (17160 Hours)	716 Day (17184 Hours)	717 Day (17208 Hours)	718 Day (17232 Hours)	719 Day (17256 Hours)	720 Day (17280 Hours)	721 Day (17304 Hours)	722 Day (17328 Hours)	723 Day (17352 Hours)	724 Day (17376 Hours)	725 Day (17400 Hours)	726 Day (17424 Hours)	727 Day (17448 Hours)	728 Day (17472 Hours)	729 Day (17496 Hours)	730 Day (17520 Hours)	731 Day (17544 Hours)	732 Day (17568 Hours)	733 Day (17592 Hours)	734 Day (17616 Hours)	735 Day (17640 Hours)	736 Day (17664 Hours)	737 Day (17688 Hours)	738 Day (17712 Hours)	739 Day (17736 Hours)	740 Day (17760 Hours)	741 Day (17784 Hours)	742 Day (17808

Attachment C

PSPS Activation Customer Notification Messaging

20200731 PSPS Activation: Customer Notifications Messaging

Friday, July 31 – Tejon – (2 day)

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions **may result in SCE turning off your power**. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit [sce.com/psps](https://www.sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit [sce.com/psps](https://www.sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Initial Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Saturday, August 1 – Tejon (1 day)

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. **These conditions may result in SCE turning off your power.** SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Update Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Sunday, August 2 – Toll (2 day)

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Initial Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Sunday, August 2 - Tejon (Day Of)

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. **These conditions may result in SCE turning off your power.** SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Update Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Sunday, August 2 - Tejon – RAR2183 – 17 customers – Imminent De-energized

Voice/ Voice Mail/TTY:

This an important safety message from Southern California Edison. Due to forecast fire weather conditions, **SCE may proactively turn off power within the next 1 to 4 hours** for a Public Safety Power Shutoff to the ^city_variable^ area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve. For more information, please visit sce.com/psps.
Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city_variable^ area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve. For more information, please visit sce.com/psps.
Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Imminent Shutoff Notice

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city_variable^ area ^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve.

The following address(es) may be affected:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps.
Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Tejon RAR2183 – 17 Customers – De-energized

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to the ^city_variable^ area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Southern California Edison has proactively turned off power to the ^city_variable^ area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Notification

From: do_not_reply@scewebservices.com

Southern California Edison

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to your area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change.

The following address(es) may be affected:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

Monday, August 3

Tejon RAR1316 – 154 customers – Preparing to re-energize

Email/Text/Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. SCE will soon begin the process of inspecting electrical lines in the **^city variable^** area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Toll – All Clear

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to improved fire weather conditions, the **^city_variable^** area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to improved fire weather conditions, the **^city_variable^** area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Avoided Shutoff Notice

From: [do not reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

Due to improved fire weather conditions, the **^city_variable^** area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service.

The following address(es) have been removed:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information please visit our website at www.sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

Tejon RAR2183 - 17 customers - Preparing to re-energize

Email/Text/Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Toll – All Clear

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Avoided Shutoff Notice

From: do_not_reply@scewebservices.com

Southern California Edison

Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service.

The following address(es) have been removed:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information please visit our website at www.sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

Tejon RAR2183 14 customers – Re-energized

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

Text/SMS:

SCE Safety Alert: Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Restoration Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored.

The following address(es) have been restored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

Thank You,

Southern California Edison

Tejon 470 customers – Update

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more

information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Initial Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Tuesday, August 4

Tejon PS1252 1 customer 3 meters – Prepare to Energize

Email/Text/Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's

restoration process, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Toll – All Clear

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Avoided Shutoff Notice

From: do_not_reply@scewebservices.com

Southern California Edison

Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service.

The following address(es) have been removed:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information please visit our website at www.sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

Tejon – All Clear

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Avoided Shutoff Notice

From: do_not_reply@scewebservices.com

Southern California Edison

Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service.

The following address(es) have been removed:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information please visit our website at www.sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison