



Diana S. Gallegos  
State Regulatory Affairs  
diana.s.genasci@sce.com

November 12, 2020

Leslie Palmer, Director  
Safety Enforcement Division  
California Public Utilities Commission  
505 Van Ness Avenue  
San Francisco, CA 94102

**SUBJECT: SCE PSPS Post Event Report - October 23 to October 28, 2020**

Dear Director Palmer:

Southern California Edison (SCE) respectfully submits the attached report in compliance with the Public Safety Power Shutoff (PSPS) Post Event Reporting requirements regarding its PSPS event that began October 23, 2020 and ended October 28, 2020.

This report has been verified by an Officer of SCE in accordance with Rule 1.11 of the Commission's Rules of Practice and Procedure.

Sincerely,

DocuSigned by:  
*Diana S. Gallegos*  
29E9CB7BDB43475...

Diana S. Gallegos  
Sr. Advisor, State Regulatory Affairs

cc: [ESRB\\_CompplianceFilings@cpuc.ca.gov](mailto:ESRB_CompplianceFilings@cpuc.ca.gov)

**Southern California Edison  
Public Safety Power Shutoff Protocol (PSPS)  
Post-Event Reporting in Compliance with Resolution  
ESRB-8 and PSPS OIR Phase 1 & 2 Requirements  
October 23 to October 28, 2020**

**Submitted to:  
California Public Utilities Commission  
Director of the Safety and Enforcement Division  
November 12, 2020**

## **Executive Summary**

On October 23, 2020, Southern California Edison (SCE) activated a hybrid<sup>1</sup> Incident Management Team (IMT) to manage forecasted increased fire danger conditions that included Santa Ana winds forecasted by SCE meteorologists and the National Weather Service in Fresno, Los Angeles, Orange, San Bernardino, Riverside, and Ventura counties, which were initially forecast to impact the SCE service territory at approximately 9:00 am on October 26 and continue into October 27. However, on October 26, hazardous weather conditions, including wind up to 96 mph as measured by weather stations in Valencia, developed several hours ahead of the forecast of 9 am. This unexpected onset of extreme weather required immediate use of PSPS to maintain public safety beginning at approximately 6:23 am on October 26.<sup>2</sup> During this event, SCE also de-energized circuits not previously forecasted to be in scope for PSPS due to the wind conditions observed by meteorologists and weather stations in Los Angeles, San Bernardino, and Orange counties.

Ultimately, SCE pro-actively de-energized 36,307 customers in areas of Kern, Ventura, Los Angeles, San Bernardino, Orange, and Riverside counties. Power was restored to all pro-actively de-energized customers on October 28 by 3:24 pm, except for 986 customers on the Atento and Taiwan circuits within Orange County that were affected by the Silverado Fire as detailed below in this report.

SCE submits this report to demonstrate its compliance with the directives of Resolution ESRB-8 and the California Public Utilities Commission (CPUC or Commission) PSPS Order to Institute Rulemaking (OIR) Phase 1 (Decision (D.) 19-05-042) and Phase 2 (D.20-05-051) requirements associated with PSPS events. This report explains SCE's decision to call, sustain, and conclude a de-energization event and provides both a summary of the event and the responses to the post-event questions as required by the Commission.

SCE appreciates that PSPS de-energizations pose significant challenges and hardships for its customers and the Public Safety Partners that provide vital services to our communities. SCE recognizes that this is particularly true when the unexpected onset of dangerous weather and fuel conditions requires that SCE take actions quickly and without all the advance notifications contemplated by the CPUC. SCE's decision to activate its PSPS protocol is based on careful consideration of multiple factors, including forecasted weather, fuel conditions, and impacts to Public Safety Partners and the communities we serve. Because SCE takes seriously its responsibilities and understands the impacts of de-energization events, SCE only uses PSPS de-energization when it believes that there are no other reasonable alternatives to mitigate identified risks to public safety that would result from catastrophic wildfire.

SCE remains committed to continuously improving its processes and welcomes input from its customers, Public Safety Partners, community representatives, and local governments on ways we can work together to enhance the existing processes, improve communication and coordination amongst impacted entities, and minimize the impact of PSPS events on all stakeholders.

---

<sup>1</sup> SCE's IMT operated both remotely and in-person at the SCE Emergency Operations Center (EOC).

<sup>2</sup> There were also wind-related outages in SCE service territory that were not caused by PSPS de-energizations that are not included in this report.

SCE took the following actions to manage its response during the PSPS event:

1. Activated a dedicated PSPS IMT to coordinate response operations associated with the potential use of PSPS to maintain public safety. The IMT was activated and utilized a hybrid approach of remote and in-person response in adherence with COVID-19 protocols.
2. Utilized ES IMT resources activated under the Incident Support Team for the Silverado Fire restorations to perform restoration activities on the Atento and Taiwan circuits
3. Reached out to the Geographical Coordination Center (GACC)<sup>3</sup> to coordinate regarding its expectation for fire potential over the course of the PSPS event.
4. Provided notifications Public Safety Partners, critical infrastructure providers, the CPUC, the California Department of Forestry and Fire Protection (CAL FIRE), the California Governor's Office of Emergency Services (Cal OES), and affected SCE customers. Additionally, SCE provided notices Community-Based Organizations (CBOs), such as Independent Living Centers (ILCs), the American Red Cross, 2-1-1, and Fire Safety Councils.
5. Initiated operating restrictions on impacted circuits, as applicable.
6. Performed field patrols of impacted circuits where possible in preparation for the potential use of PSPS.
7. Opened Community Resource Centers (CRCs) and deployed Community Crew Vehicles (CCVs) to impacted communities.
8. Performed live field observations of monitored circuits as required during the period of concern to validate actual weather conditions and the need for the use of PSPS for de-energization.
9. Performed post patrols to verify no damage to de-energized circuits in support of restoration activities.

---

<sup>3</sup> The GACC is the physical location of an interagency, regional operation center for the effective coordination, mobilization, and demobilization of emergency management resources. A coordination center serves federal, state and local wildland fire agencies through logistical coordination of resources throughout the geographic area, and with other geographic areas, as well.

## **Event Summary October 22 to October 28, 2020<sup>4</sup>**

October 22<sup>nd</sup> -- SCE's weather services team notified SCE's Business Resiliency Duty Manager (BRDM) of a weather system that was forecast to bring Santa Ana winds and low humidity levels for most of the SCE territory beginning October 26 and continuing through October 27. The decision was made to activate the PSPS IMT on October 23 at 10:00 am. Initially, SCE identified 64 distribution circuits and approximately 82,675 customers in scope for the potential PSPS event.

October 23<sup>rd</sup> -- SCE sent the CPUC an email at 10 am to communicate activation of the Public Safety Power Shut Off Incident Management Team (PSPS IMT). SCE also held a State Executive call at 2:00 pm, and an OEM County Coordination call at 3:00 pm to communicate the weather forecast, potential customers in scope and answer any questions regarding the PSPS event. SCE sent notifications to public safety partners and critical infrastructure providers at 1:40 pm with respect to circuits projected to be in scope for the event. SCE also dispatched pre-patrol resources to begin inspecting circuits in scope for the PSPS event.

October 24<sup>th</sup> -- SCE held its daily State Executive call at 2:00 pm, and an OEM County Coordination call at 3:00 pm to communicate the weather forecast, customers in scope and answer any questions regarding the PSPS event. SCE emailed the CPUC after the daily calls to provide the briefing material shared during the 2:00 pm call. SCE sent notifications to public safety partners at 3:07 pm, critical infrastructure customers at 8:07 pm, and customers at 8:29 pm with respect to circuits projected to be in scope for the event. At that point, weather forecasts indicated that up to 48 circuits and approximately 61,854 customers were potentially in scope for de-energization during the period of concern on October 26 through October 27.

October 25<sup>th</sup> -- SCE weather forecasts predicted strong Santa Ana winds starting on the morning of October 26 through October 27 impacting portions of Kern, Los Angeles, Orange, San Bernardino, Riverside, and Ventura counties. Although there had been cooler weather, light precipitation, and high humidity on October 24, this was not enough to dampen the fire potential forecast for Monday through Tuesday. Fuels in the forecasted PSPS areas were expected to dry out significantly by late Monday morning, establishing the period of concern beginning at 9:00 am, Monday, October 28. SCE provided an event update by email to the CPUC at 3:27 pm. SCE held its daily State Executive call at 2:00 pm, and an OEM County Coordination call at 3:00 pm. SCE sent notifications to public safety partners at 1:12 pm, critical infrastructure providers at 1:12 pm, and customers at 9:02 pm with respect to circuits projected to be in scope for the event. At that point, weather forecasts indicated that up to 55 circuits and approximately 71,068 customers were potentially in scope for de-energization during the period of concern on October 26 through October 27.

October 26<sup>th</sup> -- Although prior weather forecasts indicated the period of concern on October 26 beginning at 9:00 am, at approximately 6:00 am, the PSPS IMT began observing high wind speeds on SCE weather stations in Los Angeles, San Bernardino, and Orange counties that indicated early onset of dangerous weather conditions. For example, weather stations in the Valencia area measured wind speeds of up to 96 mph. Given the unanticipated early onset of these dangerous weather conditions,

---

<sup>4</sup> The following event summary serves to provide an overview of the event. Additional details regarding specific PSPS requirements are addressed in further detail after this narrative.

the Incident Commander gave approval to start pro-active de-energization, with the actual first de-energization completed at 6:23 am on October 26. As a result, some customers did not receive imminent de-energization notification. Additionally, three circuits not originally in scope for the period of concern were de-energized when weather services advised that these circuits were exceeding wind and FPI thresholds. Details related to these circuits can be found in the table on page 6.

SCE provided an event update to the CPUC at 12:33 pm to notify of the de-energization of these circuits within Los Angeles, Orange, and San Bernardino County. SCE held its daily State Executive call at 2:00 pm, and an OEM County Coordination call at 3:00 pm to provide updates and address questions and/or concerns. As hazardous weather conditions subsided and the period of concern for circuits started ending that afternoon, SCE began sending imminent notifications of re-energization to public safety partners, critical infrastructure, and customers and started patrols for circuit restoration, ultimately restoring power to 10 circuits as detailed in the table on page 6.

October 27<sup>th</sup> -- At approximately 9:30am, SCE pro-actively de-energized an additional 2 circuits not originally forecasted to be in scope for the period of concern when weather services advised that both circuits were exceeding wind and FPI thresholds. Due to the rapid onset of these conditions, although SCE was not able to provide all advance notifications, SCE provided notice of imminent de-energization, imminent re-energization, and re-energization as detailed on page 9 of this report. The IMT continued to actively monitor weather developments, patrol de-energized circuits for possible restoration, and was able to restore circuits throughout the day. In total, SCE re-energized 32 circuits as detailed in the table on page 6.

SCE sent an update to the CPUC at 6:29 am to provide notice of the customers impacted by the PSPS de-energization broken down by county, and again at 5:10 pm to provide an update on restoration efforts and communicate the end of the period of concern. SCE held its daily State Executive call at 2:00 pm, and an OEM County Coordination call at 3:00 pm to provide updates on the end of the period of concern, intent to patrol lines as weather conditions permitted for the restoration of the remaining circuits, and address any questions and/or concerns.

October 28<sup>th</sup> -- SCE continued to perform post-event patrols and, after providing notice of imminent re-energization, restored power to 11 circuits by 3:24 pm. As circuits were re-energized, SCE provided imminent re-energization notifications throughout the day as detailed on page 9 of this report. SCE was unable to restore power to 2 circuits, Atento and Taiwan, which experienced impacts from the Silverado Fire and had access restrictions imposed by Orange County Fire Authority. Restoration of these circuits was transferred to the ES IMT managing the Silverado Fire on October 28. Both the Atento and Taiwan circuits were restored on 10/29.

The following responses address how SCE complied with all applicable PSPS regulatory requirements, including ESRB-8 and the Phase 1 (D. 19-05-042) and Phase 2 (D. 20-05-051) decisions, during this event.

### 1. The time, place and duration of the power shutoff event

This event started at 6:23 am on Monday, October 26, and continued through Wednesday, October 28 at 3:24 pm. The event impacted portions of Kern, Ventura, Los Angeles, San Bernardino, Orange, and Riverside counties. The table below provides the timeline for de-energization and restoration for all impacted circuits. Circuits that SCE could not fully restore within 24 hours of being cleared to begin patrol and restoration are denoted with a red asterisk and an explanation of the delay can be found on page 11 of this report.

#### De-Energization/Re-Energization Circuit Timeline

Circuit	Isolation Device <sup>5</sup>	De-Energized Date/Military Time	Customers Affected	Re-Energized <sup>6</sup> (1 <sup>st</sup> load) Date/Military Time	Re-Energized (All load) Date/Military Time
ACOSTA	RAR0800	10/26/2020 8:22	5	N/A	10/28/2020 8:34
ACOSTA	CB	10/26/2020 9:00	783	N/A	10/27/2020 13:36
AMETHYST	RCS2301	10/26/2020 11:08	630	N/A	10/27/2020 12:46
ANTON	RAR1992	10/26/2020 9:27	20	10/26/2020 18:55	10/26/2020 20:08
ANTON	RAR0217	10/26/2020 9:29	117	N/A	10/27/2020 2:23
ATENTO*	RCS3995	10/26/2020 10:12	901	N/A	10/28/2020 7:30
AVANTI	CB	10/26/2020 8:55	1581	10/27/2020 12:31	10/27/2020 12:54
BEAR VALLEY	RAR0244	10/26/2020 8:15	30	10/28/2020 9:41	10/28/2020 9:53
BEAR VALLEY	CB	10/26/2020 10:24	0	N/A	10/28/2020 9:37
BIG ROCK	RAR0104	10/26/2020 9:32	2839	N/A	10/27/2020 1:03
BLACKHILLS	RCS2491	10/27/2020 9:21	926	N/A	10/27/2020 17:40
BLACKHILLS	RCS2491	10/27/2020 9:21	926	N/A	10/27/2020 17:40
BLUE CUT	CB	10/26/2020 8:57	300	10/27/2020 19:59	10/27/2020 18:03
BOOTLEGGER	RAR7203	10/26/2020 7:01	577	10/27/2020 10:29	10/27/2020 10:35
BOOTLEGGER	CB	10/26/2020 8:09	1002	10/27/2020 10:25	10/27/2020 10:40
CABANA	CB	10/26/2020 8:35	2366	10/27/2020 3:55	10/27/2020 3:58
CALSTATE	CB	10/26/2020 7:46	605	10/26/2020 9:47	10/27/2020 13:49
CAMP ANGELUS	CB	10/26/2020 8:15	308	N/A	10/28/2020 10:02
CAMP BALDY*	CB	10/26/2020 7:19	154	10/27/2020 19:49	10/28/2020 14:29
CANEBRAKE	RAR0621	10/26/2020 11:08	375	10/26/2020 17:56	10/26/2020 18:34
CLUB OAKS	RCS0825	10/26/2020 12:45	0	N/A	10/27/2020 16:10
COOLER	RCS4314	10/26/2020 11:18	3	N/A	10/27/2020 16:16
DAVENPORT	RAR6564	10/26/2020 7:22	429	10/26/2020 19:10	10/26/2020 19:12
DAVENPORT	RAR0050	10/26/2020 11:09	332	10/26/2020 17:16	10/26/2020 18:52
DEMILLE	CB	10/26/2020 8:38	243	10/26/2020 22:15	10/26/2020 22:19

<sup>5</sup> Remote Automatic Recloser (RAR) and Circuit Breaker (CB) denote different types of sectionalizing devices used by SCE

<sup>6</sup>1<sup>st</sup> load identifies if the circuit was re-energized in sections based on pre-patrols and weather conditions permitting re-energization of the entire line, All Load identifies when the entire circuit was re-energized.

Circuit	Isolation Device <sup>5</sup>	De-Energized Date/Military Time	Customers Affected	Re-Energized <sup>6</sup> (1 <sup>st</sup> load) Date/Military Time	Re-Energized (All load) Date/Military Time
ECHO	RAR0826	10/26/2020 7:58	117	N/A	10/27/2020 5:20
ENERGY	RAR0012	10/26/2020 6:46	37	10/26/2020 19:00	10/27/2020 11:02
ENERGY	RAR0490	10/26/2020 10:19	812	10/26/2020 18:05	10/26/2020 18:05
FERRARA	RAR0054	10/26/2020 7:19	242	N/A	10/27/2020 19:49
GALENA	RSR6282	10/27/2020 9:36	987	N/A	10/27/2020 17:04
GOWAN	CB	10/26/2020 11:21	1367	10/27/2020 6:53	10/27/2020 6:55
GALENA	RSR6282	10/27/2020 9:36	987	N/A	10/27/2020 17:04
GUIAR	RAR0402	10/26/2020 9:17	42	10/26/2020 20:36	10/27/2020 11:16
HILLFIELD	CB	10/26/2020 9:38	2373	10/26/2020 18:52	10/26/2020 18:52
ICEHOUSE*	CB	10/26/2020 7:19	12	N/A	10/28/2020 15:02
IMPALA	RCS0646	10/26/2020 7:41	417	10/26/2020 7:42	10/27/2020 18:08
JEEP	CB	10/26/2020 22:36	2066	10/27/2020 15:39	10/27/2020 15:41
JENKS LAKE	CB	10/26/2020 8:15	141	10/28/2020 10:06	10/28/2020 10:15
KICKAPOO TRAIL	RAR0241	10/26/2020 14:24	1019	10/26/2020 20:45	10/26/2020 21:29
KIMDALE	RAR1715	10/26/2020 10:47	411	10/26/2020 18:24	10/26/2020 18:24
LOPEZ	RAR3825	10/26/2020 8:38	146	10/26/2020 19:28	10/26/2020 22:03
LOPEZ	RAR0048	10/26/2020 9:05	22	10/26/2020 19:11	10/26/2020 22:03
LOUCKS	CB	10/26/2020 6:49	55	N/A	10/27/2020 11:39
MACY	CB	10/26/2020 8:57	673	10/27/2020 6:16	10/27/2020 19:05
MODJESKA	P5206529-B	10/26/2020 9:52	0	N/A	10/27/2020 11:12
NEPAL	RCS1803	10/26/2020 12:17	240	10/27/2020 1:11	10/27/2020 1:11
OBSERVATORY	CB	10/26/2020 10:14	5	N/A	10/27/2020 8:53
POWER	CB	10/26/2020 8:57	850	10/27/2020 6:16	10/27/2020 17:48
RED BOX	RAR1484	10/26/2020 6:40	20	N/A	10/28/2020 11:20
RUSTIC*	RAR4668	10/26/2020 8:32	367	10/27/2020 11:59	10/28/2020 12:20
SAND CANYON*	RAR0191	10/26/2020 6:23	9	N/A	10/28/2020 15:24
SAND CANYON	RAR3410	10/26/2020 7:34	134	N/A	10/27/2020 10:16
SHOVEL	RAR3431	10/26/2020 6:49	52	N/A	10/27/2020 11:39
SUTT	RAR0825	10/26/2020 7:24	27	N/A	10/27/2020 17:30
SUTT	CB	10/26/2020 13:23	1810	10/27/2020 14:45	10/27/2020 16:56
SWEETWATER	CB	10/26/2020 8:38	3432	10/27/2020 4:40	10/27/2020 4:42
TAIWAN*	RAR0950	10/26/2020 7:23	74	10/28/2020 12:56	10/28/2020 7:30
TAIWAN*	RAR0919	10/26/2020 11:45	11	10/28/2020 18:10	10/28/2020 7:30
TAPO	RAR6509	10/26/2020 9:19	57	10/26/2020 23:37	10/26/2020 23:37
TWIN LAKES	RCS5233	10/26/2020 9:38	840	10/26/2020 20:26	10/26/2020 20:26
VARGAS	RAR0828	10/26/2020 7:28	391	N/A	10/27/2020 12:04
VERDEMONT	CB	10/26/2020 8:57	12	10/27/2020 6:16	10/27/2020 7:56
VIDEO	RAR1716	10/26/2020 10:14	53	N/A	10/27/2020 8:53
WEESHA	CB	10/26/2020 8:15	52	N/A	10/28/2020 10:24
<b>Additional De-Energizations Not Originally in the Period of Concern<sup>7</sup></b>					
GREEN RIVER	CB	10/26/2020 12:10	2011	10/26/2020 22:43	10/26/2020 22:44
MACIEL	RAR6072	10/26/2020 11:42	13	N/A	10/28/2020 11:59
VERA CRUZ	RAR2400	10/26/2020 12:07	27	N/A	10/27/2020 2:38

<sup>7</sup> Given rapid onset of hazardous weather conditions, these circuits did not receive any notification prior to de-energization.

**2. The local communities’ representatives contacted prior to de-energization, the date on which they were contacted, and whether the areas affected by the de-energization are classified as Zone 1, Tier 2, or Tier 3 as per the definition in General Order 95, Rule 21.2<sup>8</sup>**

County	Public Safety Partner	Date	Tier
Los Angeles	County and State public safety and first responder agencies and local governments	10/23	Tier II, Tier III
Ventura	County and State public safety and first responder agencies and local governments	10/23	Tier II, Tier III
San Bernardino	County and State public safety and first responder agencies and local governments	10/23	Tier II, Tier III
Orange	County and State public safety and first responder agencies and local governments	10/23	Tier II, Tier III
Riverside	County and State public safety and first responder agencies and local governments	10/23	Tier II
Kern	County and State public safety and first responder agencies and local governments	10/23	Tier II

**3. If unable to provide customers with notice at least 2 hours prior to the de-energization event, provide an explanation in its report.**

On October 26<sup>th</sup> SCE de-energized the Green River, Maciel, and Vera Cruz circuits without any prior notification as these circuits were not originally forecasted to be in scope for this event. Additionally, some customers did not receive other types of notices as detailed in the table below.

<sup>8</sup>See Attachment A Public Safety Partner Notifications. SCE also contacted other County and State public safety and first responder agencies and local governments for areas that were not de-energized but were within the scope of concern.

Circuits	Imminent Shutdown Notification Date/Time	De-Energized Notification Date/Time	Prepare to Re-Energize Notification Date/Time	Re-Energized Notification Date/Time
ACOSTA	N/A	10/26/2020 9:11	10/27/2020 12:56	10/28/2020 10:43, 10/27/2020 16:56
AMETHYST	10/26/2020 10:52	N/A	10/27/2020 12:33	10/27/2020 21:04
ANTON	10/26/2020 9:00	N/A	10/26/2020 17:41, 10/26/2020 17:37, 10/26/2020 20:59	10/26/2020 21:25
ATENTO	10/26/2020 7:53	10/26/2020 10:41	N/A	N/A
AVANTI	10/26/2020 8:47	10/26/2020 9:48	N/A	10/27/2020 21:05
BEAR VALLEY	N/A	N/A	10/27/2020 11:52	10/28/2020 11:35
BIG ROCK	10/26/2020 7:45	N/A	10/26/2020 23:33	10/27/2020 1:26
BLACKHILLS	N/A	10/27/2020 11:09	10/27/2020 10:02, 10/27/2020 17:29	10/27/2020 20:36
BLUE CUT	10/26/2020 8:29	10/26/2020 10:23	N/A	10/27/2020 19:11, 10/27/2020 13:14
BOOTLEGGER	N/A	10/26/2020 7:24	10/26/2020 19:51	10/26/2020 21:45, 10/27/2020 11:20
CABANA	N/A	N/A	10/27/2020 1:03	10/27/2020 5:18
CALSTATE	N/A	10/26/2020 8:06	10/27/2020 11:57	10/27/2020 16:46
CAMP ANGELUS	N/A	N/A	10/27/2020 11:52	10/28/2020 11:35
CAMP BALDY	N/A	10/26/2020 7:38	10/27/2020 13:20, 10/27/2020 13:22	10/28/2020 15:22, 10/27/2020 20:42, 10/27/2020 20:32
CANEBRAKE	10/26/2020 10:37	N/A	10/26/2020 16:52	10/26/2020 19:35
CLUB OAKS	N/A	N/A	10/27/2020 12:56	10/27/2020 19:08
COOLER	N/A	N/A	10/26/2020 21:39	10/27/2020 20:55
DAVENPORT	N/A	10/26/2020 7:46	10/26/2020 16:26, 10/26/2020 18:07	N/A
DE MILLE	10/26/2020 8:12	10/26/2020 8:59, 10/26/2020 9:15	10/26/2020 18:07	N/A
ECHO	N/A	10/26/2020 8:15	10/26/2020 23:00	10/27/2020 21:18
ENERGY	N/A	10/26/2020 7:12	10/26/2020 17:21	10/27/2020 12:29
FERRARA	N/A	10/26/2020 7:38	10/27/2020 13:22	10/27/2020 20:32
GALENA	N/A	10/27/2020 11:11	10/27/2020 10:07, 10/27/2020 12:49	10/27/2020 11:05, 10/27/2020 17:25

Circuits	Imminent Shutdown Notification Date/Time	De-Energized Notification Date/Time	Prepare to Re-Energize Notification Date/Time	Re-Energized Notification Date/Time
GUITAR	10/26/2020 7:51	N/A	10/26/2020 17:58	10/27/2020 11:59
HILLFIELD	N/A	N/A	10/26/2020 17:58	10/27/2020 21:32
ICEHOUSE	N/A	10/26/2020 7:38	10/27/2020 13:22	10/28/2020 15:22, 10/27/2020 20:32
IMPALA	N/A	10/26/2020 8:32	10/27/2020 12:49	10/27/2020 19:14
JENKS LAKE	N/A	N/A	10/27/2020 11:52	10/28/2020 11:35
KICKAPOO TRAIL	10/26/2020 8:54	N/A	10/26/2020 19:39	10/26/2020 21:45
KIMDALE	10/26/2020 13:14	N/A	10/26/2020 17:28	N/A
LOPEZ	10/26/2020 8:12	10/26/2020 8:59, 10/26/2020 9:15	10/26/2020 18:07	N/A
LOUCKS	N/A	N/A	10/26/2020 16:26	N/A
MACY	N/A	10/26/2020 10:23	N/A	10/27/2020 13:14
MODJESKA	N/A	N/A	10/26/2020 21:10	N/A
NEPAL	10/26/2020 8:17	10/26/2020 12:45	N/A	10/27/2020 21:29
OBSERVATORY	N/A	N/A	N/A	10/27/2020 10:38
POWER	N/A	10/26/2020 10:23	N/A	10/27/2020 13:14
RED BOX	10/26/2020 11:36	10/26/2020 7:10	N/A	10/28/2020 11:41
RUSTIC	10/26/2020 8:21	10/26/2020 9:04	10/27/2020 9:53, 10/27/2020 9:54	N/A
SAND CANYON	N/A	10/26/2020 8:02, 10/26/2020 6:54	10/27/2020 10:19, 10/27/2020 17:05	10/27/2020 11:30, 10/28/2020 16:54
SHOVEL	N/A	10/26/2020 7:11	N/A	10/27/2020 13:14
SUTT	N/A	10/26/2020 7:46	10/27/2020 12:28	10/27/2020 20:48
TAIWAN	N/A	10/26/2020 11:05	10/26/2020 16:27, 10/26/2020 16:27	N/A
TAPO	N/A	10/26/2020 8:02	10/26/2020 21:10	10/27/2020 21:30
TWIN LAKES	N/A	N/A	10/26/2020 19:56	N/A
VARGAS	N/A	10/26/2020 8:03	10/27/2020 12:52	10/27/2020 21:08
VIDEO	N/A	N/A	N/A	10/27/2020 10:38
WEESHA	N/A	N/A	10/27/2020 11:52	10/28/2020 11:35

**4. Summarize the number and nature of complaints received as the result of the de-energization event and include claims that are filed due to de-energization.**

As of the submission of this report, no formal complaints were submitted to the Commission or SCE Consumer Affairs. SCE received approximately 147 claims for this event as of November 10, 2020, with most of the claims alleging loss of food. Any complaints/claims received after submission of this report will be added to subsequent reports, as they are received and processed.

SCE received inquiries from the cities of Malibu and Simi Valley, as well as from the Acton Town Council, regarding notifications and other issues. One of the issues that caused confusion during this PSPS event was ongoing storm conditions causing some circuits to relay and de-energize during the same timeframe that other circuits were proactively de-energized due to PSPS events. As an example, Malibu experienced wind outages that were incorrectly messaged as PSPS outages during the event. In addition to questions about notifications, SCE also received questions from the Acton Town Council about SCE's weather forecasting and customer counts. SCE has met with representatives of Malibu and the Acton Town Council to discuss their concerns and will also meet with representatives of Simi Valley.

**5. The timeline for power restoration (re-energization), in addition to the steps taken to restore power as required in Resolution ESRB-8.**

A PSPS event will continue while dangerous fire weather conditions exist, and the threat of a catastrophic wildfire event remains due to these conditions. If circuits are shut off, those circuits and lines will be inspected to ensure there is no damage before power can be safely restored. Any visual inspection of the power lines must take place during daylight hours for safety and accuracy. Therefore, patrol and restoration operations may be limited or prolonged during overnight hours. SCE strives to restore all power within 24 hours of de-energization when possible.

As hazardous weather conditions subsided and the period of concern for circuits started ending on October 26, SCE performed post patrols for damage and restored power as detailed in the table on page 13. Given the additional ongoing fire activity, SCE moved the restoration responsibilities for the Taiwan and Atento circuits to the Electrical Services (ES) IMT responsible for restoration related to fire activity on October 28 at 07:30 am, as these two circuits were under restricted access from the Orange County Fire Authority. The Atento circuit was restored on October 29 at 11:53 am, and all customers on the Taiwan circuit were restored by October 29 at 12:22 am.

**6. For any circuits that require more than 24 hours to restore, the utility shall explain why it was unable to restore each circuit within this timeframe in its post event report.**

The Camp Baldy circuit could not be fully re-energized within 24 hours, as portions of the circuit are only accessible by hiking. Given these conditions, this patrol could not be completed in one day. Resources focused on patrolling the source line (Ferrara) and a portion of the Camp Baldy circuit, restoring all but 37 customers. However, due to nightfall and hazardous conditions, the patrol was postponed until the following day. The patrol resumed on 10/28 and all load was restored in the afternoon. The Icehouse circuit was also fed by the Ferrara circuit and is only accessible by hiking.

Resources focused on completing the Icehouse patrol during daylight on 10/28 and all load was restored that afternoon. All 12 customers remained de-energized more than 24 hours after it was safe to patrol and energize. The Rustic circuit could not be re-energized within 24 hours as a helicopter was required to complete the patrol and all helicopter patrols on October 26 and October 27 were cancelled due to wind until October 28. Of the 367 impacted customers on the Rustic circuit, only 20 were de-energized more than 24 hours after it was safe to patrol and energize. The Sand Canyon circuit could not be re-energized within 24 hours once it was safe to patrol and restore as a helicopter was also required to complete the patrol. However due to strong winds, the patrol was also postponed to 10/28. Of the 143 impacted customers, only 9 were de-energized more than 24 hours after it was safe to patrol and energize. The Atento circuit impacting 901 customers could not be energized within 24 hours as access was restricted by the Orange County Fire Authority due to the circuit being within the area evacuated because of the Silverado Fire. The Taiwan circuit impacting 85 customers could also not be energized within 24 hours as access was also restricted due to the Silverado Fire.

**7. Identify the address of each community assistance location during the de-energization event, describe the location (in a building, a trailer, etc.), and describe the assistance available at each location, and give the days and hours that it was open.**

Each of the CRC/CCV locations were equipped with ice vouchers or ice, water, customer resiliency kit (containing PSPS program information, mask, gloves, hand sanitizer, solar power battery charger or an LED light with built-in battery).

**CRC/CCV Locations and Details**

Type	County	City/Community	Day and Time <sup>9</sup>	Address
CCV	San Bernardino	San Bernardino, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	CSU San Bernardino, 5500 University Pkwy
CCV	San Bernardino	Rancho Cucamonga, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	Central Park, 11200 Baseline Rd.
CRC	Orange	Orange, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	Sears, 2100 N. Tustin St
CRC	San Bernardino	Fontana, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	Jesse Turner Health and Fitness Fontana Community Center 15556 Summit Ave
CRC	Los Angeles	Acton, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	Acton Community Center, 3748 Nickels S
CRC	Riverside	Cabazon, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	James A. Venable Community Center, 50390 Carmen Ave
CRC	Los Angeles	Agua Dulce, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	Agua Dulce Women's Club, 33201 Agua Dulce Canyon Rd

<sup>9</sup> CRC/CCV operation coincided with the period of concern in each area, which resulted in actual hours of operation that are different from the CRC/CCV available hours.

Type	County	City/Community	Day and Time <sup>9</sup>	Address
CRC	Ventura	Moorpark, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	Boy's and Girl's Club of Moorpark, 200 Casey Rd.
CRC	Ventura	Simi Valley, CA	9am-10pm (Monday) 9am-12pm (Tuesday)	Boy's and Girl's Club of Simi Valley, 2850 Lemon Dr
CRC	Los Angeles	Canyon Country	9am-10pm (Monday) 9am-12pm (Tuesday)	College of the Canyons, 1700 Sierra Hwy

**8. Any wind-related damage(s) to SCE’s overhead equipment in the areas where power is shutoff.**

Crews performed post-patrols on de-energized circuits before re-energization to ensure safe operating conditions. Repairs were made before safely restoring power. A summary of all wind-related damage from this PSPS event found during the post-patrol process is below:

Circuit	Structure	Damage
Acosta	1499799E, 1388833E, 4234971E	Damaged insulators, broken pole

**9. All factors considered by SCE in its decision to shut off power, including wind speed, temperature, humidity, and vegetation moisture in the vicinity of the de-energized circuits**

SCE’s decision to shut off power is dynamic and was made by considering the following factors during this event:

- National Weather Service-issued watches and warnings for high fire risk areas in our territory
- Ongoing assessments from our in-house meteorologists using high-resolution weather models, data from SCE weather stations, and publicly available weather stations
- The SCE Fire Potential Index (FPI), a tool that utilizes weather data, fuel conditions, and vegetation moisture content to rate the daily fire potential across our region. SCE uses the following metrics to rate ignition potential: Low-11.99, Elevated-12-14.99 and Extreme-15 and above.
- Wind trends and speeds, particularly when they exceed or are expected to exceed National Weather Service Wind Advisory levels (defined as 31 mph sustained wind speed and 46 mph gust wind speed) or exceed the top 1% of historical wind speeds in the area. Wind speeds are particularly important when we consider them in combination with other local conditions, such as dry vegetation, that could present an imminent hazard for the community. Wind speed thresholds may also be adjusted based on other factors or circuit design
- Other operational considerations, such as the state of the potentially impacted circuits, flying debris and/or downed wires

SCE considered the following specific factors to inform de-energization decisions:

Circuit Name	RAR/CB	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
ACOSTA	RAR0800	SCE Big Tree Cucamonga	36.1	64.52	31 / 46	12.56	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
ACOSTA	CB	SCE Summit Ave	34.63	67.81	31 / 46	12.56	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
AMETHYST	RCS2301	SCE Deer Canyon	30.94	51	31 / 46	12.55	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
ANTON	RAR1992	SCE Happy Camp	34.54	56.85	31 / 46	12.51	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
ANTON	RAR0217	SCE Happy Camp	34.54	56.85	31 / 46	12.51	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
ATENTO	RCS3995	SCE Silverado Canyon	18.8	44	31 / 46	12.5	<ul style="list-style-type: none"> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
AVANTI	CB	SCE W Little League Dr	40.55	73.65	31 / 46	12.56	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
BEAR VALLEY	RAR0244	SCE Kilkare Rd	8.94	29.88	18 / 29	13.24	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
BEAR VALLEY	CB	SCE Big Falls 2	13.48	29	18 / 29	13.24	<ul style="list-style-type: none"> <li>Met Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
BIG ROCK	RAR0104	SCE Cochran St	27	70	31 / 46	12.57	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
BLACKHILLS	RCS2491	SCE Thunder Ridge	30.7	46.2	31 / 46	14+	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
BLUE CUT	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
BOOTLEGGER	RAR7203	SCE Palamino Dr	25.63	47.86	31 / 46	14.15	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
BOOTLEGGER	CB	SCE	28.39	43.18	31 / 46	14.15	<ul style="list-style-type: none"> <li>High Wind Trend</li> </ul>

Circuit Name	RAR/CB	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
		Palamino Dr					<ul style="list-style-type: none"> <li>Exceeded FPI Value</li> </ul>
CABANA	CB	SCE Badger Canyon	46.5	63.64	31 / 46	12.57	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
CALSTATE	CB	SCE Badger Canyon	38.32	65.74	31 / 46	12.57	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
CAMP ANGELUS	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
CAMP BALDY	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
CANEBRAKE	RAR0621	SCE Canebrake Creek	29.5	47.9	31 / 46	12.23	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
CLUB OAKS	RCS0825	SCE Arrowhead Springs Rd	37.77	59.7	31 / 46	12.52	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
COOLER	RCS4314	N/A	N/A	N/A	31 / 46	12.45	<ul style="list-style-type: none"> <li>Observed Hazard</li> </ul>
DAVENPORT	RAR6564	SCE Rattle Snake Rd	23.78	49.47	31 / 46	12.57	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
DAVENPORT	RAR0050	SCE Country Breeze Ln	20.23	41.12	31 / 46	12.57	<ul style="list-style-type: none"> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
DE MILLE	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
ECHO	RAR0826	SCE Arrowhead Springs Rd	20.42	45.89	31 / 46	12.52	<ul style="list-style-type: none"> <li>Met Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
ENERGY	RAR0012	SCE Oat Mountain	35.63	54.51	31 / 46	12.54	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
ENERGY	RAR0490	SCE Browns Canyon	48.62	68.61	31 / 46	12.54	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
FERRARA	RAR0054	SCE San Antonio Canyon	15.15	48.44	31 / 46	14.3	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
GALENA	RSR6282	SCE Thunder Ridge	33	43	31 / 46	14	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
GOWAN	CB	SCE Whitney Dr	30.2	48.4	31 / 46	12.57	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
GREEN RIVER	CB	SCE Santa Ana River Bikeway	35.2	61.2	30.55 / 39.5	N/A	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> </ul>

Circuit Name	RAR/CB	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
							<ul style="list-style-type: none"> <li>Exceeded FPI Value</li> </ul>
GUITAR	RAR0402	SCE Tapo Canyon	32.11	44.21	31 / 46	12.51	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
HILLFIELD	CB	SCE Solemint Mtwy	36.64	54.24	31 / 46	12.58	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
ICEHOUSE	CB	N/A	N	A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
IMPALA	RCS0646	SCE Lytle Creek Wash	42.79	60.13	31 / 46	12.58	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
JEEP	CB	SCE Amador Ln	26.98	40.92	27 / 43	12.26	<ul style="list-style-type: none"> <li>Met Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
JENKS LAKE	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
KICKAPOO TRAIL	RAR0241	SCE Little Morongo Rd	25.16	45.74	31 / 46	12.2	<ul style="list-style-type: none"> <li>Met Threshold</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
KIMDALE	RAR1715	SCE Lake Mathews	33.27	45.16	31 / 45	12.56	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
LOPEZ	RAR3825	SCE Meyers Canyon	19.88	54.43	31 / 46	12.55	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
LOPEZ	RAR0048	SCE Kagel Canyon	20.41	41.87	31 / 46	12.55	<ul style="list-style-type: none"> <li>Observed Hazard</li> <li>Exceeded FPI Value</li> </ul>
LOUCKS	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
MACIEL	RAR6072	SCE Chino Hills 3	38.6	78.2	27.59 / 42.17	#N/A	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
MACY	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
MODJESKA	P5206529-B	SCE Dove Canyon	23.84	54.24	30 / 44	12.49	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
NEPAL	RCS1803	SCE Villa Park Dam	25.27	54.65	31 / 44	12.45	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> <li>1% Historical</li> <li>High Wind Trend</li> <li>Exceeded FPI Value</li> </ul>
OBSERVATORY	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
POWER	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>Source line lost</li> </ul>
RED BOX	RAR1484	CHOC1-	54	79	31 / 46	14.11	<ul style="list-style-type: none"> <li>Exceeded Threshold</li> </ul>

Circuit Name	RAR/CB	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
		Chilao					<ul style="list-style-type: none"> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
RUSTIC	RAR4668	SCE Trabuco Canyon Rd 2	13.3	59.55	31 / 46	12.49	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
SAND CANYON	RAR0191	SCE Magic Mtn Truck Trail	64.87	96.2	31 / 46	12.58	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
SAND CANYON	RAR3410	SCE Magic Mtn Truck Trail	57.88	75.33	31 / 46	12.58	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
SHOVEL	RAR3431	SCE Letteau Canyon	28.93	52.46	25 / 40	12.56	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
SUTT	RAR0825	SCE Arrowhead Springs Rd	14	47.79	31 / 46	12.57	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
SUTT	CB	SCE Arrowhead Springs Rd	35.97	59.99	31 / 46	12.57	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
SWEETWATER	CB	SCE Kendell Drive	36.23	62.25	31 / 46	12.57	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
TAIWAN	RAR0950	SCE Santiago Canyon Rd	29.5	54.36	31 / 46	12.48	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
TAIWAN	RAR0919	SCE Chapman Avenue	32.18	61.74	31 / 46	12.48	<ul style="list-style-type: none"> <li>• Observed Hazard</li> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
TAPO	RAR6509	SCE Tapo Canyon	32	44	31 / 46	12.55	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
TWIN LAKES	RCS5233	SCE Cochran St	27.12	69.85	31 / 45	12.57	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
VARGAS	RAR0828	SCE Sycamore	21.16	66.49	31 / 46	12.53	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> </ul>

Circuit Name	RAR/CB	Weather Station	Wind Sustained	Gust Sustained	Threshold Sustained	FPI Value	Reasons for De-Energization
		Canyon Rd					<ul style="list-style-type: none"> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
VERA CRUZ	RAR2400	SCE Carbon Canyon	33.6	52.4	28.04 / 42	N/A	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
VERDEMONT	CB	SCE W Little League Dr	40.55	73.65	31 / 46	12.57	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
VIDEO	RAR1716	SCE Henninger Flats Rd	21.75	49.76	28 / 45	12.54	<ul style="list-style-type: none"> <li>• Exceeded Threshold</li> <li>• 1% Historical</li> <li>• High Wind Trend</li> <li>• Exceeded FPI Value</li> </ul>
WEESHA	CB	N/A	N/A	N/A	N/A	N/A	<ul style="list-style-type: none"> <li>• Source line lost</li> </ul>

**10. Evaluation of alternatives to de-energization that were considered, and mitigation measures used to decrease the risk of utility-caused wildfire in the de-energized area and an explanation of how the utility determined that the benefit of de-energization outweighed the potential public safety risks:**

SCE does not perform separate risk assessments to establish de-energization thresholds during each PSPS event, but rather incorporates known risks and sets thresholds based on SCE's risk-informed assessment of the potential for a catastrophic wildfire should an ignition occur under the conditions presented. Under such conditions, the harm to life and property resulting from a catastrophic wildfire vastly outweighs the impacts of the de-energization necessary to eliminate the potential of ignition. Additionally, SCE only uses de-energization when no other alternatives will mitigate this fire risk and SCE further minimizes the impact by limiting the de-energization to the smallest number of customers possible through segmentation of impacted circuits, where possible.

During this event, SCE used sectionalizing through RAR devices or switches to isolate and de-energize only the necessary portions of circuits. While avoiding de-energization entirely was not possible, SCE took steps to reduce the impacts of de-energization on the community and considered the impacts of the de-energization on its stakeholders within the context of the risk posed by the prevailing weather conditions, its de-energizations thresholds, and the unacceptable public safety risk of catastrophic wildfire ignition. SCE also considers the use of back-up generation when customer conditions warrant. For example, a back-up generator was deployed to a customer in hospice care on the Atento circuit at 2:35 pm on October 28 to help mitigate initial impacts from the de-energization event and ongoing impacts from the Silverado Fire.

**11. A copy of all notifications, the timing of notifications, the methods of notifications and who made the notifications (the utility or local public safety partners).**

A copy of all notifications and the timing of notifications can be found in Attachment A - Public Safety Partner Notifications, Attachment B - Critical Infrastructure and Customer Notifications, and Attachment C - PSPS Activation Customer Notification Messaging.

All PSPS event notifications to key stakeholders, including Public Safety Partners and customers, are delivered via voice, email, and TTY (telecommunication device for the hearing impaired) formats as per the preference of the recipient. Notifications are offered in multiple languages. All notifications were made by SCE.

**12. Number of affected customers broken down by all classifications including residential, medical baseline, commercial/industrial, etc.**

A detailed description of the number of affected customers broken down by all classifications including residential, medical baseline, commercial/industrial, etc. is provided in Attachment B- Customer and Critical Infrastructure Notifications.

**13. An explanation of the circumstances that resulted in failure to communicate a potential pro-active de-energization event, if any.**

Although prior weather forecasts indicated the period of concern on October 26 beginning at 9:00 am, at approximately 6:00 am, the PSPS IMT began observing high wind speeds on SCE weather stations in Los Angeles, San Bernardino, and Orange counties that indicated early onset of dangerous weather conditions. For example, weather stations in the Valencia area measured wind speeds of up to 96 mph. Given the unanticipated early onset of these dangerous weather conditions, the Incident Commander gave approval to start pro-active de-energization, with the actual first de-energization completed at 6:23 am on October 26. As a result, some customers did not receive imminent de-energization notification. Additionally, three circuits not originally in scope for the period of concern were de-energized without prior notification when weather services advised that these circuits were exceeding wind and FPI thresholds. Details related to these circuits can be found in the table on page 6.

**14. Each electric investor-owned utility shall enumerate and explain the cause of any false communications in its post event reports by citing the sources of changing data.**

SCE notes that its PSPS notices before potential de-energization only provide a warning to customers of a possible de-energization event. SCE notices are designed to give customers notice that a de-energization could take place and a time frame within which the event is most likely to occur so that customers can act and prepare. Given the unpredictability of weather on the ground, however, SCE's advance notices do not affirmatively confirm that a circuit *will be* de-energized. In fact, for clarity, SCE does not provide any affirmative confirmation of de-energization in its notifications until an actual de-energization has taken place.

SCE believes this event could be viewed as an example of a false-negative communication since we were unable to provide all of the required advance notice of de-energization to Public Safety Partners, critical infrastructure providers, or customers on 3 circuits during this event given the rapid onset of hazardous weather conditions.

**15. A description and evaluation of engagement with local and state public safety partners in providing advanced education and outreach during the de-energization event.**

Advanced education and outreach of this Public Safety Power Shutoff event was communicated to all impacted county emergency management officials, CalOES, and the Commission before any forecasted weather was scheduled to impact the SCE service territory. Regular updates were provided throughout the event using the CalOES PSPS Notification Form, daily situational awareness and coordination calls, and individual contact with Public Safety Partners in the affected counties. SCE also hosted an Agency Representative from CalOES during this event.

**16. For those customers where positive or affirmative notification was attempted, an accounting of the customers (which tariff and/or access and functional needs population designation), the number of notification attempts made, the timing of attempts, who made the notification attempt (utility or public safety partner) and the number of customers for whom positive**

**notification was achieved.**

SCE only tracks critical care customers for positive or affirmative receipt of notification attempts. Notifications are made daily as these customers remain on potentially impacted circuits. There were 14 critical care customers requiring secondary verification during this PSPS event and SCE was able to make positive contact with all of them during this event. SCE regularly requests updated contact information from all critical care customers.

**17. A description of how sectionalizing, i.e., separating loads within a circuit, was considered and implemented and the extent to which it impacted the size and scope of the de-energization event.**

There were approximately 67,957 total customers in potential scope for actual de-energization during the period of concern for this event across all known circuits. There were an additional 9,640 customers not in the period of concern that SCE had to ultimately de-energize. SCE reduced the number of customers impacted by de-energization to 36,037 customers using switching playbooks that identified sectionalizing devices to limit the scope of the event. SCE used an RAR device to separate and isolate the de-energization areas, limiting the de-energization impacts as detailed in the table on page 6 of this report. During the process of sectionalizing, 334 customers temporarily lost power (for approximately 1 minute) but SCE is not including this in the count of de-energized customers due to the fact that this was an extremely short loss of power during switching operations and the customers at issue were not actually impacted by the PSPS events.

**18. Lessons learned from the de-energization events.**

As the unexpected changes in weather associated with this event highlight, it is important to continue to develop practices aimed at improved weather forecasting while also enhancing IMT practices and protocols, to enhance our ability to provide notifications even in unexpected weather events. SCE is continuing to evaluate lessons learned from this event and is also considering potential improvements to the existing IMT processes and procedures to increase the time period between when the IMT begins monitoring for potential weather ahead of the period of concern and when the period of concern actually begins. This will allow the PSPS IMT more time to make necessary notifications and further evaluate de-energizations decisions.

**19. Any recommended updates to the guidelines adopted in Resolution ESRB-8 and this decision.**

As SCE explained in its prior report, we would appreciate clarification related to “false negative” and “false positive” communications presented in D.20-05-051. SCE notes that “false positives or negatives” typically refer to decisions made or actions taken based on erroneous information. Differences between notifications and actual de-energizations, however, do not stem from incorrect data, but rather from actual ground conditions varying from forecast conditions, as is the case with every weather forecast. This variance is inherent because of the constantly changing nature of emergent weather.

SCE also believes that the relevant timeframe for assessing the numbers of customers who received notification but did not get de-energized/re-energized or who were de-energized

without notification should be limited to imminent notification made within 1-4 hours of a de-energization event or actual de-energization without notice. Weather conditions during PSPS events are dynamic and can change very quickly, and 1-, 2-, or 3-day advance notifications inherently have significant variability built in. It is not clear if any and all notifications of potential PSPS would be considered to be a false positive, or if this would be limited to instances when a customer receives notification that PSPS is imminent but is not actually de-energized.

The same clarification would be appreciated on false negative communications, *i.e.*, de-energizations without 1-4-hour notice. SCE recommends that only (1) imminent de-energization notices (1-4 hours) when de-energization does not take place; (2) imminent re-energization notices when no re-energization took place within the period of time indicated in the notice; or (3) de-energization without any notice be considered in the context of reporting false positive and false negative notifications. SCE hopes that the Commission will take this into consideration when clarifying the definition of false positives and negatives going forward.

### Officer Verification

I am an officer of the applicant corporation herein and am authorized to make this verification on its behalf. I am informed and believe that the matters stated in the foregoing document are true.

I declare under penalty of perjury that the foregoing is true and correct.

Executed this 12th day of November 2020 in Cerritos, California

DocuSigned by:  
*Erik Takayesu*  
420B7563894B477...

---

Erik Takayesu  
Vice President,  
Transmission, Substations & Operations

# Attachment A

## Public Safety Partner Notifications

Everbridge PPS Notification Audit Report 2020-10-23-1350 All Counties Rpt 1

Notification ID	Message Title	Sent On
564328637967238	Important Information from SCE – Possible Public Safety Power Shutoff in Los Angeles County on 10/26/20.	Oct 23, 2020 13:23:35 PDT
564328637967267	Important Information from SCE – Possible Public Safety Power Shutoff in Orange County on 10/26/20.	Oct 23, 2020 13:30:01 PDT
564328637967278	Important Information from SCE – Possible Public Safety Power Shutoff in Riverside County on 10/26/20.	Oct 23, 2020 13:36:20 PDT
564328637967290	Important Information from SCE – Possible Public Safety Power Shutoff in San Bernardino County on 10/26/20.	Oct 23, 2020 13:45:08 PDT
564328637967295	Important Information from SCE – Possible Public Safety Power Shutoff in Ventura County on 10/26/20.	Oct 23, 2020 13:50:21 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 1:24 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff in Los Angeles County on 10/26/20.  
**Attachments:** SCE+LNO+POC+2020-10-23+INITIAL+Los+Angeles+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Los Angeles County. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

***Please refer to the attached file for status and periods of concern for specific circuits in your county.***

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 1:30 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff in Orange County on 10/26/20.  
**Attachments:** SCE+LNO+POC+2020-10-23+INITIAL+Orange+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Orange County. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

***Please refer to the attached file for status and periods of concern for specific circuits in your county.***

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 1:37 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff in Riverside County on 10/26/20.  
**Attachments:** SCE+LNO+POC+2020-10-23+INITIAL+Riverside+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

***Please refer to the attached file for status and periods of concern for specific circuits in your county.***

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 1:45 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff in San Bernardino County on 10/26/20.  
**Attachments:** SCE+LNO+POC+2020-10-23+INITIAL+San+Bernardino+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

***Please refer to the attached file for status and periods of concern for specific circuits in your county.***

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 1:51 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff in Ventura County on 10/26/20.  
**Attachments:** SCE+LNO+POC+2020-10-23+INITIAL+Ventura+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Ventura County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

***Please refer to the attached file for status and periods of concern for specific circuits in your county.***

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PPS Notification Audit Report 2020-10-23-1951 All Counties Rpt 2

Notification ID	Message Title	Sent On
564466076922064	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County].	Oct 23, 2020 19:16:07 PDT
565153271688481	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.	Oct 23, 2020 19:22:09 PDT
565153271688488	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Oct 23, 2020 19:30:53 PDT
565153271688505	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.	Oct 23, 2020 19:45:27 PDT
565153271688516	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.	Oct 23, 2020 19:51:15 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 7:16 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County].  
**Attachments:** SCE+LNO+POC+2020-10-23+UPDATE+Los+Angeles+County+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 7:22 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.  
**Attachments:** SCE+LNO+POC+2020-10-23+UPDATE+Orange+County+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

**PLEASE REPLACE THE "TITLE" ABOVE WITH THE FOLLOWING PRIOR TO SENDING:**

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in [COUNTY NAME]. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 7:31 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.  
**Attachments:** SCE+LNO+POC+2020-10-23+UPDATE+Riverside+County+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 7:46 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.  
**Attachments:** SCE+LNO+POC+2020-10-23+UPDATE+San+Bernardino+County+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Friday, October 23, 2020 7:51 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.  
**Attachments:** SCE+LNO+POC+2020-10-23+UPDATE+Ventura+County+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Ventura County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

PSPS Notice 2020-10-24-1459 All Counties Rpt 1

Notification ID	Message Title	Sent On
564328637968592	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Oct 24, 2020 14:37:09 PDT
564328637968599	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.	Oct 24, 2020 14:41:09 PDT
564328637968603	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Oct 24, 2020 14:46:08 PDT
564328637968613	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.	Oct 24, 2020 14:54:57 PDT
564328637968614	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.	Oct 24, 2020 14:59:02 PDT

## Jeffrey 1 Lee

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 2:37 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+Los+Angeles+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Jeffrey 1 Lee

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 2:41 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+Orange+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Orange County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Jeffrey 1 Lee

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 2:46 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+Riverside+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Jeffrey 1 Lee

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 2:55 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+San+Bernardino+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Jeffrey 1 Lee

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 2:59 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+Ventura+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Ventura County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PPS Notification Audit Report 2020-10-24-2032 All Counties Rpt 2

Notification ID	Message Title	Sent On
564328637968832	Important Information from SCE – Possible Public Safety Power Shutoff (PPSP) UPDATE for Los Angeles County.	Oct 24, 2020 20:11:11 PDT
564328637968835	Important Information from SCE – Possible Public Safety Power Shutoff (PPSP) UPDATE for Orange County.	Oct 24, 2020 20:15:08 PDT
564328637968838	Important Information from SCE – Possible Public Safety Power Shutoff (PPSP) UPDATE for Riverside County.	Oct 24, 2020 20:19:15 PDT
564328637968843	Important Information from SCE – Possible Public Safety Power Shutoff (PPSP) UPDATE for San Bernardino County.	Oct 24, 2020 20:25:19 PDT
564328637968845	Important Information from SCE – Possible Public Safety Power Shutoff (PPSP) UPDATE for Ventura County.	Oct 24, 2020 20:28:53 PDT
564328637968846	Important Information from SCE – Possible Public Safety Power Shutoff in Kern County on 10/26/20.	Oct 24, 2020 20:32:38 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 8:11 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+LOS+ANGELES+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 8:15 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+ORANGE+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Orange County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 8:19 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+RIVERSIDE+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 8:26 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+SAN+BERNARDINO+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 8:29 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.  
**Attachments:** SCE+LNO+POC+2020-10-24+UPDATE+VENTURA+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Ventura County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Saturday, October 24, 2020 8:33 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff in Kern County on 10/26/20.  
**Attachments:** SCE+LNO+POC+2020-10-24+INITIAL+KERN+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to projected weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Kern County**. SCE is also notifying customers on the affected circuits about the potential shutoff, giving them time to prepare.

SCE has opened its Emergency Operations Center and activated an Incident Management Team to monitor the weather and other conditions in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

***Please refer to the attached file for status and periods of concern for specific circuits in your county.***

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** SCE may shut off power on one or more circuits in your area. For more information, visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PPS Notification Audit Report 2020-10-25-1228 All Counties Report 1

Notification ID	Message Title	Sent On
564328637969469	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County	Oct 25, 2020 12:09:37 PDT
564328637969473	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County	Oct 25, 2020 12:13:38 PDT
564328637969475	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County	Oct 25, 2020 12:16:38 PDT
564328637969478	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County	Oct 25, 2020 12:20:07 PDT
564328637969480	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County	Oct 25, 2020 12:25:29 PDT
564328637969483	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County	Oct 25, 2020 12:28:42 PDT

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.  
**Date:** Sunday, October 25, 2020 12:11:33 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+KERN+Rpt+1.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Kern County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these

unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.  
**Date:** Sunday, October 25, 2020 12:15:34 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+LOS+ANGELES+Rpt+1.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](http://sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.

- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.  
**Date:** Sunday, October 25, 2020 12:18:14 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+ORANGE+Rpt+1.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Orange County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these

unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.  
**Date:** Sunday, October 25, 2020 12:21:48 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+RIVERSIDE+Rpt+1.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these

unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.  
**Date:** Sunday, October 25, 2020 12:27:43 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+SAN+BERNARDINO+Rpt+1.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these

unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.  
**Date:** Sunday, October 25, 2020 12:30:33 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+VENTURA+Rpt+1.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Ventura County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](http://sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.

- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Notification ID	Message Title	Sent On
564328637969883	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.	Oct 25, 2020 20:36:20 PDT
564328637969886	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Oct 25, 2020 20:41:12 PDT
564328637969888	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.	Oct 25, 2020 20:43:39 PDT
564328637969889	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Oct 25, 2020 20:46:24 PDT
564328637969893	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.	Oct 25, 2020 20:49:39 PDT
564328637969914	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.	Oct 25, 2020 21:42:39 PDT

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.  
**Date:** Sunday, October 25, 2020 8:38:08 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+Kern+County+Rpt+2.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Kern County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these

unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.  
**Date:** Sunday, October 25, 2020 8:42:53 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+Los+Angeles+County+Rpt+2.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](http://sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.

- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.  
**Date:** Sunday, October 25, 2020 8:45:22 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+Orange+County+Rpt+2.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Orange County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these

unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.  
**Date:** Sunday, October 25, 2020 8:48:09 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+Riverside+County+Rpt+2.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these

unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.  
**Date:** Sunday, October 25, 2020 8:51:32 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+Ventura+County+Rpt+2.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Ventura County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](http://sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.

- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com)  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.  
**Date:** Sunday, October 25, 2020 9:44:25 PM  
**Attachments:** [SCE+LNO+POC+2020-10-25+UPDATE+San+Bernardino+County+Rpt+2.xlsx](#)

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these

unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-0812 All Counties DE

Notification ID	Message Title	Sent On
564328637970394	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0625.	Oct 26, 2020 07:06:15 PDT
564328637970399	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0640.	Oct 26, 2020 07:10:11 PDT
564328637970475	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0649.	Oct 26, 2020 07:34:02 PDT
564328637970478	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0701.	Oct 26, 2020 07:36:39 PDT
564328637970489	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0719.	Oct 26, 2020 07:43:00 PDT
564328637970491	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0719.	Oct 26, 2020 07:43:56 PDT
564328637970528	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0734.	Oct 26, 2020 07:56:43 PDT
564328637970560	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0724.	Oct 26, 2020 08:08:40 PDT
564328637970570	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0722.	Oct 26, 2020 08:12:05 PDT

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 7:06 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0625.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Los Angeles County**. Impacted circuits and locations are:

- **Circuit:** Sand Canyon
- **County:** Los Angeles County
- **Incorporated City of:** Santa Clarita
- **Unincorporated County Area:** Agua Dulce Canyon ; Mint Canyon south of Mint Canyon Elementary school going south on Sand Canyon Rd ; Sand Canyon ; Soledad Canyon ; Long Canyo ; Russ ; Lang ; Magic Mountain ; North Fork Ranger Station Water Pump
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0625

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 7:10 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0640.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Los Angeles County**. Impacted circuits and locations are:

- **Circuit:** Red Box
- **County:** Los Angeles County
- **Unincorporated County Area:** Along Angeles Crest Hwy
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0640

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 7:34 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0649.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Los Angeles County**. Impacted circuits and locations are:

- **Circuit:** Shovel
- **County:** Los Angeles County
- **Incorporated City of:** Palmdale
- **Unincorporated County Area:** Escondido Canyon Rd between Aqua Dulce Canyon and Acton ; Kashmere Canyon ; Boiling Point
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0649

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 7:37 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0701.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Los Angeles County**. Impacted circuits and locations are:

- **Circuit:** Bootlegger (Segment 2)
- **County:** Los Angeles County
- **Unincorporated County Area:** Acton ; Surrounding area around Acton ; Vincent ; Paris ; Singing Springs ; Hidden Springs ; Angles Forest Hwy to Singing Springs ; Aliso Canyon Rd
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0701

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 7:43 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0719.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Los Angeles County**. Impacted circuits and locations are:

- **Circuit:** Ferrara
- **County:** Los Angeles County
- **Unincorporated County Area:** MOUNT BALDY ;SAN ANTONIO HEIGHTS
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0719

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 7:44 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0719.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **San Bernardino County**. Impacted circuits and locations are:

- **Circuit:** Ferrara
- **County:** San Bernardino County
- **Incorporated City of:** Upland
- **Unincorporated County Area:** Ferrara
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0719

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:09 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0724.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **San Bernardino County**. Impacted circuits and locations are:

- **Circuit: Sutt**
- **County: San Bernardino County**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Waterman Canyon**
- **De-Energized Date: 10/26/20**
- **De-Energized Time: 0724**

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:12 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0722.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Los Angeles County**. Impacted circuits and locations are:

- **Circuit:** Davenport
- **County:** Los Angeles County
- **Unincorporated County Area:** Agua Dulce ; Southwest of Agua Dulce ; Boiling Point ; White Heather ; Sleepy Valley ; Northeast of Forest Park ; The Oaks ;
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0722

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:12 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0722.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Los Angeles County**. Impacted circuits and locations are:

- **Circuit:** Davenport
- **County:** Los Angeles County
- **Unincorporated County Area:** Agua Dulce ; Southwest of Agua Dulce ; Boiling Point ; White Heather ; Sleepy Valley ; Northeast of Forest Park ; The Oaks ;
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0722

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-0829 San Bernardino County-DE

Notification ID	Message Title	Sent On
564328637970592	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0728.	Oct 26, 2020 08:16:23 PDT
564328637970608	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0746.	Oct 26, 2020 08:20:13 PDT
564328637970624	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0758.	Oct 26, 2020 08:23:44 PDT
564328637970632	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0741.	Oct 26, 2020 08:29:19 PDT

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:17 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0728.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **San Bernardino County**. Impacted circuits and locations are:

- **Circuit:** Vargas (Segment 2)
- **County:** San Bernardino County
- **Incorporated City of:** San Bernardino
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0728

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:20 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0746.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **San Bernardino County**. Impacted circuits and locations are:

- **Circuit: Calstate (Segment 1)**
- **County: San Bernardino County**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Devils Canyon**
- **De-Energized Date: 10/26/20**
- **De-Energized Time: 0746**

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:24 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0758.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **San Bernardino County**. Impacted circuits and locations are:

- **Circuit:** Echo (Segment 2)
- **County:** San Bernardino County
- **Incorporated City of:** San Bernardino
- **Unincorporated County Area:** Del Rosa
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0758

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:29 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0741.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **San Bernardino County**. Impacted circuits and locations are:

- **Circuit:** Impala (Segment 3)
- **County:** San Bernardino County
- **Incorporated City of:** Fontana
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0741

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:12 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** NEPAL
- **County:** Orange County
- **Incorporated City of:** Orange
- **Unincorporated County Area:** ORANGE PARK ESTATES ; Lolita St

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:18 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** RUSTIC
- **County:** Orange County
- **Incorporated City of:** Rancho Santa Margarita
- **Unincorporated County Area:** None

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:23 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside Co.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: RUSTIC
- County: Riverside
- Unincorporated County Area: Santiago Peak

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:29 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino Co.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: VERDEMONT
- County: San Bernardino
- Incorporated City of: San Bernardino
- Unincorporated County Area: Muscoy ; Keenbrooke ; Cosy Dell ; Cajon

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:34 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino Co.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: SWEETWATER
- County: San Bernardino
- Incorporated City of: San Bernardino
- Unincorporated County Area: none

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:39 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Acosta**
- **County: San Bernardino County**
- **Incorporated City of: Fontana; Rancho Cucamonga**
- **Unincorporated County Area: San Sevaine Flats**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:40 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: TAPO
- County: Ventura County
- Incorporated City of: Simi Valley
- Unincorporated County Area: None

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:43 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Atento**
- **County: Orange County**
- **Incorporated City of: Lake Forest**
- **Unincorporated County Area: Portola Hills ; Modjeska ; Silverado**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:44 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino Co.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: AVANTI
- County: San Bernardino
- Incorporated City of: San Bernardino
- Unincorporated County Area: Verdemont ; University Heights

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:02 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Riverside County at 0832 and 0838.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Riverside County**. Impacted circuits and locations are:

- **Circuit: Rustic (Segment 5)**
- **County: Riverside County**
- **Unincorporated County Area: Santiago Peak**
- **De-Energized Date: 10/26/20**
- **De-Energized Time: 0832 (portion of segment 5) and 0838 (portion of segment 5)**

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Mara Kahunale Portlock

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:06 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 0832 and 0838.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Orange County**. Impacted circuits and locations are:

- **Circuit:** Rustic (segment 5)
- **County:** Orange County
- **Incorporated City of:** Rancho Santa Margarita
- **Unincorporated County Area:** TRABUCO CANYON ; Santiago Peak ; Modjeska Peak
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0832 (portions of segment 5) and 0838 (portions of segment 5)

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:11 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) DE-EN Occurred in Los Angeles Co at 0839.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in Los Angeles County. Impacted circuits and locations are:

- Circuit: LOPEZ
- County: Los Angeles
- Incorporated City of: San Fernando
- Unincorporated County Area: Indian Springs, El Merrie Dell
- De-Energized Date: 10/26/20
- De-Energized Time: 0839

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Mara Kahunale Portlock

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:17 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino Co. at 0853.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in San Bernardino County. Impacted circuits and locations are:

- Circuit: ACOSTA
- County: San Bernardino
- Incorporated City of: Fontana, Rancho Cucamonga
- Unincorporated County Area: San Sevaine Flats
- De-Energized Date: 10/26/20
- De-Energized Time: 0853

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Mara Kahunale Portlock

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:20 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) DE-EN Occurred in Los Angeles Co at 0905.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in Los Angeles County. Impacted circuits and locations are:

- Circuit: LOPEZ (another portion of the circuit)
- County: Los Angeles
- Incorporated City of: San Fernando
- Unincorporated County Area: Indian Springs, El Merrie Dell
- De-Energized Date: 10/26/20
- De-Energized Time: 0905

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:22 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0900.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **San Bernardino County**. Impacted circuits and locations are:

- **Circuit:** Acosta
- **County:** San Bernardino County
- **Incorporated City of:** Fontana; Rancho Cucamonga
- **Unincorporated County Area:** San Sevaine Flats
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0900

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-0934 All Counties-IMDE

Notification ID	Message Title	Sent On
565015832739229	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.	Oct 26, 2020 08:47:06 PDT
565015832739240	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 08:50:47 PDT
564878393786941	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura County.	Oct 26, 2020 09:01:34 PDT
565015832739278	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.	Oct 26, 2020 09:08:35 PDT
565015832739281	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura County.	Oct 26, 2020 09:13:31 PDT
565015832739307	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 09:32:07 PDT
565015832739309	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura County.	Oct 26, 2020 09:34:31 PDT

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:47 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Gowan**
- **County: Riverside County**
- **Incorporated City of: Jurupa Valley**

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:51 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Kickapoo Trail**
- **County: San Bernardino County**
- **Incorporated City of: Yucca Valley**
- **Unincorporated County Area: Yucca Valley ; Little Morongo Heights ; Palm Wells ; Little Morongo Canyon ; MORONGO VALLEY**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:02 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: ANTON
- County: Ventura
- Incorporated City of: Moorpark
- Unincorporated County Area: North of Moorpark

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:09 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Siam**
- **County: Orange County**
- **Incorporated City of: Orange**
- **Unincorporated County Area: El Modena ; Cowan Heights ; Orange Park Acres**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:14 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Zone**
- **County: Ventura County**
- **Incorporated City of: Moorpark**
- **Unincorporated County Area: Santa Rosa ; Moorpark Home Acres ; East of Lagol ; West of Fairview ; West of Moorpark**

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:32 AM  
**To:** Rocio M Contreras-Regalado  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

**Importance:** High

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Big Rock**
- **County: Los Angeles County**
- **Unincorporated County Area: West of Lakeside Park**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:35 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Big Rock**
- **County: Ventura County**
- **Incorporated City of: Simi Valley**
- **Unincorporated County Area: Santa Susana Knolls**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-1045 All Counties-IMDE

Notification ID	Message Title	Sent On
565015832739370	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 10:09:19 PDT
565015832739385	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 10:20:49 PDT
565015832739393	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.	Oct 26, 2020 10:25:01 PDT
565015832739399	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.	Oct 26, 2020 10:28:32 PDT
564878393787154	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura Co.	Oct 26, 2020 10:29:52 PDT
564878393787167	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside Co.	Oct 26, 2020 10:33:38 PDT
565015832739421	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 10:44:56 PDT
564878393787194	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 10:45:10 PDT

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.  
**Date:** Monday, October 26, 2020 10:16:03 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Python
- **County:** Los Angeles County
- **Incorporated City of:** Santa Clarita
- **Unincorporated County Area:** Unincorporated communities east of Santa Clarita

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a

rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

**Members of the Public: Please DO share this information with your residents on your website or social media.**

- 800-611-1911 is for outage-specific Customer Service issues.
- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.  
**Date:** Monday, October 26, 2020 10:26:00 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Wapello**
- **County: Los Angeles County**
- **Unincorporated County Area: Altadena ; north of Altadena**

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize

information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.  
**Date:** Monday, October 26, 2020 10:31:40 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Canebrake**
- **County: Kern County**
- **Unincorporated County Area: Canebrake or Onyx or Weldon**

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize

information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.  
**Date:** Monday, October 26, 2020 10:31:28 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Fingal**
- **County: Riverside County**
- **Unincorporated County Area: Cabazon**

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize

information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura Co.  
**Date:** Monday, October 26, 2020 10:33:37 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: ESTABAM
- County: Ventura
- Incorporated City of: Camarillo
- Unincorporated County Area: None.

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize

information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside Co.  
**Date:** Monday, October 26, 2020 10:34:58 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: PARCO
- County: Riverside
- Incorporated City of: Jurupa Valley
- Unincorporated County Area: None.

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize

information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.  
**Date:** Monday, October 26, 2020 10:46:45 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Cholla**
- **County: San Bernardino County**
- **Unincorporated County Area: Morongo Valley**

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize

information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**

800-611-1911 is for outage-specific Customer Service issues.

- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.  
**Date:** Monday, October 26, 2020 10:48:30 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: AMETHYST
- County: San Bernardino
- Incorporated City of: Rancho Cucamonga
- Unincorporated County Area: unincorporated communities along Haven Ave and Snow Drop Rd located north of Rancho Cucamonga

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional

targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your**

**residents on your website or social media.**

- 800-611-1911 is for outage-specific Customer Service issues.
- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-1059-All Counties-DE

Notification ID	Message Title	Sent On
565015832739408	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0905.	Oct 26, 2020 10:37:05 PDT
564878393787179	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino Co at 0838.	Oct 26, 2020 10:38:51 PDT
565015832739414	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 1012.	Oct 26, 2020 10:40:28 PDT
565015832739439	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 0723.	Oct 26, 2020 10:59:27 PDT

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0905.  
**Date:** Monday, October 26, 2020 10:38:47 AM

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Los Angeles County**. Impacted circuits and locations are:

- **Circuit:** Lopez
- **County:** Los Angeles County
- **Incorporated City of:** San Fernando
- **Unincorporated County Area:** Indian Springs ; El Merrie Dell
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 0905

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other

unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino Co at 0838.  
**Date:** Monday, October 26, 2020 10:39:40 AM  
**Importance:** High

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in San Bernardino County. Impacted circuits and locations are:

- Circuit: SWEETWATER
- County: San Bernardino
- Incorporated City of: San Bernardino
- Unincorporated County Area: None.
- De-Energized Date: 10/26/20
- De-Energized Time: 0838

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as

safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

**Members of the Public: Please DO share this information with your residents on your website or social media.**

- 800-611-1911 is for outage-specific Customer Service issues.
- 800-684-8123 is for all other billing and service inquiries.
- [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
- Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 1012.  
**Date:** Monday, October 26, 2020 10:47:13 AM

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Orange County**. Impacted circuits and locations are:

- **Circuit: Atento**
- **County: Orange County**
- **Incorporated City of: Lake Forest**
- **Unincorporated County Area: Portola Hills ; Modjeska ; Silverado**
- **De-Energized Date: 10/26/20**
- **De-Energized Time: 1012**

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other

unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

**From:** SCELiaisonOfficer@sce.com  
**To:** [SCE Liaison Officer](#)  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 0723.  
**Date:** Monday, October 26, 2020 11:02:10 AM

---

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Orange County**. Impacted circuits and locations are:

- **Circuit: Taiwan**
- **County: Orange County**
- **Incorporated City of: Orange**
- **Unincorporated County Area: East of Irvine Lake along Santiago Rd heading east**
- **De-Energized Date: 10/26/20**
- **De-Energized Time: 0723**

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](http://sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or

PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

EverBridge PSPS Notification Audit Report 2020-10-26-1239-IMDE Orange County

Notification ID	Message Title	Sent On
565015832739482	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.	Oct 26, 2020 11:29:18 PDT
565015832739533	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.	Oct 26, 2020 12:03:26 PDT
565015832739536	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.	Oct 26, 2020 12:06:03 PDT
565015832739590	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.	Oct 26, 2020 12:39:44 PDT

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 11:30 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Cooler
- **County:** Orange County
- **Incorporated City of:** Lake Forest, Mission Viejo, Rancho Santa Margarita
- **Unincorporated County Area:** Unincorporated communities near Rancho Santa Margarita

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 12:04 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Vera Cruz
- **County:** Orange County
- **Incorporated City of:** Brea, Placentia, Yorba Linda
- **Unincorporated County Area:** Carbon Canyon

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 12:06 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Green River**
- **County: Orange County**
- **Incorporated City of: Yorba Linda**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 12:40 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Orange County.

**Importance:** High

**Follow Up Flag:** Follow up

**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Munich**
- **County: Orange County**
- **Incorporated City of: Irvine**

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

EverBridge PSPS Notification Audit Report 2020-10-26-1315-IMDE Los Angeles County

Notification ID	Message Title	Sent On
564878393787280	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 11:31:18 PDT
565015832739497	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 11:34:59 PDT
565015832739585	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 12:37:18 PDT
565015832739593	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 12:41:33 PDT
565015832739645	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 13:15:23 PDT

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>

**Sent:** Monday, October 26, 2020 11:31 AM

**To:** SCE Liaison Officer <SCELiaisonOfficer@sce.com>

**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

**Importance:** High

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: BROADCAST
- County: Los Angeles
- Incorporated City of: None.
- Unincorporated County Area: Mount Disappointment ; Mount Wilson ; Clear Creek Ranger Station ; Angeles Cresy Hwy at Mt Wilson Red Box Rd

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](http://sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>

**Sent:** Monday, October 26, 2020 11:35 AM

**To:** SCE Liaison Officer <SCELiaisonOfficer@sce.com>

**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

**Importance:** High

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Diamondback
- **County:** Los Angeles County
- **Incorporated City of:** Santa Clarita

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](http://sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>

**Sent:** Monday, October 26, 2020 12:38 PM

**To:** SCE Liaison Officer <SCELiaisonOfficer@sce.com>

**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

**Importance:** High

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Crescenta
- **County:** Los Angeles County
- **Incorporated City of:** La Canada Flintridge
- **Unincorporated County Area:** La Crescenta ; Montrose

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>

**Sent:** Monday, October 26, 2020 12:42 PM

**To:** SCE Liaison Officer <SCELiaisonOfficer@sce.com>

**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

**Importance:** High

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Anaconda
- **County:** Los Angeles County
- **Incorporated City of:** Santa Clarita

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:16 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Veterans**
- **County: Los Angeles County**
- **Incorporated City of: San Fernando**
- **Unincorporated County Area: Pacoima Dam area ; Uninco area along May Canyon Truck Dr**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

EverBridge PSPS Notification Audit Report 2020-10-26-1322-IMDE Riverside County

Notification ID	Message Title	Sent On
565015832739636	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.	Oct 26, 2020 13:09:11 PDT
565015832739655	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.	Oct 26, 2020 13:22:16 PDT

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:09 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Kimdale**
- **County: Riverside County**
- **Unincorporated County Area: Gavilan Hills ; Harford Springs Reserve ; Glen Valley**

**This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:23 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Warhawk
- **County:** Riverside County
- **Incorporated City of:** Eastvale
- **Unincorporated County Area:** Uninc areas of Chino ; Eastvale

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

EverBridge PSPS Notification Audit Report 2020-10-26-1345-DE

Notification ID	Message Title	Sent On
564878393787295	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Riverside Co at 1122.	Oct 26, 2020 11:37:28 PDT
565015832739694	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 1209.	Oct 26, 2020 13:39:53 PDT
565015832739696	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 1210.	Oct 26, 2020 13:42:41 PDT
565015832739700	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 1217.	Oct 26, 2020 13:45:02 PDT

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 11:40 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Riverside Co at 1122.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in Riverside County. Impacted circuits and locations are:

- Circuit: GOWAN
- County: Riverside
- Incorporated City of: Jurupa Valley
- Unincorporated County Area: None.
- De-Energized Date: 10/26/20
- De-Energized Time: 1122

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:40 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 1209.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Orange County**. Impacted circuits and locations are:

- **Circuit:** Vera Cruz
- **County:** Orange County
- **Incorporated City of:** Brea ; Placentia ; Yorba Linda
- **Unincorporated County Area:** Carbon Canyon
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 1209

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:43 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 1210.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Orange County**. Impacted circuits and locations are:

- **Circuit:** Green River
- **County:** Orange County
- **Incorporated City of:** Yorba Linda
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 12:10

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:45 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Orange County at 1217.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **Orange County**. Impacted circuits and locations are:

- **Circuit:** Nepal
- **County:** Orange County
- **Incorporated City of:** Orange
- **Unincorporated County Area:** Orange Park Estates ; Lolita St.
- **De-Energized Date:** 10/26/20
- **De-Energized Time:** 1217

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

EverBridge PSPS Notification Audit Report 2020-10-26-1407-IMDE San Bernardino County

<b>Notification ID</b>	<b>Message Title</b>	<b>Sent On</b>
565015832739560	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 12:26:37 PDT
565015832739576	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 12:31:46 PDT
565015832739630	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 13:04:51 PDT
565015832739644	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 13:13:06 PDT
565015832739651	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 13:19:30 PDT
565015832739659	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 13:24:24 PDT
565015832739675	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 13:32:49 PDT
564878393787568	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 14:03:20 PDT
564878393787571	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.	Oct 26, 2020 14:07:27 PDT

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 12:27 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Taggert**
- **County: San Bernardino County**
- **Unincorporated County Area: Green Valley Lake ; Running Springs ; Crab Flats**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 12:32 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Carmelita**
- **County: San Bernardino County**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Arrow Head Farms**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:05 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: Twin Peaks**
- **County: San Bernardino County**
- **Unincorporated County Area: Crestline ; Crestline Lake Arrowhead Water Agency**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:13 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Jeep
- **County:** San Bernardino County
- **Unincorporated County Area:** Lake Arrowhead

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:20 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Shake
- **County:** San Bernardino County
- **Unincorporated County Area:** Lake Arrowhead

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:25 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Warhawk
- **County:** San Bernardino County
- **Incorporated City of:** Chino

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 1:33 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit:** Santorini
- **County:** San Bernardino County
- **Incorporated City of:** Rancho Cucamonga ; Upland

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 2:03 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: ABACUS**
- **County: San Bernardino**
- **Incorporated City of: Highland**, San Bernardino
- **Unincorporated County Area:** None.

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 2:09 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in San Bernardino County.

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

**PLEASE REPLACE "TITLE" ABOVE WITH THE FOLLOWING PRIOR TO SENDING:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in [COUNTY NAME].

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: ROWCO
- County: San Bernardino
- Incorporated City of: None
- Unincorporated County Area: Running Springs ; Fredalba ; Running Springs Sewer Plant ; Along Rim of the World Hwy going North

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-1500 All Counties Rpt 1

Notification ID	Message Title	Sent On
565015832739742	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.	Oct 26, 2020 14:11:22 PDT
565015832739755	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Oct 26, 2020 14:18:46 PDT
565015832739761	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.	Oct 26, 2020 14:22:58 PDT
565015832739863	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Oct 26, 2020 15:25:00 PDT
565015832739894	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.	Oct 26, 2020 15:43:29 PDT
565015832739898	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.	Oct 26, 2020 15:46:53 PDT

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 2:12 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Kern County.  
**Attachments:** SCE+LNO+POC+2020-10-26+UPDATE+Kern+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Kern County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 2:24 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.  
**Attachments:** SCE+LNO+POC+2020-10-26+UPDATE+Los+Angeles+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 2:23 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.  
**Attachments:** SCE+LNO+POC+2020-10-26+UPDATE+Orange+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Orange County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 3:25 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.  
**Attachments:** SCE+LNO+POC+2020-10-26+UPDATE+Riverside+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 3:44 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.  
**Attachments:** SCE+LNO+POC+2020-10-26+UPDATE+San+Bernardino+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Rocio M Contreras-Regalado

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 3:47 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.  
**Attachments:** SCE+LNO+POC+2020-10-26+UPDATE+Ventura+County+Rpt+1.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Ventura County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-1932-Kern County-RE

Notification ID	Message Title	Sent On
565153271692593	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization for CANEBRAKE circuit in Kern County	Oct 26, 2020 19:32:56 PDT

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 7:33 PM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization for CANEBRAKE circuit in Kern County

**Importance:** High

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: **CANEBRAKE**
- County: **Kern**
- Unincorporated County Area: **Canebrake or Onyx or Weldon**
- Re-Energized Date: **10/26/2020**
- Re-Energized Time: **18:34**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-2041 San Bernardino County-IMRE

Notification ID	Message Title	Sent On
565153271692639	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County	Oct 26, 2020 20:41:29 PDT

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:42 PM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- Circuit: **KICKAPOO TRAIL**
- County: **San Bernardino**
- Unincorporated County Areas: **Yucca Valley ; Little Morongo Heights ; Palm Wells ; Little Morongo Canyon ; Morongo Valley**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-2156-All Counties-Rpt 2

Notification ID	Message Title	Sent On
565153271692644	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County	Oct 26, 2020 20:58:15 PDT
565153271692659	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County	Oct 26, 2020 21:15:04 PDT
565153271692679	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County	Oct 26, 2020 21:37:26 PDT
565153271692692	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County	Oct 26, 2020 21:49:14 PDT
565153271692694	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County	Oct 26, 2020 21:56:03 PDT

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 8:59 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County  
**Attachments:** SCE+LNO+POC+VENTURA+2020-10-26+Rpt+2.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in Ventura County. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:15 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County  
**Attachments:** SCE+LNO+POC+SAN+BERNARDINO+2020-10-26+Rpt+2.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:38 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County  
**Attachments:** SCE+LNO+POC+RIVERSIDE+2020-10-26+Rpt+2.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:50 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County  
**Attachments:** SCE+LNO+POC+LOS+ANGELES+2020-10-26+Rpt+2.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:56 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County  
**Attachments:** SCE+LNO+POC+ORANGE+2020-10-26+Rpt+2.xlsx  
**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

***Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.***

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Orange County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-2208-All Counties-RE

Notification ID	Message Title	Sent On
565153271692670	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of ANTON and TWIN LAKES circuits in Ventura County	Oct 26, 2020 21:27:42 PDT
565153271692698	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of KICKAPOO TRAIL circuit in San Bernardino County	Oct 26, 2020 22:08:08 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 9:28 PM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of ANTON and TWIN LAKES circuits in Ventura County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: **ANTON**
- County: **Ventura County**
- Incorporated City of: **Moorpark**
- Unincorporated County Area: **North of Moorpark**
- Re-Energized Date: **10/26/2020**
- Re-Energized Time: **20:08**
  
- Circuit: **TWIN LAKES**
- County: **Ventura County**
- Incorporated City of: **Simi Valley**
- Re-Energized Date: **10/26/2020**
- Re-Energized Time: **20:26**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 10:08 PM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of KICKAPOO TRAIL circuit in San Bernardino County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: **KICKAPOO TRAIL**
- County: **San Bernardino**
- Incorporated City: **Yucca Valley**
- Unincorporated County Area: **Yucca Valley ; Little Morongo Heights ; Palm Wells ; Little Morongo Canyon ; Morongo Valley**
- Re-Energized Date: **10/26/2020**
- Re-Energized Time: **21:29**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PPS Notification 2020-10-26-1006 All Counties IMDE

Notification ID	Message Title	Sent On
565015832739316	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.	Oct 26, 2020 09:40:38 PDT
564878393787036	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura Co.	Oct 26, 2020 09:45:23 PDT
564878393787046	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura Co.	Oct 26, 2020 09:49:36 PDT
564878393787057	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.	Oct 26, 2020 09:53:42 PDT
564878393787061	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura Co.	Oct 26, 2020 09:58:00 PDT
564878393787071	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.	Oct 26, 2020 10:01:41 PDT
565015832739355	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.	Oct 26, 2020 10:01:48 PDT
564878393787084	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 10:06:30 PDT

Everbridge PSPS Notification 2020-10-26-0956 All Counties-DE

Notification ID	Message Title	Sent On
564878393787030	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino Co at 0614.	Oct 26, 2020 09:40:50 PDT
565015832739327	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0855.	Oct 26, 2020 09:46:23 PDT
565015832739333	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 0857.	Oct 26, 2020 09:50:02 PDT
565015832739339	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Ventura County at 0645.	Oct 26, 2020 09:54:18 PDT
565015832739343	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Los Angeles County at 0645.	Oct 26, 2020 09:56:32 PDT

Everbridge PSPS Notification 2020-10-26-1006 All Counties IMDE

Notification ID	Message Title	Sent On
565015832739316	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.	Oct 26, 2020 09:40:38 PDT
564878393787036	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura Co.	Oct 26, 2020 09:45:23 PDT
564878393787046	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura Co.	Oct 26, 2020 09:49:36 PDT
564878393787057	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.	Oct 26, 2020 09:53:42 PDT
564878393787061	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Ventura Co.	Oct 26, 2020 09:58:00 PDT
564878393787071	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.	Oct 26, 2020 10:01:41 PDT
565015832739355	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Kern County.	Oct 26, 2020 10:01:48 PDT
564878393787084	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Los Angeles County.	Oct 26, 2020 10:06:30 PDT

Everbridge PPS Notification Audit Report 2020-10-26-2219-San Bernardino-IMDE

Notification ID	Message Title	Sent On
565153271692702	Important Information from SCE – Imminent Public Safety Power Shutoff (PPS) of JEEP circuit in San Bernardino County	Oct 26, 2020 22:19:48 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 10:20 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) of JEEP circuit in San Bernardino County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- Circuit: **JEEP (Segment 1)**
- County: **San Bernardino County**
- Unincorporated County Area: **Lake Arrowhead**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).

- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-26-2250-San Bernardino-DE

Notification ID	Message Title	Sent On
565153271692723	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 2227	Oct 26, 2020 22:50:55 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 10:51 PM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in San Bernardino County at 2227

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in **San Bernardino County**. Impacted circuits and locations are:

- Circuit: **JEEP (Segment 1)**
- County: **San Bernardino County**
- Unincorporated County Area: **Lake Arrowhead**
- De-Energized Date: **10/26/20**
- De-Energized Time: **22:27**

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PPS Notification Audit Report 2020-10-26-2359-Orange County-IMRE

Notification ID	Message Title	Sent On
565153271692751	Important SCE information – Imminent Public Safety Power Shutoff (PPS) Re-Energization in progress in Orange County	Oct 26, 2020 23:59:03 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Monday, October 26, 2020 11:59 PM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Orange County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- Circuit: **COOLER**
- County: **Orange County**
- Incorporated Cities of: **Lake Forest; Mission Viejo; Rancho Santa Margarita**
- Unincorporated County Area: **Unincorporated communities near Rancho Santa Margarita**
  
- Circuit: **GREEN RIVER**
- County: **Orange County**
- Incorporated City of: **Yorba Linda**
  
- Circuit: **MODJESKA**
- County: **Orange County**
- Incorporated City of: **Rancho Santa Margarita**
- Unincorporated County Area: **East of Dove Canyon**
  
- Circuit: **SIAM**
- County: **Orange County**
- Incorporated City of: **Orange**
- Unincorporated County Area: **El Modena ; Cowan Heights ; Orange Park Acres**
  
- Circuit: **VERA CRUZ**
- County: **Orange County**
- Incorporated City of: **Brea; Placentia; Yorba Linda**
- Unincorporated County Area: **Carbon Canyon**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE

relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](http://sce.com/PSPS).

## Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](http://sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

Notification ID	Message Title	Sent On
565153271692787	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of BIG ROCK circuit in Los Angeles and Ventura Counties	Oct 27, 2020 01:28:56 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 1:29 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of BIG ROCK circuit in Los Angeles and Ventura Counties

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: **BIG ROCK**
- County: **Los Angeles County**
- Unincorporated County Area: **West of Lakeside Park**
- Re-Energized Date: **10/27/2020**
- Re-Energized Time: **01:06**
  
- Circuit: **BIG ROCK**
- County: **Ventura County**
- Incorporated City of: **Simi Valley**
- Unincorporated County Area: **Santa Susana Knolls**
- Re-Energized Date: **10/27/2020**
- Re-Energized Time: **01:06**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-0201 All Counties-IMRE

Notification ID	Message Title	Sent On
565153271692798	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County	Oct 27, 2020 01:51:28 PDT
565153271692802	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County	Oct 27, 2020 02:01:21 PDT

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 1:52 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- Circuit: **CABANA**
- County: **San Bernardino County**
- Incorporated City of: **Fontana**
  
- Circuit: **ECHO**
- County: **San Bernardino County**
- Incorporated City of: **San Bernardino**
- Unincorporated County Area: **Del Rosa**
  
- Circuit: **SWEETWATER**
- County: **San Bernardino County**
- Incorporated City of: **San Bernardino**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).

- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](https://www.sce.com/pmpsalerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 2:02 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- Circuit: **CABANA**
- County: **Riverside County**
- Incorporated City of: **Jurupa Valley**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-0537 All Counties-RE

Notification ID	Message Title	Sent On
565153271692926	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of VERA CRUZ circuit in Orange County	Oct 27, 2020 05:03:43 PDT
565153271692956	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of CABANA circuit in Riverside and San Bernardino Counties	Oct 27, 2020 05:23:57 PDT
565153271692970	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of SWEETWATER circuit in San Bernardino County	Oct 27, 2020 05:37:02 PDT

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 5:04 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of VERA CRUZ circuit in Orange County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: **VERA CRUZ**
- County: **Orange County**
- Incorporated City of: **Brea; Placentia; Yorba Linda**
- Unincorporated County Area: **Carbon Canyon**
- Re-Energized Date: **10/27/2020**
- Re-Energized Time: **02:38**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 5:24 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of CABANA circuit in Riverside and San Bernardino Counties

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: **CABANA**
- County: **Riverside County**
- Incorporated City of: **Jurupa Valley**
- Re-Energized Date: **10/27/2020**
- Re-Energized Time: **03:58**
  
- Circuit: **CABANA**
- County: **San Bernardino County**
- Incorporated City of: **Fontana**
- Re-Energized Date: **10/27/2020**
- Re-Energized Time: **03:58**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 5:37 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization of SWEETWATER circuit in San Bernardino County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: **SWEETWATER**
- County: **San Bernardino County**
- Incorporated City of: **San Bernardino**
- Re-Energized Date: **10/27/2020**
- Re-Energized Time: **04:42**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PPS Notification Audit Report 2020-10-27-0551 Riverside County-IMRE

Notification ID	Message Title	Sent On
565153271692989	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County	Oct 27, 2020 05:51:16 PDT

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 5:52 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- Circuit: **GOWAN**
- County: **Riverside County**
- Incorporated City of: **Jurupa Valley**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspis](https://www.sce.com/pspis).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

Everbridge PPS Notification Audit Report 2020-10-27-1001-Riverside County- IMDE

Notification ID	Message Title	Sent On
564740954832268	Important Information from SCE – Imminent Public Safety Power Shutoff (PPSP) in Riverside County.	Oct 27, 2020 10:01:35 PDT

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 10:02 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: BLACKHILLS**
- **County: Riverside County**
- **Incorporated City of: Jurupa Valley**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1002-Riverside County- IMRE

Notification ID	Message Title	Sent On
564740954832270	Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.	Oct 27, 2020 10:02:30 PDT

## Janelle Hartley

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 10:03 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Imminent Public Safety Power Shutoff (PSPS) in Riverside County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to current weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) in the next 1 to 4 hours to reduce the risk of wildfire ignition though the PSPS may occur earlier or later depending on actual weather conditions. Areas that may be impacted include:

- **Circuit: GALENA**
- **County: Riverside County**
- **Incorporated City of: Jurupa Valley**

This Imminent De-Energization warning expires after four hours. If one or more circuits listed here are de-energized by SCE due to PSPS, a De-Energized notification confirming date and time of the PSPS event will be sent. However, **if this imminent notice expires without de-energization, the listed circuit(s) remain on SCE's monitor list and subject to PSPS.**

SCE's Incident Management Team (IMT) is in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE may shut off the power on specific circuits within the next 1-4 hours. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1011-All Counties- IMRE

Notification ID	Message Title	Sent On
565153271693013	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County	Oct 27, 2020 06:05:08 PDT
564740954832244	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Orange County.	Oct 27, 2020 09:49:03 PDT
564740954832253	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.	Oct 27, 2020 09:52:20 PDT
564740954832284	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.	Oct 27, 2020 10:11:22 PDT

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 6:05 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- Circuit: **VERDEMONT**
- County: **San Bernardino County**
- Incorporated City of: **San Bernardino**
- Unincorporated County Area: **Muscovy; Keenbrooke; Cosy Dell; Cajon**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 9:49 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Orange County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: RUSTIC**
- **County: Orange**
- **Incorporated City of: Rancho Santa Margarita**
- **Unincorporated County Area: TRABUCO CANYON; Santiago Peak; Modjeska Peak**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 9:53 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: RUSTIC**
- **County: Riverside**
- **Unincorporated County Area: Santiago Peak**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 10:12 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: SAND CANYON**
- **County: Los Angeles**
- **Incorporated City of: Santa Clarita**
- **Unincorporated County Area:** Agua Dulce Canyon; Mint Canyon south of Mint Canyon Elementary school going south on Sand Canyon Rd; Sand Canyon; Soledad Canyon; Long Canyo; Russ; Lang; Magic Mountain; North Fork Ranger Station Water Pump

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report with Contacts 2020-10-27-2117 All Counties-RE

Notification ID	Message Title	Sent On
564740954833181	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 21:01:04 PDT
564740954833185	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.	Oct 27, 2020 21:08:09 PDT
564740954833187	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 21:10:55 PDT
564740954833190	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 21:14:18 PDT
564740954833191	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 21:17:17 PDT

Everbridge PPS Notification Audit Report 2020-10-27-1055-Los Angeles County- RE

Notification ID	Message Title	Sent On
564740954832347	Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.	Oct 27, 2020 10:39:24 PDT
564740954832357	Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.	Oct 27, 2020 10:44:53 PDT
564740954832388	Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.	Oct 27, 2020 10:55:54 PDT

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 10:40 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **PARTIALLY RE-ENERGIZE** the following circuit(s):

- **Circuit: VIDEO**
- **County: Los Angeles**
- **Unincorporated County Area: Kinneloa Mesa; Eaton Canyon; Mount Wilson**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 08:53 (Partial)**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pssp](https://www.sce.com/pssp).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 10:45 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **PARTIALLY RE-ENERGIZE** the following circuit(s):

- **Circuit: VERDUGO**
- **County: Los Angeles**
- **Incorporated City of: Glendale and La Canada Flintridge**
- **Unincorporated County Area: La Crescenta Montrose; Uninco along Big Tujunga Canyon Rd; Wildwood; Sunland**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 09:49**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 10:56 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **PARTIAL RE-ENERGIZE** the following circuit(s):

- **Circuit: SAND CANYON**
- **County: Los Angeles**
- **Incorporated City of: Santa Clarita**
- **Unincorporated County Area: Agua Dulce Canyon; Mint Canyon south of Mint Canyon Elementary school going south on Sand Canyon Rd; Sand Canyon; Soledad Canyon; Long Canyon; Russ; Lang; Magic Mountain; North Fork Ranger Station Water Pump**
- 
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1017**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1110-Riverside County- DE

Notification ID	Type	Message Title	Sent On
564878393789284	DE	De-Energize PSPS Notification Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Riverside County at 0922.	Oct 27, 2020 11:05:45 PDT
564878393789290	DE	Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Riverside County at 0936.	Oct 27, 2020 11:10:36 PDT

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:06 AM  
**To:** SCE Liaison Officer  
**Subject:** De-Energize PSPS Notification Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Riverside County at 0922.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in Riverside County.

Impacted circuits and locations are:

- Circuit: BLACKHILLS
- County: Riverside County
- Incorporated City of: Jurupa Valley
- Unincorporated County Area: Rubidoux ; Camino Real Elementary School ; Rustic Lane Elementary School
- De-Energized Date: 10/27/20
- De-Energized Time: 0922

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:11 AM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Public Safety Power Shutoff (PSPS) Occurred in Riverside County at 0936.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

Due to weather conditions, SCE conducted a Public Safety Power Shutoff (PSPS) to circuits in Riverside County.

Impacted circuits and locations are:

- Circuit: GALENA
- County: Riverside
- Incorporated City of: Jurupa Valley
- Unincorporated County Area: None
- De-Energized Date: 10/26/20
- De-Energized Time: 0936

SCE is also notifying customers on the affected circuits to inform them about the shutoff. SCE understands the inconvenience of shutting off electric service. Safety is SCE's first priority. This Public Safety Power Shutoff (PSPS) action was taken with the safety of our customers and the public in mind, and to maintain the integrity of the electric system for all of our customers.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe.

**Power will be restored as weather conditions improve, crews conduct inspections, any necessary repairs have been made, and we determine it is safe to re-energize lines. In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.**

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** Due to current weather conditions, SCE has shut off power in your area. Check your email for details and visit [www.sce.com/PSPS](http://www.sce.com/PSPS).

**Web and Maps**

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](http://sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pmpsalerts](http://sce.com/pmpsalerts).

Everbridge PPS Notification Audit Report 2020-10-27-1116 Los Angeles County-RE

Notification ID	Message Title	Sent On
564878393789296	Important SCE information – Public Safety Power Shutoff (PSPS) Partial Re-Energization in Los Angeles County.	Oct 27, 2020 11:16:05 PDT

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:16 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Partial Re-Energization in Los Angeles County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **partially RE-ENERGIZE** the following circuit(s):

- **Circuit:** **BOOTLEGGER**
- **County:** **Los Angeles**
- **Incorporated City of:** **[enter city name]**
- **Unincorporated County Area:** **Acton ; Surrounding area around Acton ; Vincent ; Paris ; Singing Springs ; Hidden Springs ; Angles Forest Hwy to Singing Springs ; Aliso Canyon Rd**
- **Re-Energized Date:** **10/27/20**
- **Re-Energized Time:** **1040**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1123 All Counties Rpt 1

Notification ID	Message Title	Sent On
564740954832409	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.	Oct 27, 2020 11:06:58 PDT
564740954832412	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Oct 27, 2020 11:10:11 PDT
564740954832422	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.	Oct 27, 2020 11:13:43 PDT
564740954832428	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.	Oct 27, 2020 11:19:37 PDT
564740954832435	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Oct 27, 2020 11:23:00 PDT

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:07 AM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.  
**Attachments:** SCE+LNO+POC+SAN+BERNARDINO+2020-10-27+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:10 AM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.  
**Attachments:** SCE+LNO+POC+RIVERSIDE+2020-10-27+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:14 AM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.  
**Attachments:** SCE+LNO+POC+ORANGE+2020-10-27+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Orange County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Estela Aguilar

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:20 AM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Ventura County.  
**Attachments:** SCE+LNO+POC+VENTURA+2020-10-27+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Ventura County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:23 AM  
**To:** Estela Aguilar  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.  
**Attachments:** SCE+LNO+POC+LOS+ANGELES+2020-10-27+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1129 San Bernardino County-IMRE

Notification ID	Message Title	Sent On
564878393789313	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 11:29:23 PDT

## Estela Aguilar

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:30 AM  
**To:** Estela Aguilar  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- Circuit: AVANTI
- County: San Bernardino
- Incorporated City of: San Bernardino
- Unincorporated County Area: Verdemont ; University Heights

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.

- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PPS Notification Audit Report 2020-10-27-1149 San Bernardino County-IMRE

Notification ID	Message Title	Sent On
564740954832462	Important SCE information – Imminent Public Safety Power Shutoff (PPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 11:40:26 PDT
564740954832475	Important SCE information – Imminent Public Safety Power Shutoff (PPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 11:49:04 PDT

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:41 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: BEAR VALLEY**
- **County: San Bernardino**
- **Incorporated City of: Big Bear Lake**
- **Unincorporated County Area:** Mill Creek Canyon; Angelus Oaks; Pinezanita; Converse Flats; Seven Oaks; Forest Falls
- 

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:49 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: CALSTATE**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Devils Canyon**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PPS Notification Audit Report 2020-10-27-1155 All Counties-RE

Notification ID	Message Title	Sent On
564740954832453	Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.	Oct 27, 2020 11:32:52 PDT
564740954832458	Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Ventura County.	Oct 27, 2020 11:35:07 PDT
564740954832488	Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Ventura County.	Oct 27, 2020 11:55:20 PDT

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:33 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **PARTIALLY RE-ENERGIZE** the following circuit(s):

- **Circuit: ENERGY**
- **County: Los Angeles**
- **Incorporated City of:**
- **Unincorporated County Area: Chatsworth; Fern Ann Falls; Twin Lakes; Deer Lake Highlands; Chatsworth Lake Manor; Oat Mountain Rd to Santa Susana Mountains**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 11:02 (Partial)**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](http://sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](http://sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](http://sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](http://sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](http://sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:35 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Ventura County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **PARTIALLY RE-ENERGIZE** the following circuit(s):

- **Circuit: ENERGY**
- **County: Ventura**
- **Incorporated City of: Simi Valley**
- **Unincorporated County Area: N of Chatsworths Lake Manor; Burro Flats; Area surrounding Chatsworth Peak**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 11:02 (Partial)**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:56 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Ventura County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **PARTIALLY RE-ENERGIZE** the following circuit(s):

- **Circuit: Guitar**
- **County: Ventura**
- **Unincorporated County Area: Unico area East of Camulos; and Uninco area South East of Camulos; Tapo Canyon**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 11:17 (Partial)**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PPS Notification Audit Report 2020-10-27-1159 Los Angeles County-RE

Notification ID	Message Title	Sent On
564740954832498	Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.	Oct 27, 2020 11:59:02 PDT

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 11:59 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **PARTIALLY RE-ENERGIZE** the following circuit(s):

- **Circuit: GUITAR**
- **County: Los Angeles**
- **Incorporated City of: Santa Clarita**
- **Unincorporated County Area: Del Valle; Ninety-nine Oaks; Valencia; Castaic Junction; Sulphur Springs; Castaic**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 11:17 (Partial)**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1235 San Bernardino County-IMRE

Notification ID	Message Title	Sent On
564740954832555	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:28:36 PDT
564740954832565	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:32:09 PDT
564740954832566	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:33:17 PDT
564740954832568	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:35:32 PDT

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:29 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: SUTT**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Waterman Canyon**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Carolina Ceballos

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:32 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: NORTHPARK**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Kendall FR ; Devore Heights; Devore; Tokay Hills; W of Verdemont; Mens and Womens Prison east of Muscoy; Heading North on Wendy Ranch Rd and Martin Ranch Rd; Along Cable Canyon Rd**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:33 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: AMETHYST**
- **County: San Bernardino**
- **Incorporated City of: Rancho Cucamonga**
- **Unincorporated County Area: unincorporated communities along Haven Ave and Snow Drop Rd located north of Rancho Cucamonga**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:36 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: VARGAS**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1246 All Counties-IMRE

Notification ID	Message Title	Sent On
564740954832569	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:37:01 PDT
564740954832573	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:40:17 PDT
564740954832574	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:41:06 PDT
564740954832579	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.	Oct 27, 2020 12:43:29 PDT
564740954832583	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:46:58 PDT

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:37 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: KIMBERLY**
- **County: San Bernardino**
- **Unincorporated County Area: Rim of the World**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:40 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: CLUB OAKS**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Valley View Park; Skyland**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:41 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: IMPALA**
- **County: San Bernardino**
- **Incorporated City of: Fontana**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pssp](https://www.sce.com/pssp).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.

- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:44 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: GALENA**
- **County: Riverside**
- **Incorporated City of: Jurupa Valley**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:47 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: VERDEMONT**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Muscoy; Keenbrooke; Cosy Dell; Cajon**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1331 All Counties-IMRE

Notification ID	Message Title	Sent On
564740954832587	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.	Oct 27, 2020 12:48:11 PDT
564740954832594	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 12:50:44 PDT
564740954832617	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 13:06:11 PDT
564740954832624	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 13:07:44 PDT
564740954832629	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.	Oct 27, 2020 13:08:41 PDT
564740954832677	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.	Oct 27, 2020 13:31:51 PDT

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:48 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: GOWAN**
- **County: Riverside**
- **Incorporated City of: Jurupa Valley**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 12:51 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: ACOSTA**
- **County: San Bernardino**
- **Incorporated City of: Fontana, Rancho Cucamonga**
- **Unincorporated County Area: SAN SEVAINE FLATS**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 1:06 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: FERRARA**
- **County: San Bernardino**
- **Incorporated City of: Upland**
- **Unincorporated County Area: Ferrara**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 1:08 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: CAMP BALDY**
- **County: San Bernardino**
- **Unincorporated County Area: Mt. Baldy**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 1:09 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: CAMP BALDY**
- **County:** Los Angeles
- **Unincorporated County Area:** Pearblossom

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 1:32 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: JEEP**
- **County: San Bernardino**
- **Unincorporated County Area: Lake Arrowhead**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PPS Notification Audit Report 2020-10-20-1346-All County-IMRE

Notification ID	Message Title	Type	Sent On
564740954832684	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.	IMRE	Oct 27, 2020 13:42:01 PDT
564740954832689	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.	IMRE	Oct 27, 2020 13:46:08 PDT

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 1:42 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: RED BOX**
- **County: Los Angeles**
- **Incorporated City of: Along Angeles Crest Hwy**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 1:46 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: Staghorn**
- **County: Riverside**
- **Incorporated City of: Jurupa Valley**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team

- Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 5:02 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: SAND CANYON**
- **County:** Los Angeles
- **Incorporated City of: Santa Clarita**
- **Unincorporated County Area:** Agua Dulce Canyon; Mint Canyon south of Mint Canyon Elementary school going south on Sand Canyon Rd; Sand Canyon; Soledad Canyon; Long Canyon; Russ; Lang; Magic Mountain; North Fork Ranger Station Water Pump

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 5:06 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in Riverside County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- **Circuit: CLUB OAKS**
- **County: Riverside**
- **Incorporated City of: Jurupa Valley**
- **Unincorporated County Area: Rubidoux; Camino Real Elementary School; Rustic Lane Elementary School**

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.

- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PSPS Notification Audit Report 2020-10-27-1906-All County-RE

Notification ID	Message Title	Sent On
564740954832807	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Riverside County.	Oct 27, 2020 15:16:44 PDT
564740954832810	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.	Oct 27, 2020 15:18:43 PDT
564740954832813	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 15:21:05 PDT
564740954832856	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 16:00:39 PDT
564740954832894	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.	Oct 27, 2020 16:27:44 PDT
564740954832910	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 16:42:44 PDT
564740954832916	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 16:48:27 PDT
564740954832922	**CORRECTION** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in San Bernardino County.	Oct 27, 2020 16:51:03 PDT
564740954832967	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Riverside County.	Oct 27, 2020 17:34:56 PDT
564740954833055	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 18:56:01 PDT
564740954833067	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 19:06:23 PDT

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 3:17 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Riverside County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: GOWAN**
- **County: Riverside**
- **Incorporated City of: Jurupa Valley**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 06:55**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 3:19 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: SHOVEL**
- **County: Los Angeles**
- **Incorporated City of: Palmdale**
- **Unincorporated County Area: Escondido Canyon Rd between Aqua Dulce Canyon and Acton; Kashmere Canyon; Boiling Point**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 11:44**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 3:21 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: VERDEMONT**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Muscoy; Keenbrooke; Cosy Dell; Cajon**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 07:56**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 4:01 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: JEEP**
- **County: San Bernardino**
- **Unincorporated County Area: Lake Arrowhead**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 15:41**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 4:28 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: LOPEZ**
- **County: Los Angeles**
- **Incorporated City of: San Fernando**
- **Unincorporated County Area: Indian Springs; El Merrie Dell**
- **Re-Energized Date: 10/26**
- **Re-Energized Time: 22:03**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 4:43 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: CALSTATE**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Devil's Canyon**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1349**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 4:49 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: ACOSTA**
- **County: San Bernardino**
- **Incorporated City of: Fontana, Rancho Cucamonga**
- **Unincorporated County Area: SAN SEVAINE FLATS**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1336**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 4:51 PM  
**To:** SCE Liaison Officer  
**Subject:** **\*\*CORRECTION\*\*** Important SCE information – Public Safety Power Shutoff (PSPS) PARTIAL Re-Energization in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **PARTIALLY RE-ENERGIZE** the following circuit(s):

- **Circuit: ACOSTA**
- **County: San Bernardino**
- **Incorporated City of: Fontana, Rancho Cucamonga**
- **Unincorporated County Area: SAN SEVAINE FLATS**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 13:36 (Partial)**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 5:35 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Riverside County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: GALENA**
- **County: Riverside**
- **Incorporated City of: Jurupa Valley**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1705**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Janelle Hartley

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 6:56 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: CLUB OAKS**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Valley View Park; Skyland**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1715**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Janelle Hartley

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 7:07 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: IMPALA**
- **County: San Bernardino**
- **Incorporated City of: Fontana**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1808**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-2004 All Counties Report 2

Notification ID	Message Title	Sent On
564740954833097	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Ventura County.	Oct 27, 2020 19:43:07 PDT
564740954833104	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.	Oct 27, 2020 19:53:12 PDT
564740954833107	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.	Oct 27, 2020 19:56:05 PDT
564740954833114	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.	Oct 27, 2020 19:59:59 PDT
564740954833118	Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.	Oct 27, 2020 20:04:07 PDT

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 7:43 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Ventura County.  
**Attachments:** SCE+LNO+POC+VENTURA+2020-10-27+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.

- [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 7:54 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for San Bernardino County.  
**Attachments:** SCE+LNO+POC+SAN+BERNARDINO+2020-10-27+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **San Bernardino County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 7:56 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Riverside County.  
**Attachments:** SCE+LNO+POC+RIVERSIDE+2020-10-27+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Riverside County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 8:00 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Orange County.  
**Attachments:** SCE+LNO+POC+ORANGE+2020-10-27+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Orange County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 8:04 PM  
**To:** SCE Liaison Officer  
**Subject:** Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) UPDATE for Los Angeles County.  
**Attachments:** SCE+LNO+POC+LOS+ANGELES+2020-10-27+Rpt+2.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

**Please refer to the attached file for UPDATED status and periods of concern for specific circuits in your county.**

Due to weather conditions, SCE may need to shut off power (a Public Safety Power Shutoff or PSPS) to electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and/or unincorporated areas in **Los Angeles County**. SCE is also notifying customers on the affected circuits about the potential for shutoff, giving them time to prepare.

SCE's Incident Management Team continues to monitor the weather in real time. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential Public Safety Power Shutoffs. Additional targeted notifications will also be sent, as needed, to provide time-sensitive de-energize or re-energize information. Erratic or sudden onset of hazardous conditions that jeopardize public safety may impact SCE's ability to provide advanced notice to customers. A shutoff could occur sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will notify you as conditions change.

There also might be weather-related or other unplanned repair outages in the areas designated for potential Public Safety Power Shutoffs. Information on these unplanned outages can be found at [sce.com/outage](https://www.sce.com/outage).

**Recommended Language to Share with the Public:** Weather conditions have changed and we are providing an updated status for all circuits with potential for power shutoff in your area. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-2056 All Counties-RE

Notification ID	Message Title	Sent On
564740954833147	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.	Oct 27, 2020 20:35:48 PDT
564740954833152	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 20:37:40 PDT
564740954833159	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 20:45:19 PDT
564740954833164	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.	Oct 27, 2020 20:47:12 PDT
564740954833175	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Riverside County.	Oct 27, 2020 20:56:54 PDT

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 8:36 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: FERRARA**
- **County: Los Angeles**
- **Unincorporated County Area: MOUNT BALDY ;SAN ANTONIO HEIGHTS**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1949**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Carolina Ceballos

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 8:38 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: FERRARA**
- **County: San Bernardino**
- **Incorporated City of: Upland**
- **Unincorporated County Area: Ferrara**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1949**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Carolina Ceballos

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 8:45 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: CAMP BALDY**
- **County: San Bernardino**
- **Unincorporated County Area: Mt. Baldy**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1949**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Carolina Ceballos

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 8:47 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: CAMP BALDY**
- **County: Los Angeles**
- **Unincorporated County Area: Pearblossom**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1949**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Carolina Ceballos

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 8:57 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Riverside County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: BLACKHILLS**
- **County: Riverside**
- **Incorporated City of: Jurupa Valley**
- **Unincorporated County Area: Rubidoux; Camino Real Elementary School; Rustic Lane Elementary School**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1740**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PSPS Notification Audit Report 2020-10-27-2143 All Counties-RE

Notification ID	Message Title	Sent On
564740954833192	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.	Oct 27, 2020 21:18:44 PDT
564740954833193	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 27, 2020 21:20:44 PDT
564740954833204	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.	Oct 27, 2020 21:40:34 PDT
564740954833206	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Ventura County.	Oct 27, 2020 21:43:49 PDT

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 9:19 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: SIAM**
- **County: Orange**
- **Incorporated City of: Orange**
- **Unincorporated County Area: El Modena; Cowan Heights; Orange Park Acres**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1151**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 9:21 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: ECHO**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Del Rosa**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 0520**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 9:41 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: NEPAL**
- **County: Orange**
- **Incorporated City of: Orange**
- **Unincorporated County Area: ORANGE PARK ESTATES; Lolita St**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 0111**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Tuesday, October 27, 2020 9:44 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Ventura County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: TAPO**
- **County: Ventura**
- **Incorporated City of: Simi Valley**
- **Unincorporated County Area: Rounding Tapo Canyon Park going north on Tapo Canyon Rd within the Santa Susana Mountains**
- **Re-Energized Date: 10/26**
- **Re-Energized Time: 2337**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-28-1051 San Bernardino-IMRE

Notification ID	Message Title	Sent On
564878393790994	Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino Co.	Oct 28, 2020 10:51:41 PDT

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 10:52 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Imminent Public Safety Power Shutoff (PSPS) Re-Energization in progress in San Bernardino Co.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have completed inspections, made any necessary repairs, and determined it is safe to begin **RE-ENERGIZING** the following circuit(s) or segments of circuit(s):

- Circuit: MACIEL
- County: San Bernardino
- Incorporated City of: Chino Hills
- Unincorporated County Area: none

SCE will also begin notifying customers that power will be turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, know that SCE crews are working safely and as quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** SCE will begin turning power back on in your area. SCE has inspected its electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.

- [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PSPS Notification Audit Report 2020-10-28-1152 All Counties-RE

Notification ID	Message Title	Sent On
564878393790978	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 28, 2020 10:44:25 PDT
564740954834138	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 28, 2020 11:33:06 PDT
564740954834165	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.	Oct 28, 2020 11:50:28 PDT
564878393791118	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles Co.	Oct 28, 2020 11:52:45 PDT

## Carolina Ceballos

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 10:45 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: ACOSTA
- County: San Bernardino
- Incorporated City of: Fontana, Rancho Cucamonga
- Unincorporated County Area: San Sevaine Flats
- Re-Energized Date: 10/28/20
- Re-Energized Time: 0834

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 11:33 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: BEAR VALLEY**
- **County: San Bernardino**
- **Incorporated City of: Big Bear Lake**
- **Unincorporated County Area: Mill Creek Canyon; Angelus Oaks; Pinezanita; Converse Flats; Seven Oaks; Forest Falls**
- **Re-Energized Date: 10/28**
- **Re-Energized Time: 1024**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).

- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 11:51 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: RED BOX**
- **County: Los Angeles**
- **Unincorporated County Area: Along Angeles Crest Hwy**
- **Re-Energized Date: 10/28**
- **Re-Energized Time: 1120**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Carolina Ceballos

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 11:53 AM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles Co.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- Circuit: RED BOX
- County: Los Angeles
- Incorporated City of: None
- Unincorporated County Area: Along Angeles Crest Hwy
- Re-Energized Date: 10/28/20
- Re-Energized Time: 11:20

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PSPS Notification Audit Report 2020-10-28-1244 All Counties-RE

Notification ID	Message Title	Sent On
564740954834223	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 28, 2020 12:23:25 PDT
564740954834268	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.	Oct 28, 2020 12:42:39 PDT
564740954834273	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Riverside County.	Oct 28, 2020 12:44:17 PDT

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 12:24 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: MACIEL**
- **County: San Bernardino**
- **Incorporated City of: Chino Hills**
- **Re-Energized Date: 10/28**
- **Re-Energized Time: 1159**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 12:43 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: RUSTIC**
- **County: Orange**
- **Incorporated City of: Rancho Santa Margarita**
- **Unincorporated County Area: TRABUCO CANYON; Santiago Peak; Modjeska Peak**
- **Re-Energized Date: 10/28**
- **Re-Energized Time: 1220**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

## Mara Kahunale Portlock

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 12:44 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Riverside County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: RUSTIC**
- **County: Riverside**
- **Unincorporated County Area: Santiago Peak**
- **Re-Energized Date: 10/28**
- **Re-Energized Time: 1220**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**

- SCE Business Resiliency Team
  - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
  - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

Everbridge PSPS Notification Audit Report 2020-10-28-1534 Orange County-RE

Notification ID	Message Title	Sent On
564740954834573	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.	Oct 28, 2020 15:34:21 PDT

## Mara Kahunale Portlock

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 3:35 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Orange County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: MODJESKA**
- **County: Orange**
- **Incorporated City of: Rancho Santa Margarita**
- **Unincorporated County Area: East of Dove Canyon**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1112**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspalerts](http://sce.com/pspalerts).

Everbridge PSPS Notification Audit Report 2020-10-28-1556 All Counties-RE

Notification ID	Message Title	Sent On
564740954834576	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.	Oct 28, 2020 15:37:00 PDT
564740954834580	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 28, 2020 15:38:22 PDT
564740954834607	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 28, 2020 15:47:18 PDT
564740954834618	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.	Oct 28, 2020 15:54:24 PDT
564740954834622	Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.	Oct 28, 2020 15:56:54 PDT

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 3:37 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: DAVENPORT**
- **County: Los Angeles**
- **Unincorporated County Area: Agua Dulce; Southwest of Agua Dulce; Boiling Point; White Heather; Sleepy Valley; Northeast of Forest Park; The Oaks**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1139**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 3:39 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: KIMBERLY**
- **County: San Bernardino**
- **Unincorporated County Area: Rim of the World**
- **Re-Energized Date: 10/27**
- **Re-Energized Time: 1752**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pssp](https://www.sce.com/pssp).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 3:48 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: ICE HOUSE**
- **County: San Bernardino**
- **Unincorporated County Area: Mount Baldy; Ice House Canyon Road**
- **Re-Energized Date: 10/28**
- **Re-Energized Time: 1502**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/psps](https://www.sce.com/psps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 3:55 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in San Bernardino County.

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: CLUB OAKS**
- **County: San Bernardino**
- **Incorporated City of: San Bernardino**
- **Unincorporated County Area: Valley View Park; Skyland**
- **Re-Energized Date: 10/28**
- **Re-Energized Time: 1502**

**A notification sent 10/27 at 18:56 should have said PARTIAL Re-Energization. This notice is correctly denoting that a full Re-Energization has occurred.**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).

- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pspss](https://www.sce.com/pspss).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](https://www.sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](https://www.sce.com/pspsalerts).

## Gabriel R Grajeda

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 3:57 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) Re-Energization in Los Angeles County.

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected the lines, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** the following circuit(s):

- **Circuit: SAND CANYON**
- **County: Los Angeles**
- **Incorporated City of: Santa Clarita**
- **Unincorporated County Area: Agua Dulce Canyon; Mint Canyon south of Mint Canyon Elementary; school going south on Sand Canyon Rd; Sand Canyon ; Soledad Canyon; Long Canyon; Russ; Lang; Magic Mountain; North Fork Ranger Station Water Pump**
- **Re-Energized Date: 10/28**
- **Re-Energized Time: 1524**

SCE will notify customers when power has been turned back on. **In most cases, power will be restored within 24 hours from the end of the period of concern for the electrical circuit.** SCE's Incident Management Team will continue to monitor conditions and coordinate with government agencies.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

The SCE Liaison Officer typically sends update notifications twice a day, providing a rolling 72-hour advance warning of potential PSPS events for this county. Additional targeted notifications provide alerts with all time-sensitive de-energize or re-energize information.

**Recommended Language to Share with the Public:** SCE is turning the power back on in your area. We have inspected our electrical lines and equipment, made any necessary repairs, and determined it is safe to turn on the power. Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pssp](https://www.sce.com/pssp).

## How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
  
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
  
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspсалerts](http://sce.com/pspсалerts).

Everbridge PSPS Notification Audit Report 2020-10-28-1949 All Counties Report 1

Notification ID	Message Title	Sent On
564740954834557	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Kern County.	Oct 28, 2020 15:24:00 PDT
564740954834756	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in RIVERSIDE County.	Oct 28, 2020 17:59:01 PDT
564740954834793	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in LOS ANGELES County.	Oct 28, 2020 18:25:36 PDT
564740954834797	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in SAN BERNARDINO County.	Oct 28, 2020 18:28:17 PDT
564740954834873	Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in ORANGE County.	Oct 28, 2020 19:49:34 PDT

## Mara Kahunale Portlock

---

**From:** SCELiaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 3:24 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in Kern County.  
**Attachments:** SCE+LNO+POC+2020-10-28+UPDATE+Kern+County+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.
    - [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.

- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 5:59 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in RIVERSIDE County.  
**Attachments:** SCE+LNO+POC+RIVERSIDE+2020-10-28+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.

- [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 6:26 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in LOS ANGELES County.  
**Attachments:** SCE+LNO+POC+LOS+ANGELES+2020-10-28+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.

- [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 6:28 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in SAN BERNARDINO County.  
**Attachments:** SCE+LNO+POC+SAN+BERNARDINO+2020-10-28+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.

- [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

## Nora Mendoza

---

**From:** SCEliaisonOfficer@sce.com <noreply@everbridge.net>  
**Sent:** Wednesday, October 28, 2020 7:50 PM  
**To:** SCE Liaison Officer  
**Subject:** Important SCE information – Public Safety Power Shutoff (PSPS) EVENT CONCLUDED in ORANGE County.  
**Attachments:** SCE+LNO+POC+ORANGE+2020-10-28+Rpt+1.xlsx

[Please click here to acknowledge receipt of this message](#)

This message is from the Southern California Edison Liaison Officer for official use by local / tribal governments and public safety partners.

SCE crews have inspected any lines that were de-energized due to PSPS, made any necessary repairs, and determined it was safe to **RE-ENERGIZE** all circuits in your county. SCE's Incident Management Team is standing down and both SCE systems and staff have returned to normal status.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to a PSPS, know that SCE crews are working as safely and quickly as possible to restore service. SCE relies on forecast data provided by in-house meteorologists, fire scientists, and other technical staff. Note that weather forecasts on radio and television may provide different information.

**Recommended Language to Share with the Public:** The power shutoff in your area has concluded. Customers in this area, however, may experience other weather-related or unplanned repair outages not related to the Public Safety Power Shutoff (PSPS). Check your email for details and visit [sce.com/PSPS](https://www.sce.com/PSPS).

### Web and Maps

- PDFs of High Fire Risk Area (HFRA) circuit maps and GIS layers may be found, by county, at [sce.com/maps](https://www.sce.com/maps).
- Information about SCE's Public Safety Power Shutoff (PSPS) program is at [sce.com/PSPS](https://www.sce.com/PSPS).
- Access SCE's non-PSPS outage information page at [sce.com/outages](https://www.sce.com/outages).
- Access information on weather conditions at [sce.com/fireweather](https://www.sce.com/fireweather).
- SCE's post-PSPS reports are available at [sce.com/pmps](https://www.sce.com/pmps).

### How to Contact Us

- **First Responders and Emergency Managers: Please DO NOT share this information with the public.**
  - SCE Business Resiliency Team
    - Business Resiliency Duty Manager hotline is **(800) 674-4478**. This is a 24/7 phone line that can be used outside of PSPS events as well as during activations.
    - [BusinessResiliencyDutyManager@sce.com](mailto:BusinessResiliencyDutyManager@sce.com). The Business Resiliency Duty Manager mailbox is only monitored during activations.
- **Public Officials: Please DO NOT share this information with the public.**
  - SCE Liaison Officer (LNO)
    - LNO hotline is 800-737-9811. This 24/7 phone line is for use by local government and tribal officials only and it's monitored only during emergency activations.

- [SCELiaisonOfficer@sce.com](mailto:SCELiaisonOfficer@sce.com). The LNO mailbox is for use by local government officials and only monitored during emergencies or PSPS activations.
- **Members of the Public: Please DO share this information with your residents on your website or social media.**
  - 800-611-1911 is for outage-specific Customer Service issues.
  - 800-684-8123 is for all other billing and service inquiries.
  - [sce.com/PSPS](http://sce.com/PSPS) is the site where customers may learn more about PSPS events in their area.
  - Update customer contact information at [sce.com/pspsalerts](http://sce.com/pspsalerts).

# Attachment B

## Critical Infrastructure and Customer Notifications







# Attachment C

## PSPS Activation Customer Notification Messaging

# Customer Automated Notifications - Messaging

## **72 hour Initial – Messaging**

### **Voice/ Voice Mail/TTY:**

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, SCE is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city\_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^^Month Day^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having your resiliency plan ready to execute. SCE will send daily updates until conditions improve. For additional information available, please contact your assigned SCE account representative, go to [SCE.com/psps](http://SCE.com/psps), or call SCE at 1-800-611-1911.

### **Text/SMS:**

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city\_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^^Month Day^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having your resiliency plan ready to execute. SCE will send daily updates until conditions improve. For please contact your assigned SCE account representative, go to [SCE.com/psps](http://SCE.com/psps), or call SCE at 1-800-611-1911.

### **E-Mail:**

**Subject:** Public Safety Power Shutoff (PSPS) Advanced Initial Notification – Critical Infrastructure

**From:** [do\\_not\\_reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

Due to forecast fire weather conditions, SCE is exploring a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^^Month Day^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having your resiliency plan ready to execute. SCE will send daily updates until weather conditions improve.

The following address(es) are within areas being monitored:

Customer Name  
13240 Riverview Dr.  
Victorville, CA 92395-1234  
Service Account: 3-XXX-XX45-67  
Meter: 123456-654321  
Rate: GS-2

For additional information including please visit [sce.com/psps](http://sce.com/psps) , contact your assigned SCE account representative, or call SCE at 1-800-611-1911.

Thank You,  
Southern California Edison

## **48 Hour (Initial)**

### **Voice/ Voice Mail/TTY:**

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city\_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit [sce.com/psps](https://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

### **Text/SMS:**

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city\_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit [sce.com/psps](https://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

### **E-Mail:**

**Subject:** SCE Safety Alert: Public Safety Power Shutoff (PSPS) Initial Notification

**From:** [do\\_not\\_reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.  
Victorville, CA 92395-1234  
Service Account: 3-XXX-XX45-67  
Meter: 123456-654321  
Rate: GS-2

For more info such as expected duration: please visit [www.sce.com/psps](http://www.sce.com/psps). Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

## **24 Hour (Update)**

### **Voice/ Voice Mail/TTY:**

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city\_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit [sce.com/psps](http://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

### **Text/SMS:**

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city\_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit [sce.com/psps](http://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

### **E-Mail:**

**Subject:** SCE Safety Alert: Public Safety Power Shutoff (PSPS) Update Notification

**From:** [do\\_not\\_reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.  
Victorville, CA 92395-1234  
Service Account: 3-XXX-XX45-67

Meter: 123456-654321

Rate: GS-2

For more info such as expected duration: please visit [www.sce.com/psps](http://www.sce.com/psps). Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

### **Imminent De-energization**

#### **Voice/ Voice Mail/TTY:**

This an important safety message from Southern California Edison. Due to forecast fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city\_variable^ area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve. For more information, please visit [sce.com/psps](http://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

#### **Text/SMS:**

SCE Safety Alert: Due to forecast fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city\_variable^ area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve. For more information, please visit [sce.com/psps](http://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

#### **E-Mail:**

**Subject:** SCE Safety Alert: Public Safety Power Shutoff (PSPS) Imminent Shutoff Notice

**From:** [do\\_not\\_reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

Due to forecast fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city\_variable^ area ^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve.

The following address(es) may be affected:

13240 Riverview Dr.

Victorville, CA 92395-1234

Service Account: 3-XXX-XX45-67

Meter: 123456-654321

Rate: GS-2

For more info such as expected duration: please visit [www.sce.com/psps](http://www.sce.com/psps). Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

## **Preparing to Re-Energize (Imminent Restoration)**

### **Voice/ Voice Mail/TTY:**

This is an important safety message from Southern California Edison. SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's restoration process, please visit [sce.com/psps](https://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

### **Text/SMS:**

SCE Safety Alert: SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored. For more information on SCE's restoration process, please visit [sce.com/psps](https://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

### **E-Mail:**

**Subject:** SCE Safety Alert: Public Safety Power Shutoff (PSPS) Preparing to Re Energize Notification

**From:** [do\\_not\\_reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

This is an important safety message from Southern California Edison.

SCE will soon begin the process of inspecting electrical lines in the ^city variable^ area. Provided we find no safety concerns, we will begin the power restoration process. To ensure you are ready for service, turn off or unplug any appliances or equipment that may automatically start when your power is restored.

The following address(es) are within areas SCE is preparing to re-energize:

13240 Riverview Dr.  
Victorville, CA 92395-1234  
Service Account: 3-XXX-XX45-67  
Meter: 123456-654321  
Rate: GS-2

For more information on SCE's restoration process, please visit [sce.com/psps](https://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

## **Shutoff**

### **Voice/ Voice Mail/TTY:**

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to the ^city\_variable^ area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change. For more information, please visit [sce.com/psps](https://sce.com/psps). If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

### **Text/SMS:**

SCE Safety Alert: Southern California Edison has proactively turned off power to the ^city\_variable^ area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change. For more information, please visit [sce.com/psps](https://sce.com/psps). If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

### **E-Mail:**

**Subject:** SCE Safety Alert: Public Safety Power Shutoff (PSPS) Notification

**From:** [do\\_not\\_reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to your area due to fire weather conditions. Your power may be restored at any time. To ensure you are ready for service turn off or unplug any appliances or equipment that may automatically start when your power is restored. We will update you as conditions change.

The following address(es) may be affected:

13240 Riverview Dr.  
Victorville, CA 92395-1234  
Service Account: 3-XXX-XX45-67  
Meter: 123456-654321  
Rate: GS-2

For more information, please visit [sce.com/psps](https://sce.com/psps). If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

## **Restored**

### **Voice /Voice Mail/TTY:**

This is an important safety message from Southern California Edison. Southern California Edison proactively turned off power to the ^city\_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit [sce.com/outage](http://sce.com/outage).

### **Text/SMS:**

SCE Safety Alert: Southern California Edison proactively turned off power to the ^city\_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit [sce.com/outage](http://sce.com/outage).

### **E-Mail:**

**Subject:** SCE Safety Alert: Public Safety Power Shutoff (PSPS) Restoration Notification

**From:** [do\\_not\\_reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

Southern California Edison proactively turned off power to the ^city\_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored.

The following address(es) have been restored:

13240 Riverview Dr.  
Victorville, CA 92395-1234  
Service Account: 3-XXX-XX45-67  
Meter: 123456-654321  
Rate: GS-2

If your power is still off, please call 1-800-611-1911 or visit [sce.com/outage](http://sce.com/outage).

Thank You,

Southern California Edison

## **Avoided/All Clear Notification - Messaging**

### **Voice/ Voice Mail/TTY:**

This is an important safety message from Southern California Edison. Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city\_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more

information, please visit [sce.com/psps](http://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

**Text/SMS:**

SCE Safety Alert: Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city\_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit [sce.com/psps](http://sce.com/psps). Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

**E-Mail:**

**Subject:** SCE Safety Alert: Public Safety Power Shutoff (PSPS) Update Notification

**From:** [do\\_not\\_reply@scewebservices.com](mailto:do_not_reply@scewebservices.com)

Southern California Edison

Due to forecast fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.  
Victorville, CA 92395-1234  
Service Account: 3-XXX-XX45-67  
Meter: 123456-654321  
Rate: GS-2

For more info such as expected duration: please visit [www.sce.com/psps](http://www.sce.com/psps). Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison