



Schedule OBMC
OPTIONAL BINDING MANDATORY CURTAILMENT

Sheet 1

APPLICABILITY

This Schedule is optional for customers who can curtail load on the customer's entire circuit, either on its own or through joint participation with other customers receiving service on the same circuit, by the required amount as defined in the Special Conditions section of this Schedule, for the entire duration of every rotating outage. Additionally, customer must submit an acceptable Optional Binding Mandatory Curtailment plan with SCE, as defined in Special Condition 2, prior to participation in this program. This Schedule exempts participating customers from rotating outages in exchange for partial load curtailment during every rotating outage period.

TERRITORY

Within the entire territory served.

RATES

All charges and provisions of the customers' otherwise applicable Schedule shall apply.

Excess Energy Charge:

\$6 /kWh of Excess Energy

SPECIAL CONDITIONS

1. Optional Binding Mandatory Curtailment Event. An Optional Binding Mandatory Curtailment (OBMC) event will occur when the California Independent System Operator (CAISO) declares a rotating outage within SCE's service area. When an OBMC event is called, SCE will determine if the customer complied with such event by using the baseline measurement method in accordance with Special Condition 5.b. (T)
2. OBMC Plan: A participating customer shall, either solely or jointly with one or more customers on the same circuit, submit an OBMC plan detailing how load curtailment on the entire circuit can be achieved by the plan participants in 5 percent increments to a total load curtailment of 15 percent. The customer is defined as the party(s) that signs and submits the OBMC plan. The plan must also indicate how compliance of the load curtailment can be monitored and enforced. The burden is on the customer(s) to demonstrate that the OBMC plan is realistic, workable, measurable, and enforceable. When any one customer expresses its intent to participate in an OBMC plan, SCE will facilitate an OBMC plan by notifying customers on the circuit and coordinating communication between customers. An OBMC customer with a single tax payer identification number may aggregate the load of two circuits for the purposes of participating in the OBMC program provided: (a) it is the lead customer for both circuits; (b) it has the ability to achieve required load reductions on the total load for the circuits; (c) it agrees to achieve required load reductions on individual circuits subject to the aggregation as required by SCE or the CAISO in response to geographic area constraints; and (d) the customer commits in Form 14-740 that it has not, and will not, receive any payment from any customer on any OBMC circuit for any action related to the OBMC program. All provisions of this Schedule applicable to individual OBMC plans shall apply to the aggregated OBMC plan. (T)
3. Required Amount of Circuit Load Curtailment: Participating customers must have the ability to curtail load on the entire affected circuit(s) by 15 percent.
4. Load Curtailment Increments: Load curtailment will be requested in increments of 5 percent, up to a maximum of 15 percent during an OBMC event.

(Continued)

(To be inserted by utility)
Advice 2500-E
Decision _____

Issued by
Akbar Jazayeri
Vice President

(To be inserted by Cal. PUC)
Date Filed Aug 12, 2010
Effective Sep 11, 2010
Resolution _____

Schedule OBMC
OPTIONAL BINDING MANDATORY CURTAILMENT

Sheet 2

(Continued)

SPECIAL CONDITIONS (Continued)

5. Baseline Measurement for Determination of Required Load Curtailment: Two baseline measurements will be used to determine 1) if the required 15 percent curtailment can be obtained, and 2) if the 10 percent load curtailment has been met.
 - a. Baseline Measurement for Determination of Obtainable 15 percent Curtailment. The potential of curtaining at least 15 percent load on a given circuit will be measured by using the prior year's same month, average peak period load, adjusted for major changes in facilities.
 - b. Baseline Measurement for Determination if 10 Percent Curtailment. At least 10 percent of the total load curtailment must be achieved during each 30 minute period during an OBMC event. This will be determined by measuring the circuit load during an OBMC event, in 30 minute periods, against the same 30 minute periods of the past 10 similar days. If the OBMC event occurred on a business day then the past 10 similar days will include business days only. If the OBMC event occurred on a weekend or holiday day then the past 10 similar days will include weekend or holiday days only. The past 10 similar days will exclude days when the customer: 1) was subject to an OBMC Event, 2) was subject to a CPP event, or 3) was subject to any other demand response program event, or 4) was interrupted.
 - c. An OBMC participant may exclude the following periods from the past 10 similar days used to determine Baseline:
 - (1) Ramp-Up and Ramp-Down of Operations. Customer shall have a period of 15 consecutive calendar days designated in advance both for ramp-up and ramp-down of operations during which period the Baseline will be the hourly average circuit load for the most recent day prior to an OBMC event. Customers requesting an operation ramp-up period must also specify a commensurate operation ramp-down period occurring within one year of the ramp-up period. The 10 day baseline following the ramp-down period must be reduced a minimum of 25 percent from the 10-day baseline immediately prior to the ramp-down period. Customers failing to achieve a 25 percent reduction in the 10-day baseline following a ramp-down period will not be allowed future operation ramp-up periods for two years following the ramp-up period. The customer shall provide at least 10 calendar days prior notice to SCE when exercising this option. (T)
 - (2) Varying Conditions in Operations. Customer shall have up to 10 days per calendar year as determined by the customer and designated in advance to accommodate conditions in the customer's operations that affect the 10-day baseline. The customer shall provide at least seven calendar days' prior notice when exercising this option. (T)

(Continued)

(To be inserted by utility)
Advice 2550-E
Decision _____

Issued by
Akbar Jazayeri
Vice President

(To be inserted by Cal. PUC)
Date Filed Feb 1, 2011
Effective Mar 3, 2011
Resolution _____



Schedule OBMC
OPTIONAL BINDING MANDATORY CURTAILMENT

Sheet 3

(Continued)

SPECIAL CONDITIONS (Continued)

5. Baseline Measurement for Determination of Required Load Curtailment: (Continued) (T)

c. (Continued) (T)

(3) Unplanned Outages. Customer shall have up to two exclusions from the 10-day baseline where unplanned outages or other events cause the circuit load to deviate substantially from normal conditions. The customer shall provide notice within one calendar day after the outage or event when exercising this option. (T)

Customer requests for the above options must be received by SCE in written or e-mail format within the specified time frames or the requested option will not be allowed.

d. Day-Of Adjustment (DOA): The DOA is a ratio of (a) the average load of the first 3 hours of the 4 hours prior to the event to (b) the average load of the same hours from the last 10 similar days, please see Special Condition 5.b. The DOA value shall not be less than 0.80 or greater than 1.20. (T)

Customers may select either the Baseline Measurement or the Baseline Measurement with a DOA for Determination of their baseline. Customers can only select the Baseline Measurement or Baseline Measurement with the DOA for Determination of their baseline for each service account at the initial contract execution time or at the annual contract renewal period. The Baseline Measurement with no adjustment for Determination will be the default if the customer does not make a selection.

(Continued)

(To be inserted by utility)
Advice 2550-E
Decision _____

Issued by
Akbar Jazayeri
Vice President

(To be inserted by Cal. PUC)
Date Filed Feb 1, 2011
Effective Mar 3, 2011
Resolution _____

Schedule OBMC
OPTIONAL BINDING MANDATORY CURTAILMENT

Sheet 4

(Continued)

SPECIAL CONDITIONS (Continued)

6. Participation in Other Programs: OBMC participants who are the only customers on their circuit may participate in an SCE administered capacity interruptible program as long as that program requires the reduction of load to a pre-established firm service level (FSL). OBMC participants are eligible to concurrently participate in other demand response programs (DRP), but shall not be paid for any load curtailment during periods when an OBMC event overlaps a DRP Event.
7. Excess Energy: Excess Energy is the number of kWh consumed in each 30-minute period in an OBMC event that exceeds the required circuit load curtailment. Excess Energy shall be measured using the baseline measurement in accordance with Special Condition 5.b.
8. Charges for Excess Energy: Charges for Excess Energy shall apply to all Excess Energy, for each OBMC event. For each OBMC event during which the customer fails to curtail load to its required level, as measured in 30 minute periods, and hence incurs Excess Energy, the applicable \$/kWh Excess Energy Charge shall be added to the customer's bill.
9. Cost of Equipment: Communication, metering, or any other equipment required to participate in this program is the sole responsibility of the customer(s).
10. Failure to Comply: Failure to curtail circuit load by at least 95 percent of the required reduction, as measured during the entire duration of an OBMC event, on two occasions in any one year shall result in the customer(s) termination on the program and the customer shall be prohibited from participating in an OBMC program for five years.
11. Agreements: All applicable agreements, including an Optional Binding Mandatory Curtailment Agreement Between Customer and Southern California Edison Company (SCE), Form 14-740, must be signed in order to receive service under this Schedule.
12. Holidays are defined as follows:

Holidays are New Year's Day (January 1), Presidents' Day (third Monday in February), (T) Memorial Day (last Monday in May), Independence Day (July 4), Labor Day (first Monday in September), Veterans Day (November 11), Thanksgiving Day (fourth Thursday in November), and Christmas (December 25).

(To be inserted by utility)

Advice 2550-E

Decision _____

Issued by

Akbar JazayeriVice President

(To be inserted by Cal. PUC)

Date Filed Feb 1, 2011Effective Mar 3, 2011

Resolution _____